


GEK-90674B

**PLS
HYBRID SCHEME
SINGLE FSK CHANNEL
FOR UNCOMPENSATED LINES**



GE Power Management

205 Great Valley Parkway
Malvern, PA 19355-1337
Telephone: (610) 251-7000
<http://www.ge.com/edc/pm>

These instructions do not purport to cover all details or variations in equipment nor provide for every possible contingency to be met in connection with installation, operation, or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purpose, the matter should be referred to the General Electric Company.

To the extent required the products described herein meet applicable ANSI, IEEE, and NEMA standards; but no such assurance is given with respect to local codes and ordinances because they vary greatly.

INTRODUCTION**IN****SCHEME DESCRIPTION****SD****CALCULATION OF SETTINGS****CS****HARDWARE DESCRIPTION****HD****MODULES****MO****ACCEPTANCE TESTS****AT****PERIODIC TESTING****PT****SERVICING****SE****SPECIFICATIONS****SP****CONTINUOUS MONITOR****CM****SOFTWARE**

SO

TABLE OF CONTENTS

INTRODUCTION (GEA-11798)	IN-1
SCHEME DESCRIPTION	SD-1A
Directional Comparison Logic	SD-1A
WI/Repeat Keying/LPU/OSB Logic	SD-3A
Trip and Reclose Logic	SD-4A
CALCULATION OF SETTINGS	CS-1A
PD1 and ND - Zone 1 direct tripping functions	CS-1A
Z1	CS-1A
PD1 BIAS	CS-1A
ND BIAS	CS-1A
Negative Sequence Distance Reach Multipliers, N2 and N3	CS-2A
Reach Setting, Z1	CS-2A
PD1 and ND Bias	CS-2A
PDT Positive Sequence Overreaching Distance Function	CS-3A
ZT - Forward Reach	CS-4A
PDT Forward Offset (OFFSET) and	CS-4A
PDT Time Constant (PDT TC)	CS-5A
PDB - Pos. Seq. Distance Blocking Function	CS-6A
PDB - Reach	CS-6A
PDB Time Constant (PDB TC)	CS-7A
PDB Setting Example	CS-7A
POSB - Pos. Seq. Out-of-Step Dist. Function	CS-7A
PDX - Pos. Seq. Auxiliary Distance Function	CS-8A
ZR1 - System Impedance Angle	CS-8A
NT and NB - Negative Sequence Directional Functions	CS-9A
IT, IB, I2 SHUNT and I0 SHUNT	CS-10A
IB Setting (IB Bias)	CS-10A
IT Setting (IT Bias)	CS-10A
I2 SHUNT setting (I2 SHUNT)	CS-11A
I0 SHUNT setting (I0 SHUNT)	CS-11A
IT Bias	CS-12A
I2 SHUNT	CS-12A
I0 SHUNT	CS-12A
IDT - Overcurrent Direct Tripping Function	CS-15A
I1T - Pos. Seq. Overcurrent Line Pickup Function	CS-16A
ITOC - Time Overcurrent Function	CS-17A
TOC PU	CS-17A
TOC K1	CS-17A
TOC DIR	CS-17A
TD	CS-17A
IMA, IMB, IMC - Phase Current Functions	CS-18A
3I0 - Zero Sequence Current Function	CS-18A
OSB1, OSB2 - Out-of-Step Blocking	CS-18A
OSB1	CS-18A
OSB2	CS-18A

CALCULATION OF SETTINGS (CONT'D.)

Logic Timers	CS-19A
ZONE 2	CS-19A
ZONE 3	CS-19A
WEAK INFEED	CS-19A
TL1	CS-19A
TL9	CS-19A
TL24	CS-19A
TL25	CS-19A
TL26	CS-19A
TL13, TL22- Transfer Trip Timers	CS-20A
Reclosing Control	CS-20A
Lockout Reclosing	CS-20A
Inhibit Reclosing	CS-21A
Sequential Reclosing	CS-21A
Contact Converters	CS-22A
Channel Keying Outputs	CS-23A
Key Xmtr 1 (K1)	CS-23A
Key Xmtr 2 (K2)	CS-23A

HARDWARE DESCRIPTION

Case Assembly	HD-1A
Construction	HD-1A
Electrical Connections and Internal Wiring	HD-1A
Identification	HD-1A
Printed Circuit Board Modules	HD-1A
Basic Construction	HD-1A
Identification	HD-2A
Receiving, Handling and Storage	HD-2A
Installation	HD-2A
Environment	HD-2A
Mounting	HD-2A
External Connections	HD-2A
Surge Ground Connections	HD-3A
Directional Check	HD-3A

MODULE DESCRIPTION

ADM10-	MO-1A
AEM10-	MO-1A
AEM11-	MO-2A
DNM10-	MO-2A
DPM10-	MO-2A
DPM11-	MO-3A
DSM20-	MO-4A
TAM101	MO-5A
ULM15-	MO-5A
ULM161	MO-5A
ULM171	MO-6A
ULM181	MO-6A
ULM19-	MO-7A
PSM21-	MO-7A
	MO-8A

ACCEPTANCE TESTS

Acceptance Tests	AT-1A
Required Settings	AT-1A
Test Equipment	AT-1A
Test Connections	AT-1A
Initial Relay Settings	AT-1A
General Instructions	AT-3A
Level Detector Tests	AT-3A
Fault Detector Test	AT-3A
IT Test	AT-3A
IMA Test	AT-3A
IMB Test	AT-3A
IMC Test	AT-3A
3I0 Test	AT-3A
I1S Test	AT-3A
I1T Test	AT-3A
IB Test	AT-3A
IDT Test	AT-4A
TOC PU Test	AT-4A
Not VA Test	AT-4A
Not VB Test	AT-4A
Not VC Test	AT-4A
Positive Sequence Distance Tests	AT-5A
Long Reach Scheme Setup (PD1)	AT-5A
Short Reach Scheme Setup (PD1)	AT-5A
PD1 Reach	AT-5A
PDX Reach	AT-6A
PDT Reach	AT-6A
POSB Reach	AT-6A
PDB Reach	AT-6A
Negative Sequence Distance Tests	AT-6A
ND	AT-6A
ND ZONE 2 REACH	AT-6A
ND ZONE 3 REACH	AT-7A
NDD	AT-7A
NDD ZONE 2 REACH	AT-7A
NDD ZONE 3 REACH	AT-7A
Negative Sequence Directional Tests	AT-7A
NT Unit	AT-7A
NB Unit	AT-7A
Phase Selectors	AT-7A
Dielectric Tests	AT-8A

PERIODIC TESTING

Testing the PLS with Different Settings	PT-1A
Tolerance	PT-1A
Current Level Detectors	PT-1A
IMA, IMB, IMC	PT-1A
3I0	PT-2A
I1T	PT-2A
IB	PT-2A
IT	PT-2A
Fault Detector Pickup	PT-4A
Directional Tests	PT-4A
ITOC (Non-directional)	PT-4A
ITOC (directional)	PT-4A
IDT (Non-directional)	PT-5A
IDT (directional)	PT-5A

PERIODIC TESTING (CONT'D.)

Positive-Sequence Distance Units	PT-5A
PD1	PT-5A
PDT	PT-6A
PDB	PT-7A
POSB	PT-8A
PDX	PT-9A
Negative-Sequence Distance Units	PT-10A
NDD	PT-10A
NDD Zone 2 Reach	PT-10A
NDD Zone 3 Reach	PT-10A
ND	PT-11A
ND Zone 2 Reach	PT-11A
ND Zone 3 Reach	PT-12A
Negative Sequence Directional Tests	PT-12A
NT Unit	PT-12A
NB Unit	PT-12A
Phase Selectors	PT-12A
XTM Test Plugs	PT-13A
Terminal Designation	PT-13A
XTM Test Circuit Connections	PT-13A
Test Plug Insertion	PT-14A
Card Extender	PT-14A

SERVICING

Spares	SE-1A
Without the Continuous Monitor Module	SE-1A
With the Continuous Monitor Module	SE-1A
Power Supply Module	SE-2A

SPECIFICATIONS

Ratings	SP-1
Burdens	SP-1
Contact Data	SP-1
Replica Impedance Angle Settings	SP-2
Accuracy	SP-2
Dimensions	SP-3
Weight	SP-3

CONTINUOUS MONITOR

Basic Operation	CM-1A
Additional Function	CM-1A
Access of Stored Data	CM-1A
Local Access	CM-2A
Remote Access	CM-2A
Clearing the Stored Data	CM-2A
Modes of Operation	CM-4A
Local-Display Mode	CM-4A
Serial-Data-Link-Access Mode	CM-5A
Continuous Monitor Adjustments	CM-5A
Continuous Monitor Serial Link Use	CM-5A
CHECKSUM	CM-6A

SOFTWARE

SET PLS	SO-1
CONTMON	SO-1
	SO-1

LIST OF FIGURES

FIG	TITLE	PAGE
SD-1	MOD 10™ Mnemonic Legend	SD-7A
SD-2	Logic and Internal Diagram Legend	SD-7-8A
SD-3	Logic Diagram	SD-9-10A
SD-4	Elementary Diagram	SD-11A
SD-5	Directional Comparison/Direct Tripping	SD-12A
SD-6	Trip and Reclose Logic	SD-12A
SD-7	WI/Repeat Key/LPU/OSB Logic	SD-13A
CS-1	Sample Power System	CS-3A
CS-2	PDT Function	CS-4A
CS-3	PDB Function	CS-6A
CS-4	PDX Function	CS-8A
CS-5	Connections for Communication Channels	CS-24A
CS-6	Time Overcurrent Curve	CS-26A
HD-1	PLS Relaying System, Front View	HD-4A
HD-2	PLS Relaying System, Rear View	HD-4A
HD-3	Outline and Mounting Dimensions	HD-5A
HD-4	XTM Connections for Dir. Ck. (Tripping Direction)	HD-6A
HD-5	XTM Connections for Dir. Ck. (Non-Trip Direction)	HD-6A
MO-1	Module Locations	MO-9A
MO-2	ADM10-	MO-10A
MO-3	AEM10-	MO-10A
MO-4	AEM11-	MO-11A
MO-5	DNM10-	MO-11A
MO-6	DPM10-	MO-12A
MO-7	DPM11-	MO-12A
MO-8	TAM101	MO-13A
MO-9	ULM15-	MO-13A
MO-10	ULM171	MO-14A
MO-11	ULM181	MO-14A
MO-12	ULM19-	MO-15A
MO-13	PSM21-	MO-15A
AT-1	Level Detector Test Connections	AT-9A
AT-2	Not VA, VB, VC Test Connections	AT-9A
AT-3	Positive-Sequence Distance Test Connections	AT-10A
AT-4	Negative-Sequence Distance Test Connections	AT-10A
AT-5	Negative-Sequence Directional Test Connections	AT-11A
AT-6	IT Test Connections	AT-11A

LIST OF FIGURES (CONT'D.)

FIG	TITLE	PAGE
SE-1	Analog Block Diagram (I & V Processing)	SE-6A
SE-2	Analog Block Diagram (Reach Adj. & Polarizing Ckts)	SE-7A
SE-3	Analog Block Diagram (IDT, TOC, & POS SEQ)	SE-8A
SE-4	Analog Block Diagram (IT,IB,NT,NB,ND,NDD)	SE-9A
SE-5	Analog Block Diagram (Phase Selectors)	SE-10A
CM-1	Continuous Monitor Operation	CM-7A
CM-2	Serial Data Link Connection	CM-7A
CM-3	Continuous Monitor Phone Connection	CM-8A
CM-4	Connection for Multiple Continuous Monitors	CM-8A
CM-5	MIM Module Connections	CM-9A
CM-6	Front Panel & Internal Switches, TAM101	CM-10A

LIST OF TABLES

TABLE	TITLE	PAGE
SD-1	Logic Diagram Device Location Table	SD-14-15A
CS-1	Time Constant & Forward Offset Settings	CS-5A
CS-2	Fault Study of Figure CS-1	CS-15A
CS-3	PLS1B Settings Worksheet	CS-25A
M0-1	ULM171 Module Targets	MO-6A
AT-1	Front Panel Settings	AT-2A
AT-2	Relay Settings	AT-2-3A
AT-3	Reach Test Tolerances	AT-6A
PT-1	Test Tolerances	PT-1A
PT-2	Phase Angle Settings	PT-6A
PT-3	Test Tolerance	PT-6A
PT-4	Test Tolerances	PT-7A
PT-5	Voltage/Current Settings	PT-7A
PT-6	PDB Test Current Values	PT-8A
PT-7	POSB Test Current Values	PT-8A
PT-8	PDX Test Current Values	PT-9A
PT-9	NDD Test Voltage/Current	PT-10A
PT-10	ND Test Voltage/Current	PT-11A
SE-1	PLS Test Point Table	SE-4A
SE-2	PLS Continuous Monitor Point Table	SE-5A
SP-1	Reach Settings of Distance Units	SP-2
SP-2	Reach Multiples of PD1 and PDT	SP-2
SP-3	Adjustable Logic Timers	SP-3

LIST OF REVISIONS

Since the last printing, the following revisions have been made:

Figure	Page Number
SD-3 Logic Diagram	SD-9A
SD-3 Logic Diagram	SD-10A
SD-4 Elementary Diagram	SD-11A
MO-7 DPM11 Module	MO-12A
AT-1 Level detector test connection	AT-9A

MOD-10 PLS1 MODULAR TRANSMISSION LINE PROTECTION SYSTEM

PLS1 MOD-10 System for Single Pole/Three pole Tripping Applications

The PLS1 MOD-10 System is a polyphase, high speed, multi-zone directional comparison pilot relaying scheme for transmission line protection. The distance, directional, and overcurrent measuring units operate on combinations of positive, negative, and zero sequence quantities. The PLS design is based on the well proven principles used in GE's SLYP-SLCN/SLYP-SLYN MODIII static terminal equipments and adds enhancements with new design concepts and techniques.

The PLS1 provides excellent performance on series compensated lines, lines adjacent to series compensated lines, and uncompensated lines. The PLS is able to detect high resistance ground faults and is immune to the effects of zero sequence mutual coupling. The phase selectors perform reliably to provide single pole tripping with the added benefit that no user settings are required. When intercircuit faults on double circuit lines are judged likely to interfere with the phase selection process special phase-identified scheme logic can be supplied which, coupled with the necessary channel equipment, will provide reliable phase selection.

The measuring units of the PLS use an amplitude comparator coupled with an integrator - designated an "energy comparator" - which provides an operating time based on fault severity. This permits operating time in the order of 3-4 milliseconds for close-in severe faults that will be most critical to system stability.

The entire PLS system is supervised by a fault detector function which prevents operation unless a system disturbance has occurred.

A Microprocessor Monitoring Interface (MMI) module is available to provide instantaneous notification of any abnormal conditions in the PLS as well as functional response data for each PLS trip operation.

OPERATING CHARACTERISTICS

Operating time

Based on fault severity.

Close-in severe faults - 3-4 milliseconds.

Remote end faults - 16-24 milliseconds.


Application

Series compensated or uncompensated lines.

Single-pole tripping.

High sensitivity for ground faults- can detect fault resistances up to 700 ohms for a radial feed condition.

Suitable for two or three terminal lines.



DESIGN FEATURES

- Use of programmable logic devices (PLDs) to implement combinational logic.
- Use of "energy comparators" for measuring units.
- Line pickup (close into fault) circuit.
- Out-of-step blocking.
- Fault detector.
- Optional MMI module.

The Microprocessor Monitoring Interface (MMI) module continuously monitors up to 40 points in the PLS system. The MMI module compares the status of the fault detector with the status of the monitored points to recognize abnormal conditions in the PLS. This information is stored in non-volatile memory until accessed and/or removed by the user. The MMI module is also activated when a trip occurs and stores in a separate area of non-volatile memory all of the monitored internal responses associated with the trip. Trip data for up to five events can be stored. Trip data and monitor data are accessed by pushing a button and viewing an LCD display located on the front panel of the module. Data can also be accessed remotely via an optional RS232 interface available with the MMI.

HARDWARE & PACKAGING

Draw-out modular construction

Plug-in modules for test and maintenance.

Standard modular test connection plugs for current/voltage injection testing.

High-reliability components

168 hour burn-in of active semiconductors.

Conservative derating for long life.

Suitable for harsh environment

Temperature: - 20°C to + 65°C ambient.

IEEE/ANSI SWC surge tests (C37.90.1).

GE RFI interference test.

IEC surge withstand test.

MOD-10 PLS1 MODULAR TRANSMISSION LINE PROTECTION SYSTEM

TECHNICAL DATA

Ratings

Voltage	110/120 vac
Frequency	50 or 60 hz
Current	$I_N = 1$ or 5 amperes
DC control	48v range: 34 to 60 volts 110/125v range: 88 to 156 volts 220/250v range: 176 to 300 volts

Maximum Permissible Currents

Continuous	$2 \times I_N$
Three second	$50 \times I_N$
One second	$100 \times I_N$

Insulation Test Voltage	2 kV 50/60 hertz, one minute
Impulse Voltage Withstand	5 kV peak, 1.2/50 milliseconds, 0.5 joule
Interference Test Withstand	1 MHz, 2.5 kV peak, decay time of 3 to 6 cycles to 1/2 value.

Trip Output Contacts	Continuous rating = 3 amperes Make and carry for tripping duty = 30 amperes (per ANSI C37.90) Break 180 VA resistive @ 125/250 VDC Break 60 VA inductive @ 125/250 VDC
----------------------	---

Thyristor (SCR)	Same as trip contacts except no interrupting rating
-----------------	---

Auxiliary Contact Ratings	Continuous rating = 3 amperes Make and carry for 30 seconds = 5 amperes Break 25 watts inductive @ 125/250 VDC Maximum: 250volts or 0.5 amperes
---------------------------	--

Ambient Temperature Range	Storage: -30 to +75 degrees C Operation: -20 to +65 degrees C
---------------------------	--

Humidity	95% without condensing
Weight	45 pounds (20 kilograms)
Dimensions	
Height	14 inches (356 millimeters) 8 rack units
Width	19.1 inches (484 millimeters) standard 19 inch rack
Depth	16 inches (406 millimeters)



NOMENCLATURE SELECTION GUIDE

PLS Single-Pole Tripping Models

PLS1B*****B

1	Single pole tripping schemes
B	8 rack unit case
1	1 ampere rated current
5	5 ampere rated current
5	50 hz rated frequency
6	60 hz rated frequency
A	Hybrid scheme dual FSK channels phase identified channel logic
B	Hybrid scheme dual FSK channels 1P/3P channel logic
C	Hybrid scheme single FSK channel
X	Special customer logic
0	48 vdc
1	110/125 vdc
2	220/250 vdc
CL	Suitable for series compensated lines
UL	Suitable for long, uncompensated lines
UB	Suitable for short, uncompensated lines: Z1 = 0.25-6.25; Z2 = 2-50
XX	Special customer reach/application
1	Solid state tripping outputs(SCR)
2	Contact tripping outputs
A	No options
B	Continuous monitor
C	12 additional DLA points (24 total)
D	Continuous monitor and 12 additional DLA points (24 total)
X	Special customer options
B	Revision level

Sample:

PLS1B56B0UL1BB - PLS Rated 5 amps, 60 Hz, 48 vdc, suitable for single pole tripping on long, uncompensated lines, dual channel logic, (1 pole/3 pole), SCR output, MMI continuous monitor, revision B

**GE Meter & Control
Business Department**

SCHEME DESCRIPTION

This logic description applies to a PLS relaying system configured as a hybrid scheme and equipped to implement single-pole tripping. One frequency shift channel (power line carrier or audio tone) is required to complete the scheme. The description applies to Figure SD-3 which is used only as a means of describing the fundamental performance of the scheme. The logic has been reduced to the following three areas:

1. Directional Comparison Logic - a brief diagram showing the pilot and direct tripping portion of the overall logic.
2. Trip and Reclose Logic - a brief diagram showing the phase selected trip outputs and the reclose initiate, inhibit reclose and lockout reclose portions of the overall logic.
3. Weak Infeed/Repeat Keying/Line Pickup/Out-of-Step Logic - a brief diagram showing the weak infeed, repeat keying, line pickup and out-of-step portions of the overall logic.

Each of these areas will be described separately.

Directional Comparison Logic

The directional comparison logic is configured as a hybrid scheme and is used to determine whether the fault is internal or external to the protected transmission line. For internal faults, a trip signal will be issued and the phase selection circuitry will then allow the faulted phase or phases to be tripped (depending on the type of fault that has occurred).

Under normal conditions (infeed at all terminals of the transmission line that is sufficient to operate the tripping functions) a hybrid scheme operates exactly like a permissive overreaching transferred tripping scheme. For internal faults, one or more of the tripping functions at each terminal of the line will detect the fault and key their respective transmitter to the trip frequency. Receipt of the trip frequency and operation of one or more of the tripping functions will allow tripping to be initiated at each terminal of the line. Tripping will not be initiated for external faults because the tripping functions at least one of the terminals of the line will not see the fault hence tripping will be blocked at all terminals. If, for an internal fault, the infeed at one or more of the terminals is insufficient to operate at least one of the tripping functions, then a permissive tripping scheme will not operate because it is necessary for the fault to be detected at all terminals of the line. A hybrid scheme uses blocking functions along with some additional logic to overcome this deficiency by allowing the trip signal received from a strong terminal to be echoed (repeated) at the weak terminals and so allow the strong terminals of the line to be tripped. The weak terminals may then be tripped by weak infeed circuitry to be described later. The signal can be repeated at the weak terminals only if the blocking functions have not operated; i.e., the signal will be repeated for internal faults only. For external faults, one or more of the blocking functions will operate to block the repeat of the signal thus tripping will be blocked at all terminals of the line.

SD

Figure SD-5 shows the directional comparison logic for the PLS hybrid scheme. The following functions are used in the scheme:

Permissive Tripping

- NDD - negative sequence distance
- NT & IT - negative sequence directional and overcurrent
- PDX - positive sequence distance

Blocking

- PDB - positive sequence distance unit
- NB & IB - negative sequence directional and overcurrent

Direct Tripping

- PD1 - positive sequence distance unit (Zone 1)
- PDT - positive sequence distance unit (Pilot Trip)
- NDD - negative sequence distance
- ND - negative sequence distance
- IDT - zero sequence overcurrent with positive sequence restraint
- ITOC - time overcurrent backup (zero sequence with positive sequence restraint)

For an internal fault, one or more of the tripping functions will operate and apply one of the inputs to the comparer AND16 and key the permissive transmitter via OR10, AND15, OR18 and OR28. Receipt of the trip signal at CC1 will apply another of the inputs to the comparer while the NOT input will be absent because the blocking functions will not have operated, or will be prevented from operating, for this internal fault. A trip permission output will then be produced via AND16, OR14, TL1, OR15 and AND17.

The channel echo (repeat) circuitry, made up of the receiver, TL11 and AND34 works as follows: if a trip signal is received at CC1 and there is no output from the blocking functions the NOT input to AND34 will be absent. Thus, AND34 will produce an output to key the permissive transmitter (see above) for the 50 millisecond pickup time of timer TL11. After 50 milliseconds, no further keying will be permitted because timer TL11 will time out and apply a NOT input to AND34 to stop keying. Thus TL11 and AND34 perform a knockdown circuit to prevent the keying circuits of all transmitters from being locked in.

A priority system is used between the tripping and blocking functions to establish transient blocking during fault current reversals following clearing of an external fault on a parallel line. For an external fault, PDB or NB will operate and:

1. Apply the NOT input to AND15 to block transmitter keying.
2. Apply the NOT input to AND16 to block pilot tripping.
3. Apply the NOT input to AND11 to block zone 1 direct tripping by PD1.
4. Energize timer TL30/24 or TL25 respectively.

These timers are set with a long dropout (time delay dependent on the application) so that when the fault is cleared the NOT inputs to AND11, AND15 and AND16 will not be removed immediately. Consequently, transmitter keying and pilot/direct tripping will be prevented even if one or more of the tripping functions were to momentarily operate on a current reversal, or on a voltage reversal. Note that the operation of the tripping functions will cause the blocking functions to reset by applying a NOT input to AND2 and/or AND65 but that the reset will not be complete until the dropout time of the respective blocking function timer. The NOT inputs to

AND2 and AND65 are required during the initial occurrence of an internal fault. For this condition the blocking functions must not produce an output else tripping would be blocked. For example, for a close-in internal three-phase fault, the blocking function (PDB) may try to operate because it is offset to include the relay location within its operating characteristic. The tripping function (PDT) will also operate however, and by virtue of its design will operate faster than the blocking function. PDT will block PDB operation by applying the NOT input to AND65 and will also block NB operation by applying one of the NOT inputs to AND2. Note that NB may try to operate on the negative sequence quantities produced during the asymmetrical occurrence of the three-phase fault, thus the reason for inhibiting it with PDT. A similar priority system is established between NT and NB and is used primarily during unbalanced faults during which PDT is unlikely to operate. PDT will also initiate fast reset of timer TL30/24 in the event that NB operated before PDT on the occurrence of an internal three-phase fault.

The PDX function (not shown on the logic diagram) has a separate reach adjustment from the other positive sequence distance functions and is used with a separate timer to provide an independent zone 2 function that can be set to coordinate with zone 1 functions in adjacent lines.

The direct tripping functions listed previously operate to trip directly and independently of the pilot portion of the scheme. The output of any of these functions will initiate trip permission directly through OR214, OR14, OR15 and AND17.

Weak Infeed/Repeat Keying/Line Pickup Trip/Out-of-Step Logic

Simplified logic for the weak infeed trip circuitry is shown in Figure SD-7 and is composed of AND14, the receiver (via OR12), OR11, OR37 and TL16. Assume that an internal fault has been detected at the remote terminal of a transmission line and that the local blocking functions have not operated. Therefore, the receiver at the local terminal will be producing an output and there will be no output from OR37 because none of the blocking functions are up. If the fault detector (FD), or the overcurrent blocking supervision function (IB), or the overcurrent tripping supervision function (IT) are picked up, or if all three voltage detectors are dropped out, then OR11 will produce an output. Consequently, AND14 will have all of its upper inputs present, and if it is assumed for the moment that the lower input to AND14 is present, then AND14 will produce an output. This output is applied to security timer TL16 which will issue a trip permission when it times out.

The lower input to AND14 comes from the open-pole sequencing circuitry which is required to allow the weak infeed circuitry to perform at the inception of a fault, to remove it from service during the open-pole period and to re-insert it on the inception of a fault during this period, or following the open-pole period. The circuitry works as follows. At the inception of a fault, NOT4 will be producing an output thus the lower input to AND14 will be present, and tripping will be as described above. When the faulted phase is tripped, timer TL26 will time out to apply the middle input to AND214 via OR211 and to inhibit any phase selector output which in turn applies the upper input to AND214 via NOT212 and OR212. When the faulted phase is cleared by opening the breaker, the respective open-pole detector (AND7, AND8, or AND9) will pick up and apply the lower input to AND214 via OR32. AND214 will thus produce an output which will be sealed in on the open-pole detector via OR211 and OR212. The output of AND214 without a concurrent phase selector output will allow AND71 to produce an output which will reset NOT4 and thus remove the lower input from AND14 so that weak infeed tripping will be blocked. If a subsequent fault occurs during the open pole period, one of the phase selectors will pick up and apply the NOT input to AND71 via OR210. NOT4 will then produce an output which will apply the lower input to AND214 thus re-instating weak infeed tripping. If no fault occurs, weak infeed tripping will be re-instated when the open-pole detector resets after the breaker is successfully reclosed.

SD

Timer TL27 (following AND214) will be energized during the open-pole period and its output is used to arm the three-pole tripping circuitry so that any faults occurring during the open-pole period, or during reclosure of the breaker will be tripped three-pole.

The line pickup logic is used to initiate tripping when a line is energized by a manual closure or on reclosing following a three-pole trip. The circuitry is composed of AND41, TL4, TL7, AND42, TL8, OR42, OR41, AND60, AND43 and CC6. The circuitry works as follows. AND41 will produce an output when the line is de-energized as indicated by outputs from all three open-pole detectors. At that time, timer TL7 will be energized and when it times out 150 milliseconds later, it will apply the top input to AND42 and the bottom input to AND60. The line pickup circuit is now armed and ready to trip if any of the following functions pick up when the line is energized:

1. PDT - positive sequence tripping function
2. NDD - negative sequence tripping
3. I1T - positive sequence overcurrent function

If none of these functions operate when the line is returned to service then timer TL7 will be fast reset 3 cycles (TL4 pickup time) after all three phase voltages return to normal as indicated by no output from OR7.

Note that neither NDD or PDT will pick up when closing into a bolted three-phase fault (such as when the grounding chains are left on the line), hence the reason for the I1T function. This function must be set to detect the minimum three-phase fault for a fault at the relay location. It is desirable to set this function above the maximum load current, however, it must be set below the maximum load current if conditions require it. Timer TL8 is provided for use in those applications where I1T must be set below full load current and where high speed reclosing is used at each terminal of the transmission line. This timer allows time for the voltage to return to normal and remove line pickup tripping from service before load current can initiate a trip following a simultaneous high speed reclose. If simultaneous reclosing is not used at each end of the line, then faster tripping can be attained on closing into a fault by applying a continuous input to CC6 which allows timer TL8 to be continuously bypassed via AND43. Timer TL8 should be bypassed if I1T can be set above full load regardless of whether or not simultaneous high speed reclosing is used.

Out-of step blocking circuitry is provided and the output is routed through 2 switches (OSB-1 and OSB-2). The output of these switches is routed through various points in the logic to prevent certain outputs during an out-of-step condition. See the overall logic diagram 0153D7729 for how these switches may be used.

Trip and Reclose Logic

The trip logic is used to determine which pole or poles of the breaker should be tripped following a trip permission from the directional comparison logic. The simplified trip logic is shown in Figure SD-6. The logic works as follows. Trip permission from the directional comparison logic is applied to AND21, AND22 and AND23 via OR16. For single-line-to-ground (SLG) faults, only the phase selector associated with the faulted phase will operate. An output from the phase selector will apply the second input to its associated AND circuit (21, 22 or 23) and initiate tripping through its associated logic chain. For example, if phase "A" is faulted, then phase "A" will be selected and an input will be applied to AND21 via OR21A. The output of AND21 will initiate tripping via OR24 and AND30. Note that the second input to AND30 comes from the fault detector (FDP) that is an integral part of the PLS scheme. This fault detector will operate only for faults on or in the vicinity of the protected line and provides security by insuring that tripping cannot be initiated unless a fault has been detected by two independent functions. For multi-phase faults, the phase selector circuitry will issue a three-pole trip output which will be

applied to AND21, AND22 and AND23 concurrently. If trip permission is given, then all three poles of the breaker will be tripped simultaneously.

Sensitive overcurrent detectors (IMA, IMB AND IMC) are provided as part of the scheme to provide seal-in circuits in the event of a breaker failure. The seal-in is required to maintain the input to the breaker failure scheme in the event a failure did occur. The seal-in circuits work as follows.

For a three-pole trip, at least one of the overcurrent detectors will be up thus OR31 will be producing an output which is applied to the bottom input of AND48. The top input to AND48 comes from OR20A initially and this input will be sealed in from AND39 which will be energized for any three-pole trip. The middle input to AND48 and the bottom input to AND39 will initially be a trip permission input from OR16, but these inputs will be sealed in by an output from AND48. Thus, once a three-pole trip occurs, the trip buses will be sealed in by the sensitive overcurrent detectors, and will not be reset until all three of the detectors are reset. Note that the fault detector input is also sealed in once a trip has occurred (not shown on logic)

For a single-pole trip only the faulted phase will be tripped. In this situation, the trip output associated with the faulted phase only will be sealed in. For example, assume a phase "A" trip. The output of AND30 will be sealed in via AND24, OR24 and the current detector IMA and will remain sealed in until IMA resets.

Links are provided in the system logic so that an inhibit reclose output will be produced if a trip is initiated and there is an output from any or all of the following functions which may be independently selected via the appropriate link:

1. PDX, positive sequence distance function, zone trip
2. PDT, positive sequence distance function, pilot trip
3. PD1, positive sequence distance function, zone 1 trip
4. ND, negative sequence distance function, direct trip
5. Any multi-phase fault as indicated by the two-out-of-three selection logic
6. A direct transferred trip input from external equipment (if used, not selectable by link)

The inhibit reclose outputs are sealed in via a loss of voltage and are provided for use in sequential reclosing schemes; i.e., reclosing would be inhibited via this output until the voltage returns to normal at which time reclosing would then be permitted. The basic premise behind sequential reclosing is to allow the end where the fault is the least severe to reclose first and then allow the other end to follow if the reclosure is successful as indicated by the return of voltage.

The PLS System does not identify a three-phase fault only, but the following can be ascertained. The PDX and PDT functions will operate for all three-phase faults on the line and may operate for some severe unbalanced faults, including single-line-to-ground (SLG) faults if they are severe enough. Of the two functions, the PDT is the least likely to operate for SLG faults. The PD1 function will operate for all three-phase faults within its reach, for some severe line-to-line (L-L) and line-to-line-to-ground (L-L-G) faults but it will not operate for any SLG faults.

Although these outputs are designated inhibit reclose and are normally used in sequential reclosing schemes, there is no reason why they can not be used to block reclosing. Therefore, if it is desired to block reclosing for all three-phase faults and if it is acceptable to block reclosing for

some severe L-L and L-L-G faults then these contacts can be used. Note that blocking of reclosing for the severe L-L and L-L-G faults would be beneficial to the power system. Links are provided in the system logic so that a lockout reclose output will be produced if a trip is initiated and there is an output from any or all of the following selectable functions:

1. Zone 2 timer, time-delayed trip
2. Zone 3 timer, time-delayed trip
3. ITOC, time overcurrent trip
4. CC8 (external three-pole trip)

These outputs are not sealed by an undervoltage condition as are the inhibit reclose outputs, and persist only as long as a trip output is produced. They can be used to lockout reclosing by energizing the appropriate input in the reclosing relay.

BFI	BREAKER FAILURE INITIATE	NB	NEGATIVE-SEQUENCE BLOCKING
BLK ZN	BLOCKING ZONE	DIRECTIONAL FUNCTION	
CC	CONTACT CONVERTER	ND	NEGATIVE-SEQUENCE DISTANCE
CFA	CHANNEL FAILURE ALARM	FUNCTION	
CHTR	CHANNEL TRIP	NDD	PERMISSIVE NEGATIVE-SEQUENCE
CK, CLK	CLOCK	DISTANCE FUNCTION	
CM	CONTINUOUS MONITOR POINT	NT	NEGATIVE-SEQUENCE TRIPPING
DLA	DATA LOGGING ALARMS	DIRECTIONAL FUNCTION	
FD	FAULT DETECTOR	OS	OUT OF STEP
FDP	FAULT DETECTOR SUPERVISION	OSB	OUT OF STEP BLOCKING
FF	FUSE FAILURE	PD1	POSITIVE-SEQUENCE ZONE 1 DISTANCE
I ₀₀	PHASE TO PHASE CURRENT (MT OVERCURRENT	FUNCTION	
I ₀₀	SUPERVISION)	PDB	POSITIVE-SEQUENCE BLOCKING
I ₁	LINE PICKUP SUPERVISION	DISTANCE FUNCTION	
I _{1S}	POSITIVE-SEQUENCE SUPERVISION	PDT	POSITIVE-SEQUENCE OVERREACHING
I _{1T}	POSITIVE-SEQUENCE TRIPPING SUPERVISION	DISTANCE FUNCTION	
I _{BT}	BLOCKING OVERCURRENT SUPERVISION	PDX	AUXILIARY ZONE POSITIVE-SEQUENCE
IDT	DIRECT TRIP OVERCURRENT	DISTANCE FUNCTION	
IM	OVERCURRENT SUPERVISION	POSB	POSITIVE-SEQUENCE OUT-OF-STEP
IMA	PHASE A SENSITIVE OVERCURRENT FUNCTION	BLOCKING FUNCTION	
IMB	PHASE B SENSITIVE OVERCURRENT FUNCTION	PTFF	POTENTIAL FUSE FAILURE FUNCTION
IMC	PHASE C SENSITIVE OVERCURRENT FUNCTION	RB	RECLOSE BLOCK
I _{0-KI}	ZERO-SEQUENCE OVERCURRENT SUPERVISION	RCVR	CHANNEL RECEIVER
I _{0-KI}	ZERO-SEQUENCE OVERCURRENT WITH POS. -	RI	RECLOSE INITIATE
	SEQUENCE RESTRAINT	SUP	SUPERVISION
IPB	PILOT BLOCKING	TAR	TARGET
IPT	PILOT TRIPPING	TH	THRESHOLD
IR	RECLOSE INHIBIT	TOC	TIME OVERCURRENT BACKUP
IT	TRIPPING OVERCURRENT SUPERVISION	TP	TEST POINT
ITOC	TIME OVERCURRENT SUPERVISION	TR BUS	TRIP BUS
LR	LOCKOUT RECLOSE	TT	TRANSFER TRIP
M1	PHASE-PHASE ZONE 1 DISTANCE FUNCTION	V ₁	POSITIVE-SEQUENCE UNDER VOLTAGE
MB	MHO BLOCKING FUNCTION	FUNCTION	
MG1	PHASE-GND ZONE 1 DISTANCE FUNCTION	V _A	PHASE A UNDER VOLTAGE FUNCTION
MOB	MHO OUT OF STEP BLOCK FUNCTION	V _B	PHASE B UNDER VOLTAGE FUNCTION
MT	PHASE-PHASE OVERREACHING PERMISSIVE TRIP	V _C	PHASE C UNDER VOLTAGE FUNCTION
	FUNCTION	V _P	POLARIZING VOLTAGE
MTG	PHASE-GND OVERREACHING PERMISSIVE TRIP	W _I	WEAK-INFEED TRIP
	FUNCTION	XMTR	CHANNEL TRANSMITTER

SD



Figure SD-1 (0286A2774) MOD 10TM Mnemonic Legend


Figure SD-2 (0286A2775 Sh.1 [3]) Logic and Internal Diagram Legend

FLIP FLOPS

REFERENCE NO.
JK FLIP FLOP
 Q & \bar{Q} OUTPUTS OCCUR
 ON POSITIVE EDGE OF
 CLOCK. R MUST BE LOW
 FOR OPERATION.

TRUTH TABLE


J	K	Q
L	L	NC
L	H	H
H	L	L
H	H	TOGGLE



D FLIP FLOP
 Q & \bar{Q} OUTPUTS OCCUR
 ON POSITIVE EDGE OF
 CLOCK.

TRUTH TABLE

D	Q
L	L
H	H



RS FLIP FLOP
 Q & \bar{Q} OUTPUTS OCCUR
 ON POSITIVE EDGE OF
 CLOCK.

TRUTH TABLE

R	S	Q
L	L	NC
H	L	L
L	H	H
H	H	?

NOTE:

H=1 (HIGH INPUT)
 L=0 (LOW INPUT)
 NC= NO CHANGE
 \bar{Q} =INVERSE OF Q

Figure SD-2 (0286A2775 Sh.2 [3]) Logic and Internal Diagram Legend




Figure SD-2 (0286A2775 Sh.3 [3]) Logic and Internal Diagram Legend




Figure SD-3 (0153D7729 SH.1 [7]) Logic Diagram





Figure SD-3 (0153D7729 Sh.2 [9]) Logic Diagram

SCHEME DESCRIPTION

GEK-90674






Figure SD-5 (0179C8269 Sh.1 [1]) Directional Comparison and Direct Tripping Logic




Figure SD-6 (0179C8269 Sh.2 [1]) Trip and Reclose Logic




Figure SD-7 (0179C8269 Sh.3 [2])
Weak Infeed/Repeat Key/Line PU/Out of Step Logic

LOCATION	OR #	FUNCTION
1F2	1	Any positive sequence unit
1E5	2	Any negative sequence unit
1D2	3	Zone III Supervision
1D2	4	Zone II Supervision
1E2	5	Zone II input (TL2)
1E2	6	Zone III input (TL3)
1F9	7	Any phase undervoltage
1D4	9	WI circuit
1E3	10	local trip
1D4	11	O/C input to WI (AND 14)
2E4	12	Received Permission
1E5	13	PDI + PPID to DT
1C3	14	PT or DT input to TL1
1C3	15	PT or DT to And17 to Trip Permission
1B3	16	Trip Permission
2E8	17	PDT & AND76 + Selection LogiG
1B3	18	PT keying output
1F7	19	Received & Local DT input
1E8	20A	3 Pole Trip Permission
2D8	20B	3 Pole Trip Permission
2D7	21	ϕ A Both A & B series
2D7	22	ϕ B ϕ set output to trip circuits
2D7	23	ϕ C and Targets
2F9	24	ϕ A
2F9	25	ϕ B Any Trip bus seal in
2F9	26	ϕ C
2E10	27A	Trip Bus
2C6	27B	Any Trip Bus
2C5	28	Key channel 1PT
2D7	29	Key channel 3PT input
1B6	31	Any IM
2E10	32	Any ϕ open
2E10	33	Block 1 Pole RI
2E3	35	IT and not TL7
2C8	36	2 out of 3 3PT signal
1D6	37	Blocking signal
2E2	38	FDP (fault detector supervision)
2F2	39	Pos Seg units input to FDP
1E1	40	Seal in of OSB
1E9	41	NDD + PDT for LPU
1C10	42	LPU output
2F8	43	Receiver Supervision
2F8	44	phase selection
2E3	45	ND switching
2E5	46	
2D6	47	
2E6	48	

Table SD-1 (0286A2878 Sh.1) Logic Diagram Device Location Table

2C11	49	PT Fuse Failure output
1B9	56	Inhibit reclose input selection
2D11	58	Inhibit Reclose circuit
2D11	59	Output and seal in
2C2	60	Trip Bus Supervision FDP etc.
2C10	62	Lockout reclosing output
2E7	70	Any ϕ selector
2E3	80	TL2, TL7, RCVR input to ND switches
1E6	100	Input to ϕ selectors open Vop
1E4	102	Local trip input to component
2E2	200	overcurrent supervision input to ND circuit
1E4	201	out
1E5	202	ND & IDT input to Trip permission via OR2
1C5	203	DT input to target & trip permission via
1F8	204	NDD + IDT + ND input to 3PT circuit
2C7	207	
2C7	208	2 out of 3 3 pole trip circuit
2C8	209	
1D11	210	WI unblocking during open pole period
2F3	211	1PT control (TL26)
2D3	212	1PT control (TL26)
1C5	214	DT input to trip permission
2C3	215	1PT control delayed
2F4	216	received signal CC1 + CC2
1E4	217	received signal to repeat circuit
1E4	218	OR203 unblock & no ϕ received
B10	300	Trip permission



Table SD-1 (0286A2878 Sh.2) Logic Diagram Device Location Table, continued

Location	AND #	Function
1E3	1	IT and NT
1F6	2	NB input to OR100 (ϕ sel conted,
D2	3	Zone II input (TL2)
1D2	4	Zone III input (TL3)
1D2	5	Zone II output
1D2	6	Zone III output
1F9	7	ϕ A open
1F10	8	ϕ B open
1F10	9	ϕ C open
	10	WI circuit
1D4	11	Pos seq input to DT (OR203)
2F4	12	CC1 * CC2 Receivers
1D4	13	
1D4	14	WI input to TL16
1D3	15	Local trip keying output
1D3	16	RT output
1B3	17	PT & ST input to trip permission
2C5	18	3P maintained keying signal
1B3	19	Key 1P
	20	Key 3P
2B7	21	ϕ A T selections
2B7	22	ϕ B T selections
2B8	23	ϕ C T selections
2F8	24	ϕ A trip seal in
2F9	25	ϕ B trip seal in
2F9	26	ϕ C trip seal in
2C8	27	2 out of 3
2C8	28	3PT trip circuit
2B8	29	
2F9	30	ϕ A trip output
2F9	31	ϕ B trip output
2F9	32	ϕ C trip output
	33	
1B4	34	Repeat circuit output
2E10	35	3PT R1
2E10	36	1PT R1
1F8	38	3PT PDT * RCVR * IB
2B8	39	2 out of 3 3PT circuit
1E1	40	Out of step detected - input to TL6
1E10	41	All poles open input to TL7
1C9	42	LPU TL7 * 11T
1C10	43	CFA bypass of TL8 (LPU)
2E11	44	PT fuse failure
2E7	45	ϕ A undervoltage phase selection
2E7	46	ϕ B undervoltage phase selection
2E7	47	ϕ C undervoltage phase selection
1A3	48	3PT seal in of trip permission
2D11	49	PT fuse failure
2C10	55	3PT R1

Table SD-1 (0286A2878 Sh.3) Logic Diagram Device Location Table, continued

2C10	56	1PT R1
2F11	57	Inhibit reclosing circuit
2E11	58	Inhibit reclosing
1F7	59	NDD 3PT input
1C9	60	PDT, NDD input to LPU
2E6, 2E2	61	Positive Sequence into FDP circuit
2F1	62	POSB into FDP circuit
1E8	63	Lockout reclosing circuit
1D8	64	Lockout reclosing circuit
1F7	65	PDB input to BLK time
2D11	67	Lockout reclosing
2E8	68	ϕA and ϕB sel
2F8	69	ϕB and ϕC sel
2E8	70	ϕC and ϕA sel
1C11	71	1PT control block WI
2F5	72	
2F5	73	
2F6	74	
2E7	76	TL16 and Any phase select
2F7	77	ϕA select
2E7	78	ϕB select
2F8	79	ϕC select
2D8	80	TL7 and IT LPU reach switch of ND
2E8	81	3PT $\phi A, \phi B$
2E8	82	3RT $\phi B, \phi C$
2E8	83	3PT $\phi C, \phi A$
2D6	84	ϕA
2D6	85	ϕB
2D6	86	ϕC Trip targets
2B6	87	ϕA
2B6	88	ϕB
2B6	89	ϕC
2E3	98	ND Zone II switching
2F1	100	TL26 input to block FDP restraint circuits
2D1	101	FDP restraint SW (neg)
1E6	200	IB and NB input to transient blocking
2E3	201	NT and BLK Dir Supervision of IDT, ITOC
1F5	202	Overcurrent Supervision of ND
1F8	202A	
1E3	203	Overcurrent Supervision of NDD
1F8	203A	
1E5	204	RCVR Supervision of ND input to zone I tri
1C2	205	Zone II output to trip permission
1F8	206	DT and 1PT control to 3PT
2C1	207	FDP restraint SW (Pos)
1E8	208	Lockout reclosing circuit
1D9	209	Lockout reclosing circuit
1F5	210	PD1 and ND and IDT 3PT keying
1D10	211	ϕA sel and ϕA open
1D11	212	ϕB sel and ϕB open WI unblocking
1D11	213	ϕC sel and ϕC open
2E3	214	1PT control X open
2F4	215	1PT control ϕ selector input

Table SD-1 (0286A2878 Sh.4) Logic Diagram Device Location Table, continued

2D3	217	1PT control remove Io in IPT, remove ND sw
2D4	218	1PT control delayed output
2E6	221	Supervision of 3PT by RDT
1F10	222	All phase undervoltage
1D4	224	

Location	Timer #	Function
1C3	TL1	Comarar timer
1D2	TL2	Zone II
1D2	TL3	Zone III
1D10	TL4	Reset of TL7 LPU
1E1	TL6	OSB timer
1D10	TL7	3P line pickup
1C9	TL8	Line pickup IIT delay
1B4	TL9	Delay of Blocking in repeat
1B4	TL11	Repeat cutoff
2D4	TL13	DTT coordinating
2E7	TL15	Reset delay on any ϕ sel
1C4	TL16	WI
2C5	TL18	3P keying
2D11	TL21	PT FF
2D5	TL22	DTT reclose lockout
1E6	TL24	NB transient blocking
1E7	TL25	PDB transient blocking
2F10	TL26	Trip bus control timer
2D4	TL27	3PT open pole logic
1E6	TL30	delay in NB trans. block
2F4	TL200	OSB timer
	TL201	3P keying
2G5	TL220	delay on 3 ϕ target
2B8	TL39	3 Pole trip permission

Table SD-1 (0286A2878 Sh.5) Logic Diagram Device Location Table, continued

CALCULATION OF SETTINGS

This section addresses the use of the PLS system on a two-terminal transmission line (without series capacitors), and covers all of the required settings. The scheme is designed to be used with a single frequency shift (FSK) channel.

The designation for each setting as it appears on the respective module is indicated by underlining (e.g., ZR1). The module on which the setting is to be made is given in boldface (e.g. **AEM11-**).

The following settings must be made:

PD1 and ND - Zone 1 direct tripping functions

The system is provided with positive sequence (PD1) and negative sequence (ND) zone 1 direct tripping functions.

Settings

The following settings must be made:

<u>Z1</u>	DPM11-
<u>PD1 Bias</u>	DPM11-
<u>ND Bias</u>	DNM10-

Z1

The reach of the PD1 and ND functions is set via the Z1 setting. Set Z1 equal to 90 percent of the positive sequence line impedance.

$$Z1 = \frac{0.9(Z1L)(CT\ ratio)}{(PT\ ratio)} \quad (1)$$

Where:

Z1L = positive sequence line impedance in primary ohms

PD1 BIAS

Make the following setting:

$$PD1\ BIAS = 0$$

ND BIAS

Make the following setting:

$$ND\ BIAS = 0$$



Negative Sequence Distance Reach Multipliers, N2 and N3

The ND function described above is used to provide high speed direct tripping. Another negative sequence distance function, designated NDD is used to provide the permissive function in the pilot portion of the scheme, and the backup function in the time-delayed portion of the scheme. NDD is initially set with the same reach, Z1, as the ND function, and is stepped out in reach as follows:

1. The NDD reach is extended to N2(Z1) when timer TL2 times out, or when both NT and IT have operated and a permissive trip signal is received from the remote terminal of the transmission line. Second zone backup tripping and/or pilot tripping is thus provided via the N2 setting.
2. The NDD reach is extended to N3(Z1) when timer TL3 times out. Third zone backup tripping is thus provided via the N3 setting.

It is proposed that the zone 2 reach [N2(Z1)] be set equal to the PDT reach to optimize performance for internal faults. However, if the function must coordinate with similar functions in adjacent line sections, then conventional zone 2 reach settings can be used.

Set the zone 3 reach [N3(Z1)] to provide the required protection. If third zone protection is not required, set N3 = N2, and set timer TL3 greater than or equal to TL2.

Setting Example

The system shown in Figure CS-1 will be used.

$$\text{Pt ratio} = 4500, \quad \text{CT ratio} = 400$$

Reach Setting, Z1


From equation (1) above,

$$\begin{aligned} Z1 &= \frac{0.9(Z1L)(\text{CT ratio})}{(\text{PT ratio})} \\ &= \frac{0.9(60)400}{4500} \\ &= 4.8\Omega, \text{ use } 4.8\Omega \end{aligned}$$

PD1 and ND Bias

Set PD BIAS = 0

Set ND BIAS = 0



Transmission Line:

$XL2$ = negative sequence reactance

$XL0$ = zero sequence reactance

Shunt Capacitance:

$XC2$ = negative sequence reactance

$XC0$ = zero sequence reactance

Far End Reactor (relative to Sta. A)

$XRF2$ = negative sequence reactance

$XRF0$ = zero sequence reactance

Near End Reactor (relative to Sta. A)

$XRN2$ = negative sequence reactance

$XRN0$ = zero sequence reactance

Figure CS-1 Sample Power System

PDT - Positive Sequence Overreaching Distance Function

PDT is used as the overreaching function in the directional comparison portion of the scheme and is intended to operate for all three-phase faults and some double-line-to-ground (DLG) faults. PDT is also used in conjunction with the reclosing control circuits, and in the phase selection circuits.

The PDT function is provided with zero sequence current restraint to prevent it from operating for close-in single-line-to-ground (SLG) faults. The restraint input is related to the reach ($Z1$) of the PD1 function plus a fixed factor of $30/I_n$ ohms; i.e.,

$$I0Z_{rest} \approx (Z1 + 30/I_n)I0$$

The performance of the PDT function will be affected by this input. When longer than the proposed settings are used, the restraint becomes less effective and vice versa when shorter than proposed settings are used. Thus, when reach settings longer than the proposed settings are used, the function will operate for more DLG faults, but it will also be more prone to operation on close-in SLG faults. It is suggested that settings other than the proposed not be used on the PDT function when single-phase tripping is being utilized. If single-phase tripping is not being used, longer or shorter than the proposed settings may be used if desired. If reach settings shorter than proposed are used, PDT will operate for fewer DLG faults, plus it will also be slower in operation for these faults.




Figure CS-2 PDT Function

The PDT function can be set with a forward offset as shown in Figure CS-2 to the left, and the response of the function can be controlled via a time constant setting. Both of these features are used to minimize the effects of load flow.

Settings

The following settings must be made:

<u>ZT</u>	DPM10-
<u>OFFSET</u>	DPM10-
<u>PDT TC</u>	DPM10-

ZT - Forward Reach

The following setting is proposed:

$$ZT = \frac{Z1L(CT \text{ ratio})}{(PT \text{ ratio})} + \frac{30}{In} \quad (2)$$

Where:

$Z1L$ = uncompensated positive sequence impedance of transmission line

In = relay rated current (1A or 5A)

PDT forward offset (OFFSET) and PDT time constant (PDT TC)

The PDT forward offset and time constant settings are dependent on the reach of the PDT function and the maximum load current expected across the line. To determine these settings, first calculate the following:

$$PDTL = \frac{(ZT)(IL)}{67} \quad (3)$$

Where: ZT = the reach setting of the PDT function in secondary ohms

IL = maximum load current across the line in secondary amperes

The offset and time constant settings can then be determined from Table CS-1.

Table CS-1 Time Constant (TC) and Forward Offset (OFFSET) Settings

PDTL	Time Constant (TC)	Forward Offset (OFFSET)
0 - 1.1	SHORT	0
1.1 - 1.2	SHORT	0.1
1.2 - 1.35	SHORT	0.2
1.35 - 1.5	LONG	0.2
> 1.5	LONG	0.3



Setting Example

The system shown in Figure CS-2 will be used to demonstrate the settings for the PDT function at Station A. Assume that maximum load current is 5.4 secondary amperes.

$$Z_{1L} = 5.3 \text{ ohms}$$

From equation (2),

$$Z_T = Z_{1L} + 30/I_n = 5.3 + 6 = 11.3 \text{ ohms, use 11.3 ohms}$$

From equation (3),

$$PDTL = \frac{Z_T(I_L)}{67} = \frac{5.4(11.3)}{67} = 0.91$$

From Table CS-1,

$$PDT \text{ TC} = \text{SHORT}$$

$$\text{OFFSET} = 0$$

PDB - Positive Sequence Distance Blocking Function

PDB is a positive sequence distance function that is used to provide one of the blocking functions that is required in the directional comparison portion of the scheme. The function is also used in the weak-infeed and echo circuits, and in the transient blocking circuits.




Figure CS-3 PDB Function

The blocking function has the characteristic shape shown to in Figure CS-3. The offset is equal to the forward offset in the PDT function and the reach of the function is a multiple (PDB) of the forward reach (ZT) of the PDT function (see Figure CS-2).

The PDB function also has a time constant setting that is used to control the response of the function.

Settings

The following settings must be made:

PDB **DPM10-**
PDB TC **DPM10-**

PDB - Reach

The reach of the PDB function is equal to the reach of the PDT function (ZT) multiplied by the blocking function reach multiplier, PDB [PDB reach = ZT(PDB)]. Set the PDB reach multiplier to the larger of the following settings:

$$1. \text{ PDB} = \frac{ZT}{ZT} \quad (4)$$

$$2. \text{ PDB} = \frac{1.5(ZT' - Z1L)}{ZT} \quad (5)$$

Where:

ZT = reach of the PDT function at the local line terminal

ZT' = reach of the PDT function at the remote line terminal

Z1L = positive sequence impedance of transmission line in secondary ohms

PDB Time Constant (PDB TC)

Set the PDB time constant, PDB TC, equal to the time constant selected for the PDT function at the remote line terminal.

PDB Setting Example

The system of Figure CS-1 will be used to demonstrate the settings for the PDB functions at Station B. Assume that PDT at Station B is set with a forward reach (ZT) of 11,3 ohms.

$$ZT' \text{ at Station A} = 11.3$$

From equation (4),

$$PDB = \frac{11.3}{11.3} = 1.0$$

From equation (5),

$$PDB = \frac{1.5(11.3 - 5.3)}{11.3} = 0.8$$

Use a PDB reach multiplier of 1.0.

Use a PDB TC time constant setting of SHORT just as is used on PDT at the remote end of the line.

POSB - Positive Sequence Out-of-step Distance Function

POSB is a positive sequence distance function that works in conjunction with the PDT function to establish out-of-step blocking. The reach of POSB is equal to $POSB(ZT)$ where POSB is a reach multiplier and ZT is the reach set on the PDT function. The POSB function also has a time constant setting that is used to control the response of the function.

The following settings must be made:

$$\frac{POSB}{POSB \text{ TC}} \quad \begin{matrix} \text{DPM10-} \\ \text{DPM10-} \end{matrix}$$

POSB - reach multiplier

Use the following setting:

$$POSB = 1.1$$

POSB TC - time constant

Set the POSB TC time constant setting equal to the PDT TC setting selected for PDT at the same terminal of the line.

PDX - Positive Sequence Auxiliary Distance Function

PDX is a positive sequence distance function that is used to control timer TL2 to provide time-delayed backup protection, and it is also used in the reclosing circuits.






Figure CS-4 PDX Function

PDX has the characteristic shown in Figure CS-4. The reach of PDX is equal to $PDX(Z1)$ where PDX is a reach multiplier and Z1 is the reach of the PD1 and ND functions.

The following setting must be made:

PDX AEM10-

Select a reach [$PDX(Z1)$] to provide coordination with similar functions in adjacent line sections, or to meet reclosing control requirements as described in a later section of this book.

ZR1 - System Impedance Angle

The ZR1 setting sets the impedance angle for all of the distance functions.

The following setting must be made:

ZR1 AEM11-

ZR1 must be set equal to, or just below, the positive sequence impedance angle of the transmission line.

Setting Example

See Figure CS-1.

$$ZR1 = 85^\circ$$

NT and NB - Negative Sequence Directional Functions

Settings

The following settings must be made:

**KT ADM10-
VA2 AEM11-**

KT

The negative sequence directional tripping function (NT) uses an "offset" or compensating signal in the operating quantity to provide a dependable operating signal when the source impedance behind the function is considerably less than the line impedance. A KT setting of 0.05 is proposed for all applications.

VA2

The VA2 setting introduces a phase shift in the negative sequence voltage quantity (V2) used in the negative sequence directional functions. VA2 is calculated as follows:

$$VA2 = (85^\circ - ZSang)$$

Where:

$ZSang$ = the angle of the effective source impedance behind the relay.

If $ZSang$ is greater than or equal to 80° , set $VA2 = 0$.

Setting Example

The system shown in Figure CS-1 will be used in determining the settings for the negative sequence directional functions at both line ends.

Station A and Station B

$$KT = 0.05$$

$$VA2 = 0, \text{ since } ZSang > 80^\circ$$

IT, IB, I2 SHUNT and I0 SHUNT

The IT (tripping) and IB (blocking) functions are used in the directional comparison scheme along with the negative sequence directional functions to provide sensitive tripping for ground faults. The following operating signals are used:

$$IT \text{ operate signal} = (2|I_0| + |I_2| - 0.3|I_1|)$$

$$IB \text{ operate signal} = (2|I_0| + |I_2| - 0.2|I_1|)$$

IT and IB must coordinate with each other. This coordination is achieved via the settings placed on the functions, with the requirement that IB at one terminal of the line be more sensitive than IT at the other terminal. For example, IB at Station B in Figure CS-1 must be more sensitive than IT at station A.

Note that the negative and zero sequence currents entering the line will be greater than the respective currents leaving because of the charging current. This must be taken into account. In Figure CS-1 for example, the negative and zero sequence currents at Station A (Inear) will be greater than the respective current at Station B (Ifar). How much the current will differ will be affected by any shunt compensation used on the line (such as the far end and near end reactors shown in the figure). It is possible to compensate for the effect of the charging current by simply setting IT greater than IB by the amount of the charging current. However, this would entail a fixed difference in setting which would fix the sensitivity of IT. To overcome this limitation, the IT function is provided with an adaptive restraint via the I2 SHUNT and the I0 SHUNT inputs.

For example, for a phase-to-phase fault at F in Figure CS-1, the negative sequence voltage will be relatively large, which in turn will produce a large restraining quantity which is desirable in this instance to assure positive coordination. On the other hand, consider a high resistance fault at F1. For this condition, the negative and zero sequence voltages will be quite low, thus the restraining effect of I2 SHUNT and I0 SHUNT on the IT function at Station A will be minimized thus allowing greater sensitivity for resistive faults.

Settings

The following settings must be made (see Figure CS-1 for definition of parameters):

IB BIAS ADM10-
IT BIAS ADM10-
I2 SHUNT ADM10-
I0 SHUNT ADM10-

IB Setting (IB Bias)

Set the IB function to its minimum setting of 0.05 per unit.

IT Setting (IT Bias)

$$IT\ Bias = [IB + 0.025 + 0.1(I1SH)]K1 \quad (6)$$

Where:

$$K1 = [1 + \frac{0.75(XL2)}{XC2} + \frac{1.5(XL0)}{XC0} - \frac{XL2}{XRF2} - \frac{2(XL0)}{XRF0}] \quad (7)$$

$$I1SH = \frac{67}{XC1(I_n)} \quad (8)$$

IB = IB Bias setting at remote end of line

NOTE: If there are no far end reactors ($XRF2$ and $XRF0 =$ infinity) the last two terms in (16) go to zero

IT Bias SHOULD NEVER BE SET LESS THAN 0.1

I2 SHUNT setting (I2 SHUNT)

$$I2\ SHUNT = \frac{(XRN2 - X2)67}{XRN2(X2)I_n} \quad (9)$$

NOTE: If there are no near end reactors ($XRN2 =$ infinity), thus,

$$I2\ SHUNT = \frac{67}{X2(I_n)} \quad (10)$$

Where:

$$X2 = \frac{XC2[0.25(XL2) + XRF2]}{XRF2 + 0.25(XL2) - XC2} - 0.75(XL2) \quad (11)$$

NOTE: If there are no far end reactors ($XRF2 = \text{infinity}$), thus,

$$X2 = XC2 - 0.75(XL2) \quad (12)$$

I0 SHUNT setting (I0 SHUNT)

$$I0 \text{ SHUNT} = \frac{(XRN0 - X0)134}{XRN0(X0)In} \quad (13)$$

NOTE: If there are no near end reactors ($XRN0 = \text{infinity}$), thus,

$$I0 \text{ SHUNT} = \frac{134}{X0(In)} \quad (14)$$

Where:

$$X0 = \frac{XC0[0.25(XL0) + XRF0]}{XRF0 + 0.25(XL0) - XC0} - 0.75(XL0) \quad (15)$$

NOTE: If there are no far end reactors ($XRF0 = \text{infinity}$), thus,

$$X0 = XC0 - 0.75(XL0) \quad (16)$$

Setting Example

The IT BIAS, IB BIAS, I2 SHUNT and I0 SHUNT settings described below pertain to the IT function at Station A and the IB function at Station B. Except where noted otherwise, all of the factors used in the equations are described in Figure CS-1. All reactance values must be expressed in secondary quantities. The settings will all be determined in per unit where the base current, In (1.0 or 5.0 amperes), is the relay rated current. The following values (in secondary terms) apply.

Transmission Line	Near End Reactor (none)	Far End Reactor
XL2 = 5.3	XRN2 = ∞	XRF2 = 204
XL0 = 16.4	XRN0 = ∞	XRF0 = 204
XC1 = XC2 = 104		
XC0 = 156		

IT Bias

From equation (8),

$$I1SH = \frac{67}{104(5)} = 0.129$$

From equation (7),

$$K1 = [1 + \frac{0.75(5.3)}{104} + \frac{1.5(16.4)}{156} - \frac{5.3}{204} - \frac{2(16.4)}{204}] = 1.0$$

From equation (6),

$$IT \text{ BIAS} = [0.05 + 0.025 + 0.1(0.129)]1.0 = 0.09$$

Since this is less than 0.1, use the minimum recommended setting of 0.1.

I2 SHUNT

Since there are no near end reactors, use equation (10) above after first calculating X2 using equation (11).

$$X2 = \frac{104[0.25(5.3) + 204]}{204 + 0.25(5.3) - 104} - 0.75(5.3) = 207$$

$$I2 \text{ SHUNT} = \frac{67}{207(5)} = 0.065$$

Use a setting of 0.07

I0 SHUNT

Since there are no near end reactors, use equation (14) above after first calculating X0 using equation (15).

$$X0 = \frac{156[0.25(16.4) + 204]}{204 + 0.25(16.4) - 156} - 0.75(16.4) = 611$$

$$I0 \text{ SHUNT} = \frac{134}{5(611)} = 0.044$$

Use a setting of 0.05

IDT - Overcurrent Direct Tripping Function

The IDT direct tripping overcurrent function uses zero sequence current and may be applied with or without positive sequence current restraint. The IDT operating quantity is:

$$IDT(\text{operate}) = (3|I0| - K1|I1|) \quad (17)$$

Where:

$$K1 = 1 \text{ or } 0$$

Positive sequence current restraint is recommended ($K1 = 1$) because it makes the function less sensitive to external faults, while providing excellent sensitivity for close-in internal faults.

For example, with $K1 = 1$, consider the following three cases for the system shown in Figure CS-1.

Case 1, SLG fault at F1, all breakers closed

$$I1 = 1204A \quad I0 = 540A$$

$$IDT(\text{operate}) = [3(540) - 1204] = \underline{416A}$$

Case 2, SLG fault at F4, breaker B open

$$I1 = 860A \quad I0 = 860A$$

$$IDT(\text{operate}) = [3(860) - 860] = \underline{1720A}$$

Case 3, SLG fault at F3, all breakers closed

$$I1 = 6022A \quad I0 = 6687A$$

$$IDT(\text{operate}) = [3(6022) - 6687] = \underline{11379A}$$

NOTE: If $K1$ is set to zero, the operating quantity is simply equal to three times (3x) the zero sequence current given above. This must be remembered in determining an appropriate IDT setting if positive sequence current restraint is not used.

Assume for this example that $K1 = 1$ and that the IDT function is set to pick up at 0.5 per unit amperes. For a 5 ampere rated relay, and for the CT ratio shown in Figure CS-1, this transposes to a pickup of 1000 primary amperes. The following can be noted:

1. The function will not operate for Case 1.
2. The function will operate for Case 2, but only after breaker B opens. This will be a sequential trip because operation of IDT follows the opening of breaker B.
3. The function will operate for Case 3. It will be very fast because the operating quantity is 15 times the pickup setting.

The IDT function can be directionally controlled by the negative sequence directional functions if desired. Directional control is best used in those applications where the maximum operating quantity that is developed for external faults directly behind the function is greater than the maximum operating quantity developed for external faults at the remote terminal. If the maximum operating quantities are approximately equal for external faults at each end of the line then directional control is not necessary, and its use may be detrimental. For example, consider a fault that occurs at F5 in Figure CS-1 and then evolves into an internal SLG fault at F3 that is sufficient to operate IDT. If directional control is used, then tripping at F3 cannot occur until the transient blocking time (established by reset time of blocking function) has elapsed. On the other hand, tripping will occur immediately if directional control is not used.

When using directional control, it is only necessary to evaluate the effects of faults just beyond the remote terminal in determining an appropriate setting. If directional control is not used, then it will be necessary to evaluate the effects of faults directly behind the function as well as at the remote terminal.

Another input is also applied to the energy comparator in addition to the operate signal described above. This signal which uses zero sequence current is effective for close-in heavy faults, and is used to speed up operation of IDT. This input is further described in the setting example provided below.

Settings

The following settings must be made:

<u>IDT K1</u>	DPM11-
<u>K0</u>	DPM11-
<u>DT PU</u>	DPM11-
<u>IDT DIR</u>	DPM11-

Setting Example

The system shown in Figure CS-1 will be used in this example.

IDT K1 - This setting ($K1 = 0$ or 1) establishes the amount of positive sequence current restraint that is used. Use the recommended setting of 1 .

KO - This setting establishes the magnitude of the additional operate signal ($K0 \cdot I0 \cdot ZR1$) that is applied to the energy comparator to help speed up operation of IDT. KO is calculated as follows:

$$KO = \frac{(Z0L - Xc)K}{|Z1L|} \quad (18)$$

Where:

$Z0L$ = | zero sequence impedance of the protected line|

$Z1L$ = | positive sequence impedance of the protected line|

Xc = | total capacitive reactance of any series capacitors in the line|

K = 1 , if there is no mutual coupling with parallel lines, otherwise,

$$K = 1 - \frac{Zm^2}{(Z0L - Xc)Zop} \quad (19)$$

Where:

Zm = | zero sequence mutual impedance between protected line and parallel line|

Zop = | zero sequence impedance of parallel line|

NOTE: Use impedance magnitudes only in making the calculations, do not use phasor quantities.

For the system shown in Figure CS-1, and using equation (18):

$$K0 = \frac{185}{60} = 3.08$$

Use a setting of 2.1 .

DT PU - The DT PU setting is established by determining the maximum positive value of:

$$IDT(operate) = (3 | I0 | - K1 | I1 |) \quad (20)$$

If IDT is to be directionally controlled then the operate signal need only be evaluated for faults at F1. If IDT is not to be directionally controlled, then it will be necessary to evaluate the quantity for faults at F2 also. The IDT pickup setting (DT PU) is then equal to the maximum operate signal so determined plus a margin of 25% of the $(3|I_0|)$ used in determining the maximum value of the operate signal.

$$DT\ PU = (3|I_0| - K1|I_1|) + 0.25(3|I_0|) \quad (21)$$

TABLE CS-2 Fault Study of Figure CS-1

Case	Fault	Line C-D	I1	3(I0)	Iop	Iop+0.25(3I0)
1	F2	In	1204	1620	416	821
2	F1	In	979	1461	482	847
3	F2	Out	1417	1617	200	604
4	F1	Out	1234	1566	332	723

CS

Table CS-2 lists the results of a fault study for faults at locations F1 and F2 as shown in Figure CS-1.

From this table it can be seen that there is not a significant difference between the maximum Iop for a fault at F1 (482) versus the maximum Iop for a fault at F2 (416). On this basis, the function can be operated without directional control. It should be set to pickup at 847 primary amperes.

$$DT\ PU = \frac{847}{CT(In)} = \frac{847}{400(5)} = 0.42\ p.u.$$

Use a setting of 0.5 p.u.

Set the IDT DIR control jumper to the NON-DIR position.

I1T - Positive Sequence Overcurrent Line Pickup function

The I1T function operates from positive sequence current and is provided for use in the line pickup (close-into-fault) circuit.

I1T should be set to pick up at no greater than 2/3 of the minimum fault current for an internal three-phase fault on the line at a point equal to the forward offset setting [e.g. $Z_{fault} = OFFSET(ZT)$].

If the minimum fault current is greater than the maximum load current across the line, the I1 setting can be reduced to provide greater coverage of the line. For this case, a setting of 110% of the maximum load current is proposed. If the I1T function can be set with a pickup of at least 110% of the maximum load current contact converter CC6 can be energized continuously to bypass coordinating timer TL8 to obtain faster tripping.

If sequential reclosing is used, or if there is no automatic reclosing, then I1T can be set below load current, and CC6 can be energized continuously to bypass timer TL8. If high-speed simultaneous reclosing is used and I1T is set below full-load current, then TL8 should be continuously energized, otherwise tripping might be initiated when picking up a loaded line.

If a power transformer is energized when the line is reclosed, CC6 should not be continuously energized to bypass TL8 if I1T can pick up on the transformer inrush current. A conservative approach to determine if I1T will pick up on the transformer inrush is to calculate the steady-state positive sequence current for a three-phase through fault just on the other side of the transformer; i.e., at the transformer bushings. If I1 will pick up for this fault, then TL8 should not be bypassed.

The following setting must be made:

I1 AEM1--

Setting example

The system shown in Figure CS-1 will be used in determining the setting for I1T at Station A.

For this line, $ZT = 11.3$ ohms, per equation (2), and $OFFSET = 0$.

The minimum three-phase fault current in per-unit for a fault at a point equal to the offset setting of 0 secondary ohms is:

$$I_{min} = \frac{303100}{400(20)5} = 7.6 \text{ per-unit amperes}$$

The maximum load current across the line is 4.8 amperes. In per-unit, this is:

$$\frac{I_{load}}{5} = \frac{5.4}{5} = 1.03 \text{ per-unit amperes}$$

Since the minimum fault current is greater than the maximum load current, a setting based on 110 percent of the maximum load is proposed.

$$I1 = 1.1(1.03) = 1.19, \text{ use a setting of } 1.2 \text{ per-unit}$$

ITOC - Time Overcurrent Function

The ITOC very inverse time overcurrent function uses zero sequence current and may be applied with or without positive sequence current restraint. The function is used to provide time-delayed backup tripping for faults involving ground. It uses the following operating quantity:

$$ITOC(operate) = 3 |I0| - K1 |I1| \quad (22)$$

Where: $K1 = 0$ or 0.45

Positive sequence current restraint is used to make the function less sensitive to external ground faults. In selecting the settings for ITOC, consideration should be given to:

- a. Coordination with other ITOC functions in adjacent lines
- b. Coordination with conventional ground TOC functions on adjacent lines
- c. Coordination with the zero sequence current produced as a result of an open pole in an adjacent line section

If coordination with conventional ground TOC functions is required, then the suggested approach is to calculate the pickup and time dial settings assuming no positive sequence restraint, but to then use positive sequence restraint in the application. The use of this restraint will provide an additional coordinating margin for ITOC and increase security by preventing undesired operation due to zero sequence error current resulting from load flow over untransposed lines, unsymmetrical gap flashing across series capacitors.

The ITOC function can be directionally controlled by the negative sequence directional functions if so desired. Directional control should be considered if it becomes difficult to coordinate the ITOC function with similar functions in adjacent line sections.

The following settings must be made:

TOC PU DPM11-
TOC K1 DPM11-
TD DPM11-
TOC DIR DPM11-

TOC PU

TOC PU determines the pick up setting and is set in per-unit on the relay rated ampere base ($I_n = 1A$ or $5A$):

$$\text{TOC PU} = \frac{\text{ITOC(operate)}}{I_n} \quad (23)$$

Use equation (22) to calculate the minimum ITOC(operate) for which the ITOC function must operate.

TOC K1

TOC K1 is used to remove ($\text{TOC K1} = 0$) positive sequence restraint, or to apply ($\text{TOC K1} = 0.45$) positive sequence restrain. Select the appropriate setting to meet the application.

TOC DIR

TOC DIR selects whether or not the function will be directionally controlled by the negative sequence directional functions. Select the appropriate setting to meet the application.

TD

TD sets the time-dial setting for the ITOC function. Select an appropriate setting to meet the application.

IMA, IMB, IMC - Phase Current Functions

The IM functions are used in the open-pole detector circuits and in the breaker failure (BFI) seal-in circuits.

The following setting must be made:

IM AEM10-

Use the following setting:

$$I_M = 1.5(I_{1c}) \quad (24)$$

Where:

I_{1c} = the net positive sequence charging current, taking into account any shunt reactors that are in service with the remote end of the line open

3I0 - Zero Sequence Current Function

3I0 is used to provide supervision to the negative sequence distance functions to prevent them from initiating a three-pole trip during single-line-to-ground faults. The setting is made in per unit of the relay rated current, $I_n = 1A$ or $5A$.

The following setting must be made:

3I0 AEM10-

Use the following setting:

$$3I0 = \frac{I_{0x}}{I_n}$$

Where, I_{0x} equals the lower of:

1. 30 percent of the maximum load current, or
2. two-thirds (2/3) of the 3I0 current for a single-line-to-ground fault at the remote end of the transmission line.

OSB1, OSB2 - Out-of-Step Blocking

Out-of-step blocking (OSB) is provided in the PLS system. Two switches are provided to route the OSB output to do the following in the logic:

OSB1

Set this switch to the in position to block zone 1 and pilot tripping, zone 2 and zone 3 time-delayed tripping, and to block all transmitter keying.

OSB2

Set this switch to the IN position to block all tripping, including those functions blocked by OSB1. Consideration should be given to setting the OSB2 switch to the IN position in those applications where the breaker is incapable of interrupting during an out-of-step condition.

Logic Timers

The following timers must be set:

<u>ZONE 2</u>	ULM19-
<u>ZONE 3</u>	ULM19-
<u>WEAK INFEED</u>	ULM19-
<u>TL1</u>	ULM19-
<u>TL9</u>	ULM19-
<u>TL24</u>	ULM19-
<u>TL25</u>	ULM19-
<u>TL26</u>	ULM17-

CS

ZONE 2

The ZONE 2 setting applies to timer TL2 in the logic and that is used with the PDX function to provide time-delayed backup tripping if desired. The timer may be switched out altogether if required. Select an appropriate setting for the application.

ZONE 3

The ZONE 3 setting applies to timer TL3 in the logic that is used with the PDT function to provide time-delayed backup tripping if desired. The timer may be switched out altogether if required. Select an appropriate setting for the application.

WEAK INFEED

The WEAK INFEED setting applies to timer TL16 in the logic that is used to provide security against spurious receiver outputs causing false trips through the weak infeed logic. Use a WEAK INFEED setting of 5 milliseconds unless it is determined that spurious outputs could last longer in which case the timer setting should be increased accordingly.

TL1

The TL1 setting applies to timer TL1 in the logic that is used to provide security against spurious receiver outputs during external fault conditions. A minimum setting of 3 milliseconds is proposed if a GE Type 71 channel is used. Longer settings will be required if it is determined that the spurious outputs will last longer than 3 milliseconds.

TL9

The TL9 setting applies to timer TL9 in the logic that is used to supervise the channel repeat circuit. Use a TL9 setting of channel time minus 4 milliseconds.

TL24

The TL24 setting applies to timer TL24 in the logic that is used to establish the dropout time of the NB negative sequence blocking function. Use a TL24 setting of 50 milliseconds.

TL25

The TL25 setting applies to timer TL25 in the logic that is used to establish the dropout time of the PDB positive sequence blocking function. A minimum setting of 50 milliseconds is proposed.

TL26

The TL26 setting applies to timer TL26 in the logic that is associated with phase selector operation. Use a TL26 setting of the nominal breaker opening time minus a half-cycle (e.g., 25 milliseconds for a 2-cycle breaker on a 60 Hz system).

TL13, TL22- Transfer Trip Timers

The following settings must be made:

<u>TL13</u>	ULM15-
<u>TL22</u>	ULM15-

Settings for these timers are required only if the output from the direct transferred trip receivers are routed to contact converter CC3 in the logic. If the PLS system is not used with these receivers, then these two timer settings have no effect and may be left set at any value.

When transferred tripping is used, use a TL13 setting that is greater than the maximum spurious output expected from the transferred trip receivers.

Use a TL22 setting that will discriminate between a trip signal produced by a line fault as opposed to a transferred trip signal that is produced because of equipment fault (transformer, etc.) or a breaker failure. This discrimination is based on the duration of the transferred trip signal. Trip signals produced for a line fault will be relatively short and will be less than the TL22 setting thus preventing it from timing out. On the other hand, for equipment faults, or breaker failure, the transferred trip signal will be prolonged and will be greater than the TL22 setting. When timer TL22 times out it will energize the lockout reclosing relay (LR) in the PLS system, the output of which can be used to prevent reclosing.

Reclosing Control

The PLS system is provided with two outputs that can be used in the external reclosing control circuits.

1. Lockout Reclosing

The lockout reclosing (LR) output is always activated by any one of the following:

- a. Direct Transferred Trip (timer TL22 output)
- b. TL2 (zone 2 timer) output
- c. TL3 (zone 3 timer) output
- d. ITOC (time-delayed trip) output
- e. CC8 (external trip input to logic) output
- f. OSB AND any Trip Bus (trip during out-of-step)

The LR output, as its name implies, is used to lockout or block all reclosing because the inputs that are used to activate it generally indicate that a fault of a permanent nature has occurred. Reclosing can be blocked externally via the lockout reclosing contacts, or the reclose initiate (RI) functions provided in the PLS can be blocked internally via a switch (BLOCK RI) provided in the logic.

2. Inhibit Reclosing

The inhibit reclosing (IR) output may be activated by any one of the following:

- a. PD1 output (zone 1 positive sequence direct trip)
- b. ND output (zone 1 negative sequence direct trip)
- c. PDX output (positive sequence direct trip)
- d. PDT output (positive sequence direct trip)
- e. OR36 output (two-out-of-three trip logic output)
- f. Direct Transferred Trip (timer TL13 output)

The IR output, as its name implies, is only meant to inhibit reclosing, and is intended to be used in reclosing schemes where sequential reclosing is permitted.

Inputs "a" through "e" can be enabled/disabled through individual switches provided in the logic. Input "f" is present all of the time that a direct transferred trip signal is received.

Sequential Reclosing

In a sequential reclosing scheme, one end of the line is allowed to reclose first, and if that reclosure is successful then the other end of the line is allowed to follow. Hence, the name sequential reclosing. A prime reason for using sequential reclosing is to allow the end of the line at which the fault appears to be least severe to the system to close first so as to minimize the shock to the power system, if the reclosure proves unsuccessful.

The PLS system is well-suited to this type of application because the fault detectors used to activate the inhibit reclose circuit provide an indication of fault severity. For example, a positive sequence distance function will operate for all three-phase faults within its reach; and, depending on source impedance and reach setting, will also operate for some close-in, severe unbalanced faults¹. The functions in the PLS system exhibit this type of performance but have the following features included:

- PDT** The PDT function, as described earlier, is provided with a zero sequence current restraint input that is used to prevent it from operating for close-in phase-to-ground faults. Thus, if the PDT input is used in the inhibit reclose circuit, it will inhibit reclosing for all three-phase faults on the line, and for some phase-to-phase and some phase-to-phase-to-ground faults. It will not inhibit for close-in SLG faults.
- PDX** The PDX function has a zero sequence current input that aids operation, rather than restrains it as in PDT, thus this function is more likely to operate for close-in severe SLG faults. It may be desirable to use this feature to inhibit reclosing at the ends of transmission lines located near a generating station, where, from a stability point of view, a close-in SLG fault may be as severe as any other type of fault further out on the line.
- PD1** The PD1 function is set to reach short of the end of the transmission line when used as a pure distance function, or it is set to operate at certain level of operate signal when used in the combination overcurrent distance mode. Thus, this function will be limited in the number of three-phase faults that it sees on the line, and even more limited in the number of unbalanced faults that it sees. It will be an indication of a rather severe fault when it operates because of the limited setting that is used.



The ND input, and two-out-of-three logic input, can be used to energize the IR circuit to inhibit on the occurrence of even more unbalanced faults than can be detected by the positive sequence distance functions alone.

The 5 inputs (a through f) just described are sealed in by an output from any one of the undervoltage functions so that IR will stay energized as long as the undervoltage condition persists. For example, consider a phase-to-ground fault at F4 in Figure CS-5. Assume that the PDX functions at both ends of the line are set to inhibit reclosing, and further assume that only the PDX at line-end B operates. For this condition, line-end A will reclose in high speed. Line-end B cannot reclose until end A has reclosed successfully to allow the voltage to return to normal at end B to release the inhibit reclose output. When voltage returns to normal, indicating a successful reclosure, end B will be allowed to successfully reclose. Note that if there is no indication of fault severity at either end of the line, then each end will be allowed to reclose in high speed. On the other hand, if each end indicates that a severe fault has occurred, then sufficient time-delay should be added before reclosing is attempted, or reclosing should be blocked altogether.

The direct transferred trip (DTT) input to the IR circuit is not sealed in via an undervoltage output. This input comes from timer TL13 (security timer) in the logic and will last only as long as a transferred trip signal is received from the other end of the line. Thus, if the DTT input is initiated by the normal relaying at the other end of the line, the DTT signal will reset shortly after the fault is cleared at the other end. At that time, the IR circuit will be released unless a severe fault has been indicated as described above. If the DTT signal is initiated as a result of an equipment fault or breaker, the DTT signal will be received for a long time, or continually, and timer TL22 will time out to energize the lockout reclosing circuit to lockout reclosing.

Settings

The following settings must be made:

<u>BLOCK RI</u>	ULM17-
<u>INH REC-1, PDT</u>	ULM18-
<u>INH REC-2, PDX</u>	ULM18-
<u>INH REC-3, PD1</u>	ULM18-
<u>INH REC-4, ND</u>	ULM18-
<u>INH REC-4, 2/3</u>	ULM18-

Contact Converters

The following contact converters (CC-) are included in the system:

- CC1 This contact converter is used for the permissive receiver input. See Figure CS-5 for external connections.
- CC2 This contact converter is not used.
- CC3 This contact converter is used for the direct transferred trip (DTT) channel input when tripping through the logic for a DTT is desired. If DTT tripping is not used, leave this CC unenergized.
- CC5 This contact converter is used to arm the three-pole trip circuits when it is desired to initiate a three-pole trip regardless of fault type. It must be energized continuously when the scheme is applied for three-pole tripping only.

- CC7 This contact converter is used to initiate a three-pole trip through the logic, but RI will not be blocked and the lockout reclose relay will not be energized. Use this CC if it is desired to trip through the logic and allow reclosing.
- CC8 This contact converter is used to initiate a three-pole trip through the logic. The lockout reclose (LR) relay will be energized to block reclosing, and the reclose initiate (RI) relay will be blocked if the BLOCK RI switch is in the IN position. Use this CC if it is desired to trip through the PLS logic and block reclosing.
- CC9 This contact converter is used to block all of the trip, BFI, RI and keying outputs. The green in service, "IN SERV" LED on the ULM17- module will also go out when CC9 is energized.
- CC10 This contact converter is used to reset the red sealed in target lamps.
- CC11 This contact converter is not used.
- CC12 CC12 must be energized at both ends of the line in those applications where the $ZS0/ZS1$ ratio of the source impedance at either end of the transmission line is less than 0.75. This might occur, for example, on a line terminated at a large generating station. The output from CC12 does the following:
1. It permits any phase selector output to block three-pole trip selection by the PDT function.
 2. It permits any phase selector output to block undervoltage phase selection during weak infeed conditions.
- CC13 Leave this contact converter de-energized.

Channel Keying Outputs


The following outputs are provided. See Figure CS-5 for external connections.

Key Xmtr 1 (K1)


Two normally open contacts are provided for keying of the permissive transmitter.

Key Xmtr 2 (K2)

Two normally open contacts are provided for keying of the number 2 transmitter (for use in certain schemes). These contacts are not used in this scheme.



Connections When Two Communication Channels are Used



Connections When one Communication Channel is Used

Figure CS-5 Connections for Communication Channels

TABLE CS-3 PLS1B SETTINGS

Station: _____ Line: _____

<u>Module</u>	<u>Adjustment</u>	<u>Purpose</u>	<u>Location</u>	<u>Setting</u>
ADM101	IB BIAS	IB pickup	on board	_____
ADM101	IT BIAS	IT pickup	on board	_____
ADM101	I0 SHUNT	IT adaptive restraint	on board	_____
ADM101	KT	NT/NB compensation	on board	_____
ADM101	I2 SHUNT	IT adaptive restraint	on board	_____
AEM10-	IM	IMA,IMB,IMC pickup	on board	_____
AEM10-	3I0	3I0 pickup	on board	_____
AEM10-	PDX	PDX reach multiplier	on board	_____
AEM111	I1	I1T pickup	on board	_____
AEM111	VA2	NT/NB phase shift	on board	_____
AEM111	ZR1	Replica impedance angle	on board	_____
DNM10-	ND BIAS*	ND restraint bias	on board	_____
DNM10-	N2	ND/NDD Z2 reach multiplier	on board	_____
DNM10-	N3	ND/NDD Z3 reach multiplier	on board	_____
DPM10-	ZT	PDT reach	front pnl	_____
DPM10-	OFFSET	Forward offset	on board	_____
DPM10-	PDB	PDB reach multiplier	on board	_____
DPM10-	POSB	POSB reach multiplier	on board	_____
DPM10-	PDB TC	PDB time constant	on board	_____
DPM10-	PDT TC	PDT time constant	on board	_____
DPM10-	POSB TC	POSB time constant	on board	_____
DPM11-	Z1	PD1 reach	front pnl	_____
DPM11-	DT PU	IDT pickup	on board	_____
DPM11-	K0	IDT I0 compensation	on board	_____
DPM11-	PD1 BIAS*	PD1 restraint bias	on board	_____
DPM11-	TD	ITOC time dial	on board	_____
DPM11-	TOC PU	ITOC pickup	on board	_____
DPM11-	IDT DIR	IDT directional control	on board	_____
DPM11-	IDT K1	IDT I1 restraint factor	on board	_____
DPM11-	TOC DIR	ITOC directional control	on board	_____
DPM11-	TOC K1	ITOC I1 restraint factor	on board	_____
ULM15-	TL13	Direct transfer trip timer	on board	_____
ULM15-	TL22	DTT reclose lockout timer	on board	_____
ULM171	TL26	Coordination timer	on board	_____
ULM171	BLOCK RI	RI control	on board	_____
ULM181	INH REC	-1 PDT selection	on board	_____
ULM181	INH REC	-2 PDX selection	on board	_____
ULM181	INH REC	-3 PD1 selection	on board	_____
ULM181	INH REC	-4 ND selection	on board	_____
ULM181	INH REC	-5 3PT selection	on board	_____
ULM19-	ZONE 2	Zone 2 timer	front pnl	_____
ULM19-	ZONE 3	Zone 3 timer	front pnl	_____
ULM19-	WEAK INFEED	Weak infeed delay timer	front pnl	_____
ULM19-	TL1	Integrator timer	on board	_____
ULM19-	TL9	TL9 pickup time	on board	_____
ULM19-	TL24	NB dropout time	on board	_____
ULM19-	TL25	MB dropout time	on board	_____
ULM19-	OSB-1	OSB block selection	on board	_____
ULM19-	OSB-2	OSB block selection	on board	_____

*Not used in Short Reach Schemes




Figure CS-6 (GES-9879) Time Overcurrent Curve

HARDWARE DESCRIPTION

CASE ASSEMBLY

Construction

The case that houses the electronic modules is constructed from an aluminum alloy. It consists of a main frame with side mounting brackets, a front cover and a rear cover.

The front cover, comprised of a metal frame with plate glass, is pivoted on the top and is opened from the bottom by way of two spring-loaded latches. The door is constrained from coming off by tabs that require the door to be unlatched and lifted slightly in order to be removed.

The rear cover supports terminal blocks that are used in making external connections to the case.

The modules are mounted vertically inside the case and they are supported by sockets within the case. In addition to this mechanical support, the sockets also offer the means of making the electrical connection to the modules. The modules are further restrained inside the case by the front cover.

Proper alignment of the module with respect to the socket is maintained by slotted guides, one guide above and one guide beneath each module, with the exception of the magnetics module, MGM, which requires two guides above and two beneath.

Electrical Connections and Internal Wiring

External connections are made to each case through twelve terminal blocks mounted on the rear cover plate. Each block contains 14 terminal points, which consist of a Number 6 screw threaded into a flat contact plate.

Connection to the printed circuit board modules is made by means of 60-pin edge connectors. Connection to the MGM module is made by means of two connector sockets; an 8-contact current block and a 104-pin signal block. The current block contacts are rated to handle current transformer (CT) secondary currents, and they are shorted upon removal of the MGM module.

Identification

The PLS system model number label is located on the inside of the front cover.

A marking strip indicating the name and position of every module in a case is included on the lower bar. It is placed to be read when the front cover is removed. Figure MO-1 shows the location of the modules.

The terminal blocks located on the rear of the modular case are uniquely identified by a two letter code that is found directly beneath the outer-most edge of each terminal block. Also, the terminal points (1 through 14) are identified by stamped numbers.

PRINTED CIRCUIT BOARD MODULES

Basic Construction

Each module consists of a printed circuit board and front panel. Two knobs are provided on the front panel for removing and inserting the module. Electrical connection is made by the contact pads at the back edge of the board. Not all module locations within the case have a printed circuit board. Some locations have a blank board and front panel.

Identification

Each module has its own identification number consisting of a three letter code followed by a three digit number. These are found at the bottom of each front panel and may be read when the case cover is removed.

RECEIVING, HANDLING AND STORAGE**CAUTION**

This relay contains electronic components which could be damaged by electrostatic discharge currents if those currents flow through certain terminals of the components. The main source of electrostatic discharge currents is the human body, and the conditions of low humidity, carpeted floors and isolating shoes are conducive to the generation of electrostatic discharge currents. Where these conditions exist, care should be exercised when removing and handling the modules to make settings on the internal switches. The persons handling the module should make sure that their body charge has been discharged by touching some surface at ground potential before touching any of the components on the modules.

Immediately upon receipt, the equipment should be unpacked and examined for any damage sustained in transit. If damage resulting from rough handling is evident, file a damage claim at once with the transportation company and promptly notify the nearest General Electric Sales Office.

If the equipment is not to be installed immediately, it should be stored indoors in a location that is dry and protected from dust, metallic chips, and severe atmospheric conditions.

INSTALLATION**Environment**

The location should be clean and dry, free from dust and excessive vibration, and well lighted to facilitate inspection and testing.

Mounting

The PLS case has been designed for standard rack mounting. The case measures eight rack units in height. Refer to Figure HD-3 for the outline and mounting dimensions.

External Connections

External connections are made according to the elementary diagram, Figure SD-4. This is a general diagram incorporating all of the available options. Connection need not be made to those terminals associated with options that will not be used. External and temporary jumper connections for acceptance and periodic testing are located at the end of the Acceptance Test section. When Test Point pins 55 and 60 are jumpered with an external jumper, the FD LED will illuminate, and the Red Continuous Monitor LED will flash throughout testing of the relay.

SURGE GROUND CONNECTIONS

WARNING

PLS TERMINALS BH13 AND BH14 MUST BE TIED TOGETHER, AND TERMINAL BH14 MUST BE TIED TO THE GROUND, BUS AS SHOWN IN THE ELEMENTARY DIAGRAM, FIGURE SD-4. THE CONNECTION TO THE GROUND BUS MUST BE MADE USING A NO. 12 WIRE OR LARGER. THE LEADS USED IN MAKING BOTH OF THESE CONNECTIONS SHOULD BE AS SHORT AS POSSIBLE.

DIRECTIONAL CHECK

It is often desirable to perform a directional check of the relay system before it is placed in service to make sure that the potential and current transformers are phased correctly. This can be accomplished with the PLS relay system using load current and the system voltages. The load current should be greater than 0.5 ampere secondary for this test. If the load current is less, the test may still work if the Fault Detector supervision is defeated by connecting points 55 and 56 on the test card extender to pin 60 (+ 12 vdc).

For load in the tripping direction, use the XTM test plug connections shown in Figure HD-4. These connections simulate an internal θ AG fault by applying rated voltage to phases B and C and zero voltage to phase A, while applying current only to phase A. During this test the trip circuits of the PLS should be interrupted to prevent inadvertent tripping of the breaker. Check for a logic one output at pin 23 of the test card extender. This indicates operation of the forward looking directional element, NT. If the load current is in the non - trip direction, use the XTM test plug connections of Figure HD-5; these connections reverse the θ A current so that the NT unit will operate for this load flow condition.

HD




Figure HD-1 (8043804) PLS Relaying System, Front View




Figure HD-2 (8043803) PLS Relaying System, Rear View




Figure HD-3 (0184B6393 [1]) Outline and Mounting Dimensions




Figure HD-4 (0285A9895) XTM Connections for Dir. Ck. (Tripping Direction)




Figure HD-5 (0285A9896) XTM Connections for Dir. Ck. (Non-Trip Direction)

MODULE DESCRIPTION

Refer to the **CALCULATION OF SETTINGS** section for determination of module settings.

ADM10- (See Figure MO-2)

This module provides the following functions:

1. Directional unit for directional overcurrent channel tripping (NT)
2. Overcurrent unit for directional overcurrent channel tripping (IT)
3. Directional unit for directional overcurrent channel blocking (NB)
4. Overcurrent unit for directional overcurrent channel blocking (IB)

On-Board Switches

IB BIAS	These switches adjust the pickup level of the IB unit. The operating signal is $(2 I_0 + I_2 - 0.2 I_1)$ where $ I_0 $ indicates the magnitude of zero-sequence current. Pickup is in per unit of I_N and is adjustable from 0.05 to 0.755 per unit in steps of 0.025 per unit. The per unit pickup current is equal to 0.05 plus the sum of the closed (toggle to the right) switches.
IT BIAS	These switches adjust the pickup level of the IT unit. The operating signal is $(2 I_0 + I_2 - 0.3 I_1)$ where $ I_0 $ indicates the magnitude of zero-sequence current. Pickup is in per unit of I_N , and is adjustable from 0.05 to 0.755 per unit in steps of 0.025 per unit. The per unit pickup current is equal to 0.05 plus the sum of the closed (toggle to the right) switches.
I ₀ SHUNT	These switches compensate the pickup level of the IT unit for the zero-sequence current in the shunt capacitance of the transmission line. The compensation is in per unit of rated current (I_N) and is adjustable from 0.01 to 0.63 per unit in steps of 0.02 per unit. The per unit compensation is equal to 0.01 plus the sum of the closed (toggle to the right) switches.
I ₂ SHUNT	These switches compensate the pickup level of the IB and IT units for the negative-sequence current in the shunt capacitance of the transmission line. The compensation is in per unit of rated current (I_N) and is adjustable from 0.01 to 0.63 per unit in steps of 0.02 per unit. The per unit compensation is equal to 0.01 plus the sum of the closed (toggle to the right) switches.
KT	These switches adjust the current compensation for the NT and NB units. Compensation is in per unit of reach and is adjustable from 0 to 1 per unit in steps of 0.05 per unit. The per unit compensation is equal to 0 plus the sum of the closed (toggle to the right) switches.

MO

AEM10- (See Figure MO-3)

These modules provide the following functions:

1. Zone 2 positive-sequence distance unit (PDX)
2. Phase current level detectors (IMA, IMB, IMC)
3. Zero-sequence current level detector (3I0)
4. Phase undervoltage detectors (VA, VB, VC)

On-Board Switches

- IM** These switches adjust the pickup level of the IMA, IMB and IMC level detectors. Pickup is in per unit of rated current (I_N) and is adjustable from 0.1 to 1.0 per unit in steps of 0.05 per unit. The per unit pickup is equal to 0.1 plus the sum of the closed (toggle to the right) switches.
- 3I0** These switches adjust the pickup level of the 3I0 level detector. Pickup is in per unit of rated current (I_N) and is adjustable from 0.1 to 0.7 per unit in steps of 0.2 per unit. The per unit pickup is equal to 0.1 plus the sum of the closed (toggle to the right) switches.
- PDX** These switches select the reach of the PDX unit in multiples of the Zone 1 reach (which is set on the front panel of the DPM11- module). This reach multiplier is adjustable from 1 to 2.5 in steps of 0.1, and is equal to 1 plus the sum of the closed (toggle to the right) switches.

AEM11- (See Figure MO-4)

These modules provide the following functions.

1. Fault detector (FD)
2. Positive-sequence current level detector (I1T)

On-Board Switches

- I1** These switches adjust the pickup level of the I1T level detector. Pickup is in per unit of rated current (I_N) and is adjustable from 0.2 to 3.2 per unit in steps of 0.2 per unit. The per unit pickup is equal to 0.2 plus the sum of the closed (toggle to the right) switches.
- VA2** These switches provide an adjustable leading phase shift in the negative- sequence voltage signal for the NT and NB units. This phase shift is adjustable from 0° to 30° in 10° Steps. The phase shift is equal to 0 plus the sum of the closed (toggle to the right) switches.
- ZR1** These switches select the replica impedance angle for the distance measuring units. The replica impedance angle can be selected from 70° to 85° in 5° steps. The characteristic angle is equal to 70° plus the sum the of closed (toggle to the right) switches.

DNM10- (See Figure MO-5)

These modules provide the ND and NDD functions.

On-Board Switches

- ND BIAS** These switches provide an adjustable restraint bias to prevent overreach of the ND unit due to series capacitors. The bias is in per unit with a base voltage of 67 volts RMS line-to-neutral, and is adjustable from 0 to 1.6 per unit in steps of 0.03 per unit. The per unit bias is equal to 0 plus the sum of the closed (toggle to the right) switches.
- N2** These switches select the zone 2 reach of the ND and NDD units in multiples of the zone 1 reach (which is set on the front panel of the DPM11- module). This reach multiplier is adjustable from 1 to 2.5 in steps of 0.1 and is equal to 1 plus the sum of the closed (toggle to the right) switches.
- N3** These switches select the zone 3 reach of the ND and NDD units in multiples of the zone 1 reach (which is set on the front panel of the DPM11- module). This reach multiplier is adjustable from 1 to 4.75 in steps of 0.25, and is equal to 1 plus the sum of the closed (toggle to the right) switches.

DPM10- (See Figure MO-6)

These modules provide the following functions:

1. Overreaching positive-sequence distance unit (PDT)
2. Blocking positive-sequence distance unit (PDB)
3. Out-of-step blocking unit (POSB)

Front Panel Switches

- ZT** These switches adjust the positive-sequence reach of the PDT unit directly, and they also affect the reach of the PDB and POSB units. The reach of 5-ampere- rated relays is adjustable from 2 to 50 ohms in 0.2 ohm steps. The reach is equal to 2 plus the sum of the closed (toggle to the right) switches .

For relays rated 1 ampere, the reach will be 5 times the value determined by the above method.

On-Board Switches

- OFFSET** These switches select the per unit offset (into the protected line section) of the polarizing voltage for the positive-sequence distance units. The offset is adjustable from 0 to 0.3 per unit in 0.1 per unit steps and is equal to 0 plus the sum of the closed (toggle to the right) switches.
- PDB** These switches select the positive-sequence reach of the PDB unit in multiples of the PDT reach (which is set on the front panel of this module). This reach multiplier is adjustable from 0.5 to 2.25 in steps of 0.25 and is equal to 0.5 plus the sum of the closed (toggle to the right) switches.
- POSB** These switches select the positive-sequence reach of the POSB unit in multiples of the PDT reach (which is set on the front panel of this module). This reach multiplier is adjustable from 1 to 2.5 in steps of 0.1 and is equal to 1 plus the sum of the closed (toggle to the right) switches.

On-Board Links

- PDB TC This link selects the time constant for the integrator of the PDB unit. A SHORT and a LONG position are provided.
- PDT TC This link selects the time constant for the integrator of the PDT unit. A SHORT and a LONG position are provided.
- POSB TC This link selects the time constant for the integrator of the POSB unit. A SHORT and a LONG position are provided.

DPM11- (See Figure MO-7)

These modules provide the following functions:

1. Zone 1 positive-sequence distance unit (PD1)
2. Direct trip overcurrent unit (IDT)
3. Time overcurrent unit (TOC)

Front Panel Switches

- Z1 These switches adjust the positive-sequence reach of the PD1, ND and NDD units, and they also affect the reach of the PDX unit. The reach of 5-ampere-rated relays is adjustable from 1 to 25 ohms in 0.1 ohm steps (0.25 to 6.25 ohms for short reach models), and is equal to 1 plus the sum of the closed (toggle to the right) switches.

For relays rated 1 ampere, the reach will be 5 times the value determined by the above method.

On-Board Switches

- DT PU These switches adjust the pickup level of the IDT unit. The operating signal is $(3|I_0| - K_1|I_1|)$ where $|I_0|$ indicates the magnitude of the zero-sequence current and K_1 is a constant equal to either 0 or 1, as selected by the "IDT K_1 " link. Pickup is in per unit of I_N and is adjustable from 0.4 to 4.0 per unit in 0.1 per unit. The per unit pickup current is equal to 0.4 plus the sum of the closed (toggle to the right) switches.
- K0 These switches select the zero-sequence current compensation for the IDT unit. Compensation is adjustable from 1 to 7 per unit in steps of 0.1 per unit and is equal to 1 plus the sum of the closed (toggle to the right) switches.
- PD1 BIAS These switches provide an adjustable restraint bias to prevent transient overreach of the PD1 unit due to series capacitors. The bias is in per unit with a base voltage of 67 volts RMS line-to-neutral and is adjustable from 0 to 1.6 per unit in steps of 0.03 per unit. The per unit bias is equal to 0 plus the sum of the closed (toggle to the right) switches.
- TD These switches select the time-dial setting for the TOC unit. Time delay, at a given multiple of pickup current, increases directly as the time-dial setting increases. The time dial is adjustable from 0.5 to 10 in 0.5 and is equal to 0.5 plus the sum of the closed (toggle to the right) switches.

TOC PU These switches adjust the pickup level of the TOC unit. The operating signal is $(3|I_0| - K_1|I_1|)$ where $|I_0|$ indicates the magnitude of the zero-sequence current and K_1 is a constant equal either to 0 or 0.45, as selected by the "TOC K1" link. Pickup is in per unit of I_N and is adjustable from 0.05 to 0.6 per unit in 0.05 steps. The per unit pickup current is equal to 0.05 plus the sum of the closed (toggle to the right) switches.

On-Board Links

IDT DIR This link selects whether the IDT unit has directional control (DIR position) or does not have directional control (NON-DIR position). It also has an OFF position that disables the IDT unit completely.

IDT K1 This link selects "K1" for the IDT unit, which can be either 0 or 1.

TOC DIR This link selects whether the TOC unit has directional control (DIR position) or does not have directional control (NON-DIR position).

TOC K1 This link selects "K1" for the TOC unit, which can be either 0 or 0.45.

DSM20-

These modules provide the phase selection function.

There are no adjustments on these modules.

TAM101 (See Figure MO-8)

Refer to Continuous Monitor (CM) Section for a detailed description of how to use the Continuous Monitor Module.

ULM15- (See Figure MO-9)

The ULM15- module contains the channel keying, receiver, and phase selection logic. The combinational logic is implemented with programmable logic devices (PLD) which are socket-mounted. The transfer trip timers, TL13 and TL22, are also located on this board.

On-Board Adjustments

TL13 Transfer trip coordination delay time.

Range: 0 to 15 milliseconds in 1 millisecond steps. The operating time is the sum of the closed (toggle to the right) switches.

TL22 Delay to reclose lockout from the receipt of a transfer trip.

Range: 0 to 3.1 seconds in 0.1 second steps. The operating time is the sum of the closed (toggle to the right) switches.

ULM161

The ULM161 module provides the supervision logic for the measuring units. There are no adjustments on this board.

ULM171 (See Figure MO-10)

The ULM171 provides the targeting and output buffering for the scheme. There are two classes of targets, sealed-in (red) and monitor (amber). The red, or sealed-in, targets only light while the trip bus is energized, and retain the trip information for the last trip as long as the unit remains powered. The targets reset automatically on power up, or if a local or remote reset signal is given. The monitor targets are provided to simplify testing and indicate the status of the indicated point.

A crystal oscillator is located on this module. This device controls the relay timing. A watch-dog timer circuit monitors the oscillator output, and will close the Clock Failure Alarm contact if the oscillator fails.

A local reset also initiates a lamp test; all indicators on this module will remain lit while the reset button is depressed. See Table MO-1 for a description of each target.

TABLE MO-1

Panel Marking	Color	Description
A	Red	Phase A fault
B	Red	Phase B fault
C	Red	Phase C fault
ZONE 1	Red	Trip via PD1, ND, IDT or ITOC
ZONE 2	Red	Trip via Zone 2 timer
ZONE 3	Red	Trip via Zone 3 timer
CH. TR.	Red	Channel trip or channel received during Zone 1 trip
DTT	Red	Transfer trip via TL13
50N	Red	Overcurrent direct trip (IDT)
51N	Red	Time overcurrent trip (ITOC)
LPU	Red	Line pickup trip
WI	Red	Weak infeed trip via TL16
TR. BUS	Amber	Trip bus operated
FD	Amber	Fault detector operated
3 POLE	Amber	3-pole trip selected
RCVR	Amber	Channel received
BLK ZN.	Amber	Blocking zone operated
IN SERV	Green	Unit in operable state

On-Board Adjustments

TL26 Supervision timer

Range: 0 to 77.5 milliseconds in 2.5 millisecond steps. The operating time is the sum of the closed (toggle to the right) switches.

BLOCK RI

This switch chooses whether or not reclose initiation is blocked by lockout reclose. With the toggle to the left, reclose initiation is NOT blocked by lockout reclose; when the toggle is to the right, reclose initiation IS blocked by reclose lockout.

ULM181 (See Figure MO-11)

The ULM181 module contains the three-pole, inhibit reclose and lockout reclose logic and the line-pickup timers and logic.

On-Board Adjustment**INHIBIT RECLOSE**

Choose what units will inhibit reclosing:

Switch position 1	PDT unit
Switch position 2	PDX unit
Switch position 3	PD1 unit
Switch position 4	ND unit
Switch position 5	3-pole trip

ULM19- (See Figure MO-12)

The ULM19- module provides the logic for First, Second, Third and Blocking Zone, Channel, Weak Infeed and Out-of-step Block.

Front Panel Adjustments**ZONE 2** Zone 2 (TL2) timer setting

Range: 0 to 3.1 seconds in 0.1 second steps. The operating time is the sum of the closed (toggle to the right) switches. The last switch is labeled IN/OUT. The timer is in service when this switch is set to IN, and out of service when it is set to OUT.

ZONE 3 Zone 3 (TL3) timer setting

Range: 0 to 3.1 seconds in 0.1 second steps. The operating time is the sum of the closed (toggle to the right) switches. The last switch is labeled IN/OUT. The timer is in service when this switch is set to IN, and out of service when it is set to OUT.

WEAK INFEED Weak infeed (TL16) timer setting

Range: 0 to 75 milliseconds in 5 millisecond steps. The operating time is the sum of the closed (toggle to the right) switches. The last switch is labeled IN/OUT. The timer is in service when this switch is set to IN, and out of service when it is set to OUT.

On-Board Settings**TL1** Trip integrator timer setting

Range: 0 to 15.5 milliseconds in 0.5 millisecond steps. The operating time is the sum of the closed (toggle to the right) switches.

TL9 Time delay to blocking of repeat keying from operation of the blocking unit

Range: 0 to 15 milliseconds in 1 millisecond steps. The operating time is the sum of the closed (toggle to the right) switches.

TL24 NB/IB blocking unit dropout time setting

Range: 10 to 120 milliseconds in 10 millisecond steps. The reset time is 10 plus the sum of the closed (toggle to the right) switches.

TL25 PDB blocking unit dropout time setting

Range: 40 to 210 milliseconds. The reset time is 39 plus the sum of the closed (toggle to the right) switches.

OSB Select functions blocked by the out-of-step unit

OSB-2 Blocks all tripping and OSB-1 functions when set to the right

OSB-1 Blocks all transmitter keying, PD1, and pilot tripping, and zone 2 and zone 3 timers.

PSM21- (See Figure MO-13)

The PSM21- module converts station battery to a usable DC voltage.

Front Panel Adjustments

ON-OFF toggle switch with a green LED that illuminates when the power supply is operating

A 3AG fuse is located on the module and is accessible for user replacement if necessary.

Power Supply Outputs:

12V, 1A
24V, 1A
NO, NC Power Supply Alarm Contacts

LOCATION														B	
ZJ	ZG	ZE	ZC	ZA	Y	W	U	S	P	M	K	H			
<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
DNM 10-	DSM 20-	ADM 10-	DPM 10-	DPM 11-	AEM 11-	AEM 10-	ULM 161	ULM 181	ULM 19-	ULM 15-	ULM 171	TAM 101			
1	15	<div>RATINGS: IN AMPS VN VOLTS FREQ HZ VNA VDC</div>				<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
2	16					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
3	17					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
4	18					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
5	19					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
6	20					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
7	21					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
8	22					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
9	23					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
10	24					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
11	25					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
12	26					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
13	27					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
14	28					<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
TP	TP	PM-CM		2V		2N		2L	2J	2G	2E				
				PSM 21-		IDM 203		IDM 203	IDM 203	IDM 101	IDM 202	IDM 202			
				MGM											

SELECT CURRENT
COMPENSATION FOR
NT AND NB UNITS

KT
0+()

☐ .05
.1
.15
.3
.4

COMPENSATES PICKUP
OF ITRIP AND IBLOCK
FOR ZERO SEQUENCE
CURRENT IN SHUNT
CAPACITANCE OF LINE

10 SHUNT
.01+()

☐ .02
.04
.08
.16
.32

IT BIAS
.05+()

☐ .025
.05
.1
.18
.35

IB BIAS
.05+()

☐ .025
.05
.1
.18
.35

12 SHUNT
.01+()

☐ .02
.04
.08
.16
.32

COMPENSATES PICKUP
OF ITRIP AND IBLOCK
FOR NEGATIVE SEQUENCE
CURRENT IN SHUNT
CAPACITANCE OF LINE

SELECTS PICKUP
CURRENT FOR
BLOCKING UNIT
COORDINATING
LEVEL DETECTOR

SELECTS PICKUP
CURRENT FOR
TRIPPING UNIT
LEVEL DETECTOR

ADM101

Figure MO-2 (0285A9825 [3]) ADM10-

3I0
0.1+()

☐ .2
.4

SELECTS PICKUP
CURRENT FOR ZERO
SEQUENCE LEVEL
DETECTOR

1N
0.1+()

☐ .05
.1
.15
.2
.4

SELECTS PICKUP CURRENT
FOR PHASE CURRENT LEVEL
DETECTOR

PDX
1+()

☐ .1
.2
.4
.8

SELECTS REACH OF
ZONE 2 POSITIVE
SEQUENCE DISTANCE
UNIT

AEM10-

Figure MO-3 (0285A9826 [2]) AEM10-

VA2
0+()

☐ 10
☐ 20

SELECTS PHASE SHIFT
IN NEGATIVE SEQUENCE
VOLTAGE FOR NT AND NB
UNITS

ZR1
70+()

☐ 5
☐ 10

SELECTS REPLICA
IMPEDANCE ANGLE
FOR DISTANCE UNITS

SELECTS PICKUP
CURRENT OF POSITIVE
SEQUENCE CURRENT
DETECTOR

I1
0.2+()

☐ .2
☐ .4
☐ .8
☐ 1.6

AEM11-

Figure MO-4 (0285A9827 [1]) AEM11-

N2
1+()

☐ .1
☐ .2
☐ .4
☐ .8

SELECTS REACH OF
ZONE 2 NEGATIVE
SEQUENCE DISTANCE
UNIT

N3
1+()

☐ .25
☐ .5
☐ 1
☐ 2

SELECTS REACH OF
ZONE 3 NEGATIVE
SEQUENCE DISTANCE
UNIT

ND BIAS
0+()

☐ .03
☐ .06
☐ .11
☐ .2
☐ .4
☐ .8

SELECTS RESTRAINT
BIAS FOR NEGATIVE
SEQUENCE DISTANCE
UNIT

DNM10-

≠ (NOT USED ON SHORT REACH MODELS (DNM107/108))

Figure MO-5 (0285A9828 [1]) DNM10-




Figure MO-7 (0285A9830 [4]) DPM11-




Figure MO-8 (0285A9831 [3]) TAM101




Figure MO-9 (0285A9832 [1]) ULM15-




Figure MO-10 (0285A9833 [1]) ULM171




Figure MO-11 (0285A9834 [1]) ULM181




Figure MO-12 (0285A9835 [2]) ULM19-




Figure MO-13 (0286A2547 [1]) PSM21-

ACCEPTANCE TESTS

ACCEPTANCE TESTS

The operational tests described in this section should be conducted prior to the installation of the PLS system. These may be done on a "bench-top" basis.

One method of removing power is to turn OFF the power switch on the PSM21- power supply module and then remove both of the connection plugs located in the TPM position.

REQUIRED SETTINGS

To begin the acceptance tests, the module settings should be as indicated in Tables AT-1 and AT-2 (see next pages). Remove the modules to gain access to the links and switches referred to in Table AT-2. Module locations are shown in Figure MO-1.

Where there are different values for 5 ampere and 1 ampere relays, the value for the 1 ampere relay is given in parentheses after the 5-ampere value.

TEST EQUIPMENT

The acceptance tests may be conducted in a conventional manner using the following test equipment:

- Three-phase source of voltage and current at rated frequency
- DC control voltage source
- Three AC voltmeters
- Three AC ammeters
- One oscilloscope
- One card extender (GE #0138B7406G1)
- One pair XTM test plugs (GE #XTM28R1 and XTM28L1)

The specific requirements for this equipment are given in the text of this **ACCEPTANCE TESTS** section, and in the associated test circuit diagrams.

The three-phase AC sinusoidal voltage must be balanced and undistorted. Similarly, the DC power should come from a good DC source having less than 5% ripple.

As an alternative, a three phase electronic test source may be used. In many cases, these devices enable the test circuits to be simplified considerably.

TEST CONNECTIONS

The test circuit diagrams indicate not only PLS terminal numbers (rear cover terminals) but also the corresponding XTM test plug terminal numbers, and Test Point connections. For the acceptance tests, the test connections should be made to the rear cover terminals. The test plugs are intended for post-installation testing and are described in a separate subsection under **PERIODIC TESTING**.

INITIAL RELAY SETTINGS

1. Place the front panel switches on the modules in the positions listed in Table AT-1. Refer to Module Section (MO) for switch locations.

Table AT-1: Front Panel Settings

Module	Function	Short Reach	Long Reach
DPM11-	Z1	3 (15)	12 (60)
DPM10-	ZT	2	2
ULM19-	ZONE 2	1 Sec	1 Sec
ULM19-	ZONE 3	3 Sec	3 Sec
ULM19-	WEAK INFEED	20 mSec	20 mSec

2. Place the internal links and switches on the modules in the positions shown in Table AT-2. Refer to Module Section (MO) for switch locations.

Table AT-2: Relay Settings

MODULE	FUNCTION	TYPE*	DESCRIPTION	SETTING
ADM10-	KT 0+()	5s	NT/NB compensation	0
	I2 shunt .01+()	5s	IT adaptive restraint	0.01
	I0 shunt .01+()	5s	IT adaptive restraint	0.01
	IT bias .05+()	5s	IT pickup setting	0.2
	IB bias .05+()	5s	IB pickup setting	0.2
AEM10-	IM .1+()	5s	IMA,IMB,IMC pickup	0.4
	3I0 .1+()	2s	3I0 Pickup	0.3
	PDX 1+()	4s	PDX reach multiplier	1.0
AEM11-	VA2 0+()	2s	NT/NB phase shift	0
	ZR1 70+()	2s	Replica impedance angle	85
	I1 .2+()	4s	I1T pickup	0.4
DNM10-	N2 1+()	4s	ND/NDD Z2 reach mult.	2.0
	N3 1+()	4s	ND/NDD Z3 reach mult.	4.0
	ND bias 0+()	6s**	ND restraint bias	0
DPM10-	OFFSET 0+()	2s	forward offset	0
	PDB 0.5+()	3s	PDB reach multiplier	1.0
	POSB 1.0+()	4s	POSB reach multiplier	1.0
	PDB TC	2b	PDB time constant	short
	PDT TC	2b	PDT time constant	short
	POSB TC	2b	POSB time constant	short
	DT PU .4+()	6s	IDT pickup	0.4
DPM11-	TOC PU .05+()	4s	ITOC pickup	0.2
	TD .5+()	5s	ITOC time dial	10.0
	PD1 bias 0+()	6s**	PD1 restraint bias	0
	K0 1+()	6s	IDT I0 compensation	1.0
	IDT K1	2b	IDT I1 restraint factor	1.0
	TOC K1	2b	ITOC I1 restraint factor	0.45
	IDT DIR	4b	IDT directional control	Non-Dir
	TOC DIR	3b	ITOC directional control	Non-Dir
	ULM15- TL13	4s	DTT timer	4msec
	ULM15- TL22	5s	DTT reclose lockout timer	2sec
ULM171	BLOCK RI	1s	Reclose initiate control	Out/Left
ULM181	TL26	5s	Coordination timer	30msec
	Inhibit reclose	5s	PDT selection	Out/Left
			PDX selection	Out/Left
			PD1 selection	Out/Left
			ND selection	Out/Left
			3PT selection	Out/Left

MODULE	FUNCTION	TYPE*	DESCRIPTION	SETTING
ULM19-	TL1	5s	Trip integrator	3msec
	TL9	4s	Repeat blocking timer	4msec
	TL24	4s	NB dropout timer	80msec
	TL25	4s	PDB dropout timer	80msec
	OSB-1	2s	OSB block selection	Out/Left
	OSB-2	2s	OSB block selection	Out/Left

* 5s = five position toggle switch, 2b = two position berg post.

** Not adjustable on short reach models.

GENERAL INSTRUCTIONS

- Remove the upper right blank module and insert a card extender (GE#0138B7406G1) in this location. The oscilloscope ground should be connected to pin 1 of this card for all tests.

Place the test source in rated frequency position. Turn on the power supply and check that the green LED on the PSM21- module is lit.
- The following tests are intended to verify the operation of the measuring units. If it is desired to check outputs or targets, refer to the logic diagram.
- In the following tests, a LOW is defined as approximately 0 volts and a HIGH is defined as approximately 10 volts.
- Where two numbers are shown: xx(yy), xx is the value to be used for relays rated 5 amperes, and (yy) is the value to be used for relays rated 1 ampere.
- If the test source is an electronic type and one (or more) current source is not used for a particular test, that source must be set to "zero" in addition to being turned OFF. Also, these current sources should only be switched with the current set at, or near, zero.
- All phase angles of test sources are shown relative to phase A voltage. A (+) phase angle refers to the referenced quantity leading phase A voltage. A (-) phase angle refers to the referenced quantity lagging voltage.

LEVEL DETECTOR TESTS

- Make the connections shown in Figure AT-1 with relay input Y connected to BH1 or TP9. Connect the oscilloscope probe to card extender Pin 2. Set the oscilloscope for external trigger.

2. Fault Detector Test

Set current IOP at 0.5 (0.1) ampere RMS. Close the push-button test switch for approximately one second. When the push button test switch opens, the oscilloscope trace at pin 2 should go to HIGH momentarily, after which it should return to LOW. Increase IOP to 2.25 (0.45) amperes RMS and repeat the test 2. The oscilloscope trace should remain HIGH except when the push-button test switch is closed.

3. IT Test

Move the oscilloscope input to card extender pin 14. Place a temporary jumper between pins 56 and 60 of the card extender. Set current IOP at 1.4 (0.28) amperes RMS. Close the push-button switch for approximately one second. When the push-button test switch opens, the oscilloscope trace should stay LOW.

Increase current IOP to 1.9 (0.38) amperes RMS and repeat the above test. The oscilloscope trace should go HIGH when the push-button test switch is open. Remove the temporary jumper between pins 56 and 60 on the card extender.

4. IMA Test

Make the connections shown in Figure AT-1 for testing the IMA function. Connect the scope probe to pin 3 of the test card extender. Slowly increase the current IOP until the oscilloscope trace goes from LOW to HIGH. At this point, the current should be between 1.96 (0.39) and 2.30 (0.46) amperes RMS.

5. IMB Test

Change connections to those shown in Figure AT-1 for testing the IMB function and repeat step 4. Monitor pin 4 on the oscilloscope.

6. IMC Test

Change connections to those shown in Figure AT-1 for testing the IMC function and repeat step 4. Monitor pin 5 on the oscilloscope.

7. 3I0 Test

Change connections to those shown in Figure AT-1 for testing the 3I0 LD function. Slowly increase the current IOP until the oscilloscope trace at pin 10 goes from low to high. At this point the current should be between 1.47 (0.29) and 1.65 (0.33) amperes RMS.

8. IIS Test

Change connections to those shown in Figure AT-1 for testing the IIS function and repeat step 4, except that the pickup current should be between 0.60 (0.12) and 1.0 (0.2) amperes RMS. Monitor pin 11 on the oscilloscope.

9. IIT Test

Change connections to those shown in Figure AT-1 for testing the IIT function and repeat step 4, except that the pickup current should be between 5.56 (1.12) and 6.6 (1.32) amperes RMS. Monitor pin 12 on the oscilloscope.

10. IB Test

Place temporary jumpers between pins 55, 56 and 60 on the card extender. Connect the oscilloscope input to card extender pin No. 13. Slowly increase "IOP" until the oscilloscope trace goes from LOW to HIGH. At this pickup point, the current "IOP" should be between 0.9 (0.16) and 1.1 (0.22) amperes RMS.

11. IDT Test

Move the oscilloscope input to card extender pin No. 15 and repeat test 10, except that pickup should occur when "IOP" is between 2.70 (0.54) and 3.15 (0.63) amperes RMS.

12. TOC PU Test

Move the oscilloscope input to card extender pin No. 54 and repeat test 10, except that pickup should occur when "IOP" is between 1.1 (0.22) and 1.30 (0.26) amperes RMS.

13. Not VA Test

Change connections to those shown in Figure AT-2 for testing the "Not VA" function. Slowly decrease voltage "VA" until pulses start to appear on the oscilloscope. "VA" should be between 40 and 45 volts RMS at this point. Continue decreasing "VA" until the oscilloscope trace is HIGH continuously, at which point "VA" should be 30 volts RMS or higher.

14. Not VB Test

Change connections to those shown in Figure AT-2 for testing the "Not VB" function. Repeat test 13.

15. Not VC Test

Change connections to those shown in Figure AT-2 for testing the "Not VC" function. Repeat test 13.

POSITIVE SEQUENCE DISTANCE TESTS

Change connections to those shown in Figure AT-3. Leave the temporary jumpers between pins 55, 56, and 60 on the card extender, and add a temporary jumper from pin 38 to pin 1. Move the oscilloscope input to card extender pin 17. Set angle IA = -85° (lagging), angle IB = $+155^\circ$ (leading) and angle IC = $+35^\circ$ (leading), at 5.0 (1.0) amperes RMS.

Long Reach Scheme Setup (PD1)

Set VA, VB and VC to 70 volts RMS and set angles VA to 0° , VB to -120° and VC to $+120^\circ$. Reduce VA, VB, and VC until the measuring unit under test picks up as indicated by the oscilloscope trace going from LOW to HIGH.

Short Reach Scheme Setup (PD1)

Set VA, VB and VC to 60 volts RMS and set angles VA to 0° , VB to -120° and VC to $+120^\circ$. Reduce VA, VB, and VC until the measuring unit under test picks up as indicated by the oscilloscope trace going from LOW to HIGH.

PD1 Reach

Move the oscilloscope input to card extender pin 17 perform the PD1 test as shown in the setup. This test checks the PD1 reach at the replica impedance angle including the pull-back effect at this current level (approximately 3%). See Table AT-3 for test tolerances.

PDX Reach

Move the oscilloscope input to card extender pin 19 and perform the test as shown in the setup. This test checks "PDX" reach at the replica impedance angle, including the pull-back effect at this current level (approximately 3%). See Table AT-3 for test tolerances.

PDT Reach

Reduce the reach on DPM11- module to 1 (5) ohms and increase the reach on the DPM10- module to 12 (60) ohms. Move the oscilloscope input to card extender pin 20 and perform the test as shown in the setup. See Table AT-3 for test tolerances. This test checks "PDT" reach at the replica impedance angle, including the pull-back effect at this current level (approximately 2%).

POSB Reach

Move the oscilloscope input to card extender pin 22 and lower IA, IB and IC to 4.5 (0.9) amperes RMS. Perform the test as shown in the setup. This test checks "POSB" reach. See Table AT-3 for test tolerances.

PDB Reach

Move the oscilloscope input to card extender pin 21 and raise IA, IB and IC to 5.0 (1.0) amperes RMS. Set angle IA = +95°, angle IB = -25° and angle IC = -145°. Set VA, VB, and VC to 70 Volts RMS, at 0°, -120°, and +120° respectively. Set and lower the input voltages as shown in the setup until the oscilloscope trace goes from LOW to HIGH. See table III for test tolerances. Then raise the input voltages until the oscilloscope trace goes from HIGH to LOW. This dropout point should occur between 6 and 12 volts RMS above the pickup voltage.

TABLE AT-3: Reach Test Tolerances

UNIT	TP	SHORT REACH		LONG REACH	
		MIN	MAX	MIN	MAX
PD1	17	10	18	42	60
PDX	19	10	18	42	60
PDT	20	6	15	47	65
POSB	22	6	15	54	66
PDB	21	12	24	48	66

NEGATIVE SEQUENCE DISTANCE TESTS**ND**

Change connections to those shown in Figure AT-4. Add temporary jumpers between pins 55, 56, 57, 58 and 60 on the card extender. Move the oscilloscope input to card extender pin 25. Increase the reach on DPM11- module to 3 (15) ohms. Set VA = 67 volts RMS, VB = 47 volts RMS and VC = 47 volts RMS. Set angle VB = -135° and angle VC = +135°. Set angle IOP = -175°. Slowly increase IOP until the oscilloscope trace goes from LOW to HIGH. At this pickup point, the current IOP should be between 10.5 (2.1) and 12.67 (2.53) amperes RMS. This test checks the "ND" reach, including the pull-back effect (approximately 2%).

ND ZONE 2 REACH

Remove the temporary jumpers from pins 58 on the card extender. Repeat ND test, except that Iop at pin 25 should now be between 5.0 (1.0) and 7.0 (1.2) amperes RMS. This test checks the Zone 2 reach multiplier.

ND ZONE 3 REACH

Remove the temporary jumper from pin 57 to pin 60 and add a temporary jumper from pin 58 to pin 60 on the card extender. Repeat ND Zone 2 Reach test, except that Iop at the pickup point should now be between 2.72 (.54) and 3.32 (.67) amperes RMS. This test checks the zone 3 reach multiplier.

NDD

Move the oscilloscope input to card extender pin No. 26 and repeat ND test, except that now the pickup should occur between 9.0 (1.80) and 13.0 (2.6) amperes. This test checks the "NDD" reach, including the pull-back effect (approximately 2%).

NDD ZONE 2 REACH

Remove the temporary jumper from pin 58 to pin 60 on the card extender. Repeat ND test, except that Iop at pin 26 should now be between 5.1 (1.0) and 6.5 (1.1) amperes RMS. This test checks the Zone 2 reach multiplier.

NDD ZONE 3 REACH

Remove the temporary jumper from pin 57 to pin 60 and add a temporary jumper from pin 58 to pin 60 on the card extender. Repeat ND Zone 2 Reach test, except that Iop at the pickup point should now be between 2.48 (.49) and 3.04 (.61) amperes RMS. This test checks the zone 3 reach multiplier.

NEGATIVE SEQUENCE DIRECTIONAL TESTS**1. NT Unit.**

Add temporary jumpers to pins 55, 56, and 60 on the card extender. Change connections to those shown in Figure AT-5 with relay input Y connected to BH1 or TP9. Move the oscilloscope input to card extender pin No. 23. Set VA = 30 volts RMS, VB = 67 volts RMS, VC = 67 volts RMS. Set angle VB = -120° and angle VC = +120°. Set angle IA = -85°. Slowly increase IA until the oscilloscope trace goes from LOW to HIGH. At this pickup point, current IA should be less than 0.06 (0.012) amperes RMS.

Change angle IA to +95° and check that the oscilloscope trace does not go HIGH as IA is increased up to 10 (2) amperes RMS.

2. NB Unit.

Move the oscilloscope input to card extender pin No. 24. Reduce IA to 1.0 (0.2) amperes RMS and check that the oscilloscope trace is HIGH.

Change the angle IA to -85° and check that the oscilloscope trace is LOW.

PHASE SELECTORS

1. Move the oscilloscope input to card extender pin 27. Set IOP = 1.6 (0.32) amperes RMS and leave all other settings set per step 1 of NEGATIVE-SEQUENCE DIRECTIONAL TESTS. Check that the oscilloscope trace is HIGH.
2. Change connections to those shown for testing PHB SEL in Figure AT-5. Raise VA to 67 volts RMS, lower VB to 30 volts RMS and set angle IOP to -205°. Check that the oscilloscope trace at pin 28 is HIGH.

3. Change connections to those shown for testing PHC SEL in Figure AT-5. Raise VB to 67 volts RMS, lower VC to 30 volts RMS and set the angle of Iop to -325° . Check that the oscilloscope trace at pin 29 is HIGH.

DIELECTRIC TESTS

Dielectric testing may be performed 1) between all terminals (tied together) and the case, and 2) between independent circuit groups (refer to elementary diagram, Figure SD-4). The recommended voltage is 2000 volts RMS for initial testing and 1500 volts RMS for subsequent periodic testing. The test voltage should be applied for 1 minute.

CAUTION

When hipot testing, it is necessary to remove the jumpers between terminals BH13 and BH14. This removes the grounding connection between the surge capacitors and case ground. Failure to do so could result in damage to the filter capacitors on the PSM module when the DC supply terminals are tested.

NOTE

All other studs can be tested with the jumper in place without damage; however, leakage will be indicated due to current flowing through the surge capacitors.




Figure AT-1 (0285A9838 [2]) Level Detector Test Connections




Figure AT-2 (0285A9839 [1]) Not VA, VB, VC Test Connections




Figure AT-3 (0285A9840 [1]) Positive-Sequence Distance Test Connections




Figure AT-4 (0285A9841 [2]) Negative-Sequence Distance Test Connections




Figure AT-5 (0285A9842 [1]) Negative-Sequence Directional Test Connections and Phase Selectors Test Connections




Figure AT-6 (0285A9843 [1]) IT Test Connections

PERIODIC TESTING

TESTING THE PLS OPERATION WITH DIFFERENT SETTINGS

Because of the level of sophistication of the PLS modular relay system and the large number of selections that may be made, it is impossible to present one or two equations that will satisfy every condition. An attempt has been made, however, to allow the calculation of the pickup currents or voltages for the functions when using the test circuits described in the corresponding section of the ACCEPTANCE TESTS portion of this instruction book. This will permit some testing to be done using settings other than those specified as part of the acceptance tests.

To test with different settings, refer to the corresponding section of ACCEPTANCE TESTS. For instance, if the PD1 function is being tested, use the same test setup and settings as described in the PD1 portion, but use the equations and notes below to modify the expected test results.

Tolerance

The tolerances on the pickup values calculated for the PLS functions are dependent on the magnitude of the test current, as listed in Table PT-1.

TABLE PT-1: Test Tolerances*

<u>ITEST (RMS Amperes)</u>		<u>Tolerance in Percent</u>	
<u>IN = 5</u>	<u>IN = 1</u>	<u>Minimum</u>	<u>Maximum</u>
0-1	0 -0.2	0	+15
1-3	0.2-0.6	-2	+10
3-7	0.6-1.4	-3	+7
>7**	>1.4**	-5	+5

* The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current, or $\pm .025$ per unit of IN, whichever is greater.

** Note that the relay is continuously rated for 10 (2) amperes RMS. For test currents greater than the continuous rating, testing should be conducted with a duty cycle. For example, with a test current of 20 (4) amperes, the current should not be applied longer than 5 minutes, followed by a cooling-off period of 5 minutes.

CURRENT LEVEL DETECTORS

A. IMA, IMB, IMC

Use the connections shown in Figure AT-1 for testing IMA. Slowly increase the current, IOP, until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 1. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = IM \times IN \quad (1)$$

Where: IM is the pickup set on the AEM10- module
 IN is the rated relay current (1 or 5 amperes)
 IPU is the nominal pickup current



To test IMB and IMC use the procedure specified for IMA, and the appropriate connections from Figure AT-1.

B. 3I0

Use the connections shown in Figure AT-1 for testing 3I0. Slowly increase the current, IOP, until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 2. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current, or $\pm .025$ per unit, whichever is greater.

$$IPU = 3I0 \times IN \quad (2)$$

Where: 3I0 is the pickup set on the AEM10- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

C. I1T

Use the connections shown in Figure AT-1 for testing I1T. Slowly increase the current, IOP, until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 3. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = I1 \times IN \times 3 \quad (3)$$

Where: I1 is the pickup set on the AEM11- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

D. IB

Place temporary jumpers between pins 55, 56, and 60 on the test card extender. Use the connections shown in Figure AT-1 for testing IB. Slowly increase current IOP until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 4. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = 1.07 \times IB \text{ BIAS} \times IN \quad (4)$$

Where: IB BIAS is the IB pickup set on the ADM10- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current
Tolerance = $\pm .025$ per unit, or equal to Table PT-1, whichever is greater

E. IT

The IT unit in the PLS is designed with an adaptive pickup circuit; that is, when a current higher than pickup is suddenly applied to the relay, IT will pick up initially, but after a time delay the unit will "adapt" to the steady-state current level and will reset. The duration of the output is a function of the difference between the applied current and the pickup current.

There are two methods of testing the IT unit. The first involves defeating the adaptive pickup circuit by means of a temporary jumper. This allows the pickup to be measured with steady-state currents. The second method uses a transiently applied test current. In this test, the IT unit will "adapt" and drop out after a short time delay.

Method I (without adaptive pickup)

Place the ADM10- module in a card extender. Connect a jumper from TP7 on the module (TP7 is located behind the nameplate, towards the bottom of the module) and reference (pin 1 on the card extender).

Place temporary jumpers between pins 55, 56, and 60 on a second card extender in the test card position. Use the test connections shown in Figure AT-6 and connect the oscilloscope input to test card extender pin 14. Slowly increase current IOP until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is calculated in Equation 5. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = 1.1 \times IT \text{ BIAS} \times IN \quad (5)$$

Where: IT BIAS is the IT pickup set on the ADM10- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

After the IT unit has picked up, remove the jumper from TP7 and check that the oscilloscope trace goes from HIGH to LOW. Place the ADM10- module in its original location.

Method II (with adaptive pickup)

NOTE: When the PLS is tested with transiently-applied current, the waveform of the test current should be similar to the currents the relay will see in service. In particular, the relay should not be tested with currents that have an unrealistic rate of rise. Therefore, the test current should be limited by reactance, rather than by resistance. If an electronic current source is used, it should be the type that only turns ON the current at a current zero crossing. Use of other types of current sources may cause pickup values that appear to be out of tolerance.

Place temporary jumpers between pins 55, 56, and 60 on the card extender in the test position. Connect the oscilloscope input to pin 14 on the test card extender. Use the test current connections of Figure AT-6.

Without current applied to the relay, set the current level to the value specified by Equation 6.

$$IPU = 1.4 \times IT \text{ BIAS} \times IN \quad (6)$$

Where: IT BIAS is the IT pickup set on the ADM10- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

Suddenly apply the calculated test current and check that the oscilloscope trace momentarily goes from LOW to HIGH. If this test is repeated, wait at least 30 seconds between tests to allow the adaptive circuit to reset.

Without current applied to the relay, set the current level to the value specified by Equation 7.

$$IPU = 1.9 \times IT \text{ BIAS} \times IN \quad (7)$$

Where: IT BIAS is the IT pickup set on the ADM10- module
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

Suddenly apply the calculated test current and check that the oscilloscope trace does not go from LOW to HIGH.

F. Fault Detector Pickup.

Set current IOP at 0.5 (0.1) ampere RMS. Close the pushbutton test switch for approximately one second. When the push button test switch opens, the oscilloscope trace at pin 2 should go to HIGH momentarily, after which it should return to LOW. Increase IOP to 2.25 (0.45) amperes RMS and repeat the test. The oscilloscope trace should remain HIGH except when the pushbutton test switch is closed.

DIRECTIONAL TESTS

NOTE: The IDT and ITOC tests can be performed directionally, or non-directionally, depending upon customer settings. If both tests are performed, return the directional controls to the proper setting.

A. ITOC (Non-directional)

Use the connections shown in Figure AT-1 for testing TOC. Set the TOC DIR setting to NON-DIR on the DPM11- module for this test. Return the ITOC pickup setting to required value. Slowly increase the current, IOP, until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 8. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = \frac{3}{3-TOC K1} \times TOC \text{ PU} \times IN \quad (8)$$

Where: TOC PU is the pickup set on the DPM11- module
TOC K1 is the I1 restraint factor set on the DPM11- module (0 or 0.45)
IN is the rated relay current (1 or 5 amperes)
IPU is the nominal pickup current

NOTE: Return the TOC DIR setting to its required setting following this test.

B. ITOC (directional)

Use the connections shown in Figure AT-5, and connect "Y" to BH1. Set the IDT DIR berg post to DIR on the DPM11- module. Place temporary jumpers between pins 55,56, and 60 on the test card extender. The nominal pickup current is given by equation 8. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

Set the voltage phase angles per Table PT-2, set IOP to -85°. Set VA to 47V, VB and VC to 69 volts RMS.

Slowly increase Iop from 0 amps until the oscilloscope trace at pin 54 goes from LOW to HIGH.

Change the angle of IOP to +100° and verify that the oscilloscope trace goes from HIGH to LOW.

C. IDT (Non-directional)

NOTE: To prevent ITOC tripping during this test, temporarily set ITOC pickup to the maximum value and the time dial to ten (10). If the IDT directional control is set to "NON-DIR" go to test E and continue testing.

Use the connections shown in Figure AT-1 for testing IDT. Place temporary jumpers between pins 55,56, and 60 on the test card extender. Slowly increase the current, IOP, until the oscilloscope trace goes from LOW to HIGH. The nominal pickup current is given by Equation 9. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

$$IPU = \frac{3}{3-IDT K1} \times DT PU \times IN \quad (9)$$

Where: DT PU is the pickup set on the DPM11- module
 IDT K1 is the I1 restraint factor set on the DPM11- module (0 or 1)
 IN is the rated relay current (1 or 5 amperes)
 IPU is the nominal pickup current

D. IDT (directional)

Use the connections shown in Figure AT-5, and connect "Y" to BH1. Set the IDT DIR berg post to DIR on the DPM11- module. Place temporary jumpers between pins 55,56, and 60 on the test card extender. The nominal pickup current is given by equation 9. The actual pickup current should be within the tolerance given in Table PT-1 for the particular value of test current.

Set the voltage phase angles per Table PT-2, set IOP to -85° . Set VA to 47V, VB and VC to 69 volts RMS.

Slowly decrease Iop from 2 amps until the oscilloscope trace at pin 15 goes from HIGH to LOW.

Change the angle of IA to +100° and verify that the oscilloscope trace goes from LOW to HIGH.

POSITIVE-SEQUENCE DISTANCE UNITS

A. PD1

Use the connections shown in Figure AT-3, and connect a temporary jumper between pin 38 and pin 1. Connect temporary jumpers between pins 55, 56 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 17 on the test extender. For the PD1 test only, set the "ZT" reach on the front plate of the DPM10- module to 2 (10) ohms.

Set the current and voltage phase angles per Table PT-2.

TABLE PT-2: Phase Angle Settings

<u>FUNCTION</u>	<u>ANGLE</u>
IA	$-\theta$
IB	$-(\theta + 120)$
IC	$120 - \theta$
VA	0
VB	-120
VC	120

Where θ is the ZR1 angle set on the AEM11- module.

The current used for this test should be equal to or greater than the value given in Table PT-3. The magnitude of all three phase currents should be equal.

TABLE PT-3: Test Tolerance

<u>Z1</u>	<u>ITEST</u>	<u>TOLERANCE (%)</u>		<u>Z1</u>	<u>ITEST</u>
		<u>MIN</u>	<u>MAX</u>		
1 - 6 Ω	10	-5	+5	5 - 30 Ω	2
6 - 12 Ω	5	-7	+3	30 - 60 Ω	1
12 - 20 Ω	3	-10	+2	60 - 100 Ω	0.6
20 - 25 Ω	2	-15	0	100 - 150 Ω	0.4

The nominal operating voltage is given by Equation 10.

$$VOP = (ITEST \times Z1) - PD1 \text{ BIAS} - 1.5 \quad (10)$$

Where: ITEST is the test current
 Z1 is the PD1 reach set on the front panel of the DPM11- module
 PD1 BIAS is the bias set on the DPM11- module multiplied by 67 to convert from per unit
 VOP is the nominal operating voltage

The applied voltage should initially be set to a value larger than the nominal operating voltage, and the three phase voltages should be lowered simultaneously until the PD1 unit operates, i.e. until pin 17 on the test extender steps from LOW TO HIGH. The actual operating voltage should be within the tolerances given in Table PT-3 for the value of ITEST used.

NOTE: For short-reach relays ($Z1 < 1\Omega$), a test current of 30A is recommended. The test tolerance is -10% to +2%

B. PDT

Use the connections shown in Figure AT-3. Connect temporary jumpers between pins 55, 56, and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 20 on the test extender.

Set the current and voltage phase angles per Table PT-2.

The current used for this test should be equal to or greater than the value given in Table PT-4. The magnitude of all three phase currents should be equal.

TABLE PT-4: Test Tolerances

IN = 5		Tolerance%		IN = 1	
ZT	ITEST	MIN	MAX	ZT	ITEST
2- 6 Ω	10	5	5	10- 30 Ω	2
6-12 Ω	5	7	3	30- 60 Ω	1
12-20 Ω	3	10	2	60-100 Ω	0.6
20-30 Ω	2	15	0	100-150 Ω	0.4
30-40 Ω	1.5	15	0	150-200 Ω	0.3
40-60 Ω	1	15	0	200-30 Ω	0.2

The nominal operating voltage is given by Equation 11.

$$VOP = ITEST \times ZT \quad (11)$$

Where: ITEST is the applied test current
 ZT is the PDT reach set on the front panel of the DPM10- module
 VOP is the nominal operating voltage

The applied voltage should initially be set to a value larger than the nominal operating voltage, and the three phase voltages should be lowered simultaneously until the PDT unit operates, i.e. until pin 20 on the test extender steps from LOW TO HIGH. The actual operating voltage should be within the tolerances given in Table PT-4 for the value of ITEST used.

C. PDB

Use the connections shown in Figure AT-3. Connect temporary jumpers between pins 55, 56, and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 21 on the test extender.

Set the current and voltage phase angles per Table PT-5. The reach of the PDB unit is equal to the product of the PDT reach and the PDB reach multiplier set on the DPM10-. The recommended test current is determined by the PDB reach, as shown in Table PT-6. The current used for this test should be equal to or greater than the value given in Table PT-6. The magnitude of all three phase currents should be equal.

TABLE PT-5: Voltage/Current Settings

Function	Phase angle
IA	180- θ
IB	-(θ -60)
IC	-(θ +60)
VA	0
VB	-120
VC	+120

Where θ is the ZR1 angle set on the AEM11- module.

TABLE PT-6: PDB Test Current Values

IN=5		IN=1	
ZRPDB	ITEST	ZRPDB	ITEST
2- 6	10	10- 30	2
6-12	5	30- 60	1
12-20	3	60-100	0.6
20-30	2	100-150	0.4
30-40	1.5	150-200	0.3
40-60	1	200-300	0.2

The nominal operating voltage is given by Equation 12.

$$VOP = ITEST \times ZRPDB \quad (12)$$

Where: ITEST is the applied test current

$$ZRPDB = ZT \times PDB$$

ZT is the PDT reach set on the front of the DPM10- module.

PDB is the reach multiplier, set on the DPM10- module.

VOP is the nominal operating voltage

The applied voltage should initially be set to a value larger than the nominal operating voltage, and the three phase voltages should be lowered simultaneously until the PDB unit operates, i.e. until pin 21 on the test extender steps from LOW TO HIGH. The actual operating voltage should be within the tolerances given in Table PT-3 for the value of ITEST used.

D. POSB

Use the connections shown in Figure AT-3. Connect temporary jumpers between pins 55, 56, and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 22 on the test extender.

Set the current and voltage phase angles per Table PT-2. The reach of the POSB unit is equal to the product of the PDT reach and the POSB reach multiplier set on the DPM10-. The recommended test current is determined by the POSB reach, as shown in Table PT-7. The current used for this test should be equal to or greater than the value given in Table PT-7. The magnitude of all three phase currents should be equal.

TABLE PT-7: POSB Test Current Values

IN=5		IN=1	
ZRPOSB	ITEST	ZRPOSB	ITEST
2- 6	10	10- 30	2
6-12	5	30- 60	1
12-20	3	60-100	0.6
20-30	2	100-150	0.4
30-40	1.5	150-200	0.3
40-60	1	200-300	0.2

The nominal operating voltage is given by Equation 13.

$$VOP = ITEST \times ZRPOSB + 8 \quad (13)$$

Where: ITEST is the applied test current
 ZRPOSB is the product of the PDT reach set on the front of the DPM10- module, ZT, and the POSB reach multiplier, POSB.
 VOP is the nominal operating voltage

The applied voltage should initially be set to a value larger than the nominal operating voltage, and the three phase voltages should be lowered simultaneously until the POSB unit operates, i.e. until pin 22 on the test extender steps from LOW TO HIGH. The actual operating voltage should be within the tolerances given in Table PT-4 for the value of ITEST used.

E. PDX

Use the connections shown in Figure AT-3. Connect temporary jumpers between pins 55, 56, and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 19 on the test extender.

Set the current and voltage phase angles per Table PT-2. The reach of the PDX unit is equal to the product of the PD1 reach set on the DPM11- module, Z1, and the PDX reach multiplier set on the AEM10- module. The recommended test current is determined by the PDX reach, as shown in Table PT-8. The current used for this test should be equal to or greater than the value given in Table PT-8. The magnitude of all three phase currents should be equal.

TABLE PT-8: PDX Test Current Values

IN = 5		IN = 1	
ZRPDX	ITEST	ZRPDX	ITEST
1- 6	10	5- 30	2
6-12	5	30- 60	1
12-20	3	60-100	0.6
20-25	2	100-125	0.4

The nominal operating voltage is given by Equation 14.

$$VOP = ITEST \times ZRPDX \quad (14)$$

Where: ITEST is the applied test current
 ZRPDX is the product of the PD1 reach set on the front of the DPM11- module (Z1), and the PDX reach multiplier set on the AEM10- module, (PDX).
 VOP is the nominal operating voltage

The applied voltage should initially be set to a value larger than the nominal operating voltage, and the three phase voltages should be lowered simultaneously until the PDX unit operates, i.e. until pin 19 on the test extender steps from LOW TO HIGH. The actual operating voltage should be within the tolerances given in Table PT-4 for the value of ITEST used.

NEGATIVE-SEQUENCE DISTANCE UNITS**A. NDD**

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 57, 58 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 26 on the test extender.

Choose test voltages to be applied to the relay according to the Zone 1 reach as set on the DPM11- module, Z1. Refer to Table PT-9.

TABLE PT-9: NDD Test Voltage/Current

<u>IN=5</u>	<u>Z1</u> <u>IN=1</u>	<u>VA</u>	<u>VB</u>	<u>VC</u>	<u>ITEST / -(90+θ)</u>
1-3	5-15	67/0	35/-163	35/163	$\frac{10.2}{Z1}$
3-12	15-60	67/0	47/-135	47/135	$\frac{33.1}{Z1}$
> 12	(> 60)	67/0	58/-125	58/125	$\frac{47.3}{Z1}$

Where θ is the ZR1 angle set on the AEM10- module.

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST, as shown in Table PT-9, with a tolerance given in Table PT-1 for the value of ITEST used.

B. NDD Zone 2 Reach

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 57 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 26 on the test extender.

The Zone 2 reach of the switched NDD is equal to the Zone 1 reach times the Zone 2 reach multiplier set on the DNM10- module. Choose test voltages to be applied to the relay according to the Zone 2 reach of NDD. Refer to Table PT-9, and substitute the NDDZ2 value for Z1 in the ITEST equation.

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST as shown in Table PT-10 with a tolerance given in Table PT-1 for the value of ITEST used.

$$\text{NDDZ2} = Z1 \times Z2 \text{ reach multiplier (on DNM10-)} \quad (15)$$

C. NDD Zone 3 Reach

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 58 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 26 on the test extender.

The Zone 3 reach of the switched NDD is equal to the Zone 1 reach times the Zone 3 reach multiplier set on the DNM10- module. Choose test voltages to be applied to the relay according to the Zone 3 reach of NDD. Refer to Table PT-9, and substitute the NDDZ3 value for Z1 in the ITEST equation.

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST as shown in Table PT-9 with a tolerance given in Table PT-1 for the value of ITEST used.

$$\text{NDDZ3} = \text{Z1} \times \text{Z3 reach multiplier (on DNM10-)} \quad (16)$$

D. ND

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 57, 58 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 25 on the test extender.

Choose test voltages to be applied to the relay according to the Zone 1 reach as set on the DPM11- module (PD1 reach). Refer to Table PT-10. The ND Bias is equal to the value set on the DNM10- module multiplied by 67 (to convert from per unit to applied volts).

TABLE PT-10: ND Test Voltage/Current

<u>IN=5A</u>	<u>Z1</u> <u>IN=1A</u>	<u>VA</u>	<u>VB</u>	<u>VC</u>	<u>ITEST / -(90+θ)</u>
1-3	5-15	67/0	35/-163	35/163	$\frac{14 + \text{ND BIAS}}{1.16 \times \text{Z1}}$
3-12	15-60	67/0	47/-135	47/135	$\frac{42 + \text{ND BIAS}}{1.16 \times \text{Z1}}$
> 12	(> 60)	67/0	58/-125	58/125	$\frac{58 + \text{ND BIAS}}{1.16 \times \text{Z1}}$

Where θ is the ZR1 angle set on the AEM10- module.

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST as shown in Table PT-10 with a tolerance given in Table PT-1 for the value of ITEST used.

E. ND Zone 2 Reach

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 57 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 25 on the test extender.

The Zone 2 reach of the switched ND is equal to the Zone 1 reach times the Zone 2 reach multiplier set on the DNM10- module. Choose test voltages to be applied to the relay according to the Zone 2 reach of the ND. Refer to Table PT-10, and substitute the NDZ2 value for Z1 in the ITEST equation. The ND Bias is equal to the value set on the DNM10- module multiplied by 67 (to convert from per unit to applied volts).

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST as shown in Table PT-10 with a tolerance given in Table PT-1 for the value of ITEST used.

$$NDZ2 = Z1 \times Z2 \text{ reach multiplier (on DNM 10-)} \quad (17)$$

F. ND Zone 3 Reach

Use the test connections shown in Figure AT-4. Connect temporary jumpers between pins 55, 56, 58 and 60 on a test card extender in the test card position. Connect the oscilloscope input to pin 25 on the test extender.

The Zone 3 reach of the switched ND is equal to the Zone 1 reach times the Zone 3 reach multiplier set on the DNM10- module. Choose test voltages to be applied to the relay according to the Zone 3 reach of the ND. Refer to Table PT-10, and substitute the NDZ3 value for Z1 in the ITEST equation. The ND Bias is equal to the value set on the DNM10- module multiplied by 67 (to convert from per unit to applied volts).

Slowly increase the applied test current until the oscilloscope trace steps from LOW to HIGH. This value of test current should be equal to ITEST as shown in Table PT-10 with a tolerance given in Table PT-1 for the value of ITEST used.

$$NDZ3 = Z1 \times Z3 \text{ reach multiplier (on DNM10-)} \quad (18)$$

NEGATIVE SEQUENCE DIRECTIONAL TESTS

1. NT Unit.

Add temporary jumpers to pins 55, 56 and 60 on the card extender. Change connections to those shown in Figure AT-5 with relay input Y connected to BH1 or TP9. Move the oscilloscope input to card extender pin No. 23. Set VA = 30 volts RMS, VB = 67 volts RMS, VC = 67 volts RMS. Set angle VB = -120° and angle VC = +120°. Set angle IA = -85°. Slowly increase IA until the oscilloscope trace goes from LOW to HIGH. At this pickup point, current IA should be less than 0.05 (0.01) amperes RMS.

Change angle IA to +95° and check that the oscilloscope trace does not go HIGH as IA is increased up to 10 (2) amperes RMS.

2. NB Unit.

Move the oscilloscope input to card extender pin No. 24. Reduce IA to 1.0 (0.2) amperes RMS and check that the oscilloscope trace is HIGH.

Change the angle IA to -85° and check that the oscilloscope trace is LOW.

PHASE SELECTORS

1. Move the oscilloscope input to card extender pin 27. Set IOP = 1.6 (0.32) amperes RMS and leave all other settings set per step 1 of NEGATIVE-SEQUENCE DIRECTIONAL TESTS. Check that the oscilloscope trace is HIGH.
2. Change connections to those shown for testing PHB SEL in Figure AT-5. Raise VA to 67 volts RMS, lower VB to 30 volts RMS and set angle IOP to -205°. Check that the oscilloscope trace at pin 28 is HIGH.

3. Change connections to those shown for testing PHC SEL in Figure AT-5. Raise VB to 67 volts RMS, lower VC to 30 volts RMS and set angle to -325° . Check that the oscilloscope trace at pin 29 is HIGH.

XTM TEST PLUGS

Description

The XTM test plugs are designed specifically for post-installation testing of the PLS system. There are two plugs; XTM28L1 (left-hand plug) and XTM28R1 (right-hand plug), each providing access to fourteen relay-side and fourteen system-side points. The system-side points are designated "S" and the relay-side points are designated "R". The plugs are keyed by the contact finger arrangement so that there may be no accidental interchange between the left-hand and right-hand plugs.

The plugs are fitted with a sliding handle that swings out to facilitate wiring to the terminals. The terminals consist of number 8 screws threaded into flat contact plates. The handles each have a tab on the outside edge to guide the wire dress of the test leads.

CAUTION

Not all the external connections to the PLS are wired through the test receptacle.

TERMINAL DESIGNATION

The test receptacle and connection plugs are located to the left of the magnetics module (extreme left-hand position). Their terminals are labeled 1 through 28, with 1 through 14 corresponding to the left-hand side and 15 through 28 corresponding to the right-hand side. These points are designated on the elementary diagram (Figure SD-4) as TP1 through TP28.

The left-hand test plug (XTM28L1) terminals are labeled 1R through 14R and 1S through 14S for the relay side and system side, respectively, with the system side labelled in red. Similarly, the right hand test plug (XTM28R1) terminals are labelled 15R through 28R and 15S through 28S.

XTM TEST CIRCUIT CONNECTIONS

Test circuit connections, designated as TP points in the elementary diagrams, should be made to the relay side of the test plug. Where it is desired to use available system quantities for testing, e.g., DC control power, jumpers may be inserted between the corresponding system side and relay side test plug terminals. Appropriate precautions should be taken when working with station battery DC.

Connections should be made to the test plugs prior to insertion into the PLS.

TEST PLUG INSERTION

To insert the test plugs, the two connection plugs must first be removed. In so doing, electrical continuity is broken between the power system and the PLS for those signals which are wired through the test receptacle (refer to TP points on elementary diagram, Figure SD-4). For the terminals connected to the current transformer secondaries, shorting bars are included on the system side of the test receptacle. These are clearly visible through the transparent plastic face plate on the receptacle. The shorting bars make contact before the connection plug contacts break during removal, so that the CT secondaries are never open-circuited.

Both test plugs may be inserted at the same time. Otherwise, if using only one test plug, the connection plug may remain in the other half of the receptacle.

When the test plugs are inserted into the receptacle, parts of the power system become isolated from the PLS. Refer to the PLS elementary diagram (Figure SD-4) for the TP points associated with each of the test plugs.

WARNING

IT IS CRITICAL THAT JUMPERS BE INSERTED ON THE SYSTEM-SIDE TEST PLUG TERMINALS WHICH ARE CONNECTED TO THE CT SECONDARIES AS SHOWN IN FIGURE SD-4. IF THESE JUMPERS ARE LEFT OUT, THE RESULTING HIGH VOLTAGES DEVELOPED PRESENT A SERIOUS HAZARD TO PERSONNEL AND MAY SEVERELY DAMAGE EQUIPMENT.

CARD EXTENDER

The card extender (GE #0138B7406G1) can be used to examine the input and output levels of each printed circuit module in the relay, as outlined below:

Remove power to the module by turning off the PSM21- module.

Remove the module from the relay.

Insert the card extender into the relay with the connector and test points facing the right hand side of the relay. Make sure the card extender is firmly seated in the relay connector.

Place the module on the card extender, and reapply relay power.

Use extreme caution when probing on modules. Damage to the module or operator may occur if the module or card extender are not handled properly.

The extender has 60 test points which are identified by numbers 1 through 60.

One method of removing power is to turn OFF the power switch on the PSM21- power supply module and then remove both of the connection plugs located in the TPM position on the left side of the case.

SERVICING

SPARES

There are two basic approaches that may be followed in servicing the PLS. One approach is field service, where an attempt is made to replace defective components at the relay location. Generally, this will take the most time and require the highest degree of skill and understanding. It can also be expected to result in the longest system-outage time.

The preferred approach is module replacement, where a determination is made as to which function has failed and that function is replaced with a spare module. The system can then be quickly returned to service. Considerable time is saved, and there is much less pressure to make a decision about what to do with the defective part. This approach typically yields the shortest down time. It is recommended that a complete set of spare modules be kept at the main maintenance center.

For those who wish to repair at the component level, drawings are available from the factory. When requesting drawings, the following information must be supplied to the factory:

1. The model number of the module. This is found on the lower part of the front nameplate of each module, e.g. ADM11-.
2. The assembly number of the module. This is found on the component side of the printed circuit board. It is an eight-digit number with a letter inserted between the fourth and fifth digit and suffixed with a group identification, e.g. 0215B5865 G001 or G1.
3. The revision number, this is also found on the printed circuit board, e.g. REV. 1.

WITHOUT THE CONTINUOUS MONITOR MODULE

By inserting an extender card into the test slot, location "B" (see figure MO-1 in the MODULES section), one can gain access to various points throughout the PLS. This feature is extremely useful when testing and servicing the PLS.

If the Continuous Monitor, which is an option that is also a useful device for testing and servicing the PLS, is not provided, a second extender card can be inserted into the slot reserved for it, location "D" (Figure MO-1 in the MODULES section). This gives access to additional points throughout the PLS.

The pin number on the extender card versus signal for the test points (TP-) that are shown in the Logic Diagram, Figure SD-2 (in the SCHEME DESCRIPTION section), is given in Table SE-1. The pin number on the extender card versus the monitor points (CM-), also shown in the Logic Diagram, is given in Table SE-2.

WITH THE CONTINUOUS MONITOR MODULE

When the PLS relay is equipped with the optional Continuous Monitor, many problems can be quickly located. When a failure occurs that causes one or more internal logic levels to shift, this will normally cause one of the many points monitored by the Continuous Monitor to go to an abnormal state. If the monitored point stays in this state for more than 0.5-1 second, the Continuous Monitor will give a Monitor Alarm contact closure. The front panel MON DATA indicator on the TAM101 module, Figure CM-6 in the CONTINUOUS MONITOR section, will also light.

There are two different methods by which the operator can determine which point or points failed. He can place the front panel DATA-SELECT switch in the MON DATA position and step through the display of abnormal points, using the STEP DISPLAY switch. The numbers of the abnormal points need to be recorded at this time.

The other alternative is to interrogate the Continuous Monitor through the serial data link. If monitor data is requested, the video terminal will display all the abnormal point numbers. The operator can leave these numbers on the screen to work from, or they can be copied from the screen and entered in the log.

These abnormal point numbers are the signal input numbers to the Continuous Monitor. Refer to Table SE-2 to find the mnemonic of the PLS signal connected to this input. Table SE-2 also gives the module where the signal originates. Refer to the system Logic Diagram, Figure SD-2 in the SCHEME DESCRIPTION section, and locate the abnormal signal levels on this diagram. Locate the earliest abnormal points, that is, the points closest to the AC inputs to the PLS. The problem is normally ahead of this point. Abnormal points that follow the first abnormal point in a signal path probably do not indicate a failure at these points. If there is an earlier, monitored, logic level in the same signal path that is normal, then the problem will usually be between the normal and the abnormal points.

If there is no earlier logic point, then the AC inputs to the PLS that drive the abnormal logic point should be checked. Refer to the Measuring Functions Block Diagram, Figure SE-1 in this section, and locate the abnormal signal levels on this diagram.

The techniques just described locate failures that resulted in monitor alarms from the Continuous Monitor. If a relay failure is suspected of causing a false trip, then the trip data in the Continuous Monitor must be analyzed. Obtain the trip data point numbers using the front panel controls: DATA SELECT, TRIP DATA, STEP DISPLAY and LCD display, or by using the serial data link. See if point 48 went to its abnormal state, HIGH. If not, the trip did not originate in the trip bus connected to the PLS. If point 48 went abnormal, see if point 47 went HIGH (abnormal state). If so, then there was a system disturbance and the trip probably was probably not a false trip. Check the event recorder, if used, and see if a trip condition did exist.

If there was no fault detector signal (point 47 did not go HIGH), then there was an error in the PLS. As in the case where a Monitor alarm light is lit, look for the earliest abnormal point in the signal path. Replace the module where this abnormal point is located. If the failure cannot be localized as occurring between a normal and abnormal monitored point, then it may be necessary to replace all modules between the abnormal point and the AC inputs that supply signals to the abnormal point.

POWER SUPPLY MODULE

Check the following items if the LED found on the front panel of the PSM21- module (Figure MO-13) fails to light when the Power Supply is turned on:

1. The correct DC supply is applied to the PLS.
2. The connection plugs, located on the left side of the MGM module (see Figure MO-1), are properly inserted into the test receptacle.
3. The condition of the fuse located on the PSM21- module, (Figure MO-13).

4. Check for the correct voltages from the Power Supply Module:

The voltages should be within $\pm 5\%$ of nominal. Check each of the following voltages with respect to pins 1, 30, 31 or 60:

Pins 4 or 34	+24 VDC
Pins 2 or 32	+12 VDC
Pins 29 or 59	-12 VDC

The following voltage is checked with respect to pins 25, 55 or 56, and it should also be within $\pm 5\%$ of nominal:

Pins 21 or 51	+24 VDC
---------------	---------

Table SE-1: PLS TEST POINT TABLE

PIN NUMBER	SIGNAL (LOGIC) NAME	MODULE	LOGIC DIAGRAM LOCATION
1	GROUND		
2	FD	AEM11-	2F2
3	IMA	AEM10-	1F9
4	IMB	AEM10-	1F10
5	IMC	AEM10-	1F10
6	NVA	AEM10-	1F9
7	NVB	AEM10-	1F10
8	NVC	AEM10-	1F10
9	FDP (OR38)	ULM161	2D1
10	I0	AEM11-	2F6
11	I1S	AEM11-	
12	I1T	AEM11-	1F9
13	IB	ADM10-	1F6
14	IT	ADM10-	1F3
15	IDT	DPM11-	1E5
16	ITOC	DPM11-	1F4
17	PD1	DPM10-	1F4
18	PD1D	DPM11-	
19	PDX	AEM10-	1F2
20	PDT	DPM10-	1E2
21	PDB	DPM10-	1F6
22	POSB	DPM10-	1F1
23	NT	ADM10-	1F3
24	NB	ADM10-	1G6
25	ND	DNM10-	1F5
26	NDD	DNM10-	1F3
27	φA SELECTOR	ULM15-	2F7
28	φB SELECTOR	ULM15-	2F7
29	φC SELECTOR	ULM15-	2F8
30	KEY 3 (not used)	ULM15-	2F8
31	φA TRIP (AND 21)	ULM15-	2F9
32	φB TRIP (AND 22)	ULM15-	2F9
33	φC TRIP (AND 23)	ULM15-	2F10
34	ANY TRIP (OR27A)	ULM171	2E10
35	3P TRIP PERM(OR20A)	ULM181	1C8
36	TL7	ULM181	2D10
37	TRIP PERM (OR16)	ULM19-	1B3
38	POSB	DPM11-	
39	PERM KEYING(OR18)	ULM19-	1B4
40	KEY TRANS 1(OR28)	ULM15-	2A4
41	KEY TRANS 2(OR29)	ULM15-	2B5
42	RCVR (OR12)	ULM15-	2E4
43	LOCAL TRIP (OR10)	ULM19-	1D3
44	DIRECT TRIP(OR214)	ULM19-	1C5
45	CHANNEL TRIP(AND16)	ULM19-	1C3
46	BLOCK ZONE (OR37)	ULM19-	1D6
47	MOB (TL6)	ULM19-	1D1
48	ANY POLE OPEN(OR32)	ULM181	1D10
49	LINE PICKUP (OR42)	ULM181	1B10
50	WEAK INFEEED (TL16)	ULM19-	1B4
51	ND Z2	ULM161	2D3
52	ZONE 2 TIMER (TL2)	ULM19-	1C2
53	ZONE 3 (AND6)	ULM19-	1C2
54	TOC PU	DPM11-	
55	Test1	ULM161	
56	Test2	ULM161	
57	Test3	ULM161	
58	Test4	ULM161	
59	Test5	ADM10-	
60	+12	PSM21-	

Table SE-2: PLS CONTINUOUS MONITOR POINT TABLE

MONITOR POINT	SIGNAL	SOURCE	LOGIC DIA. LOCATION	SOCKET (H) PIN NO.
4	NAND98	ULM161	2D3	43
5	PDX	AEM10-	1F2	14
6	PDT	DPM10-	1F2	44
7	PD1	DPM11-	1F4	15
8	PD1D	DPM11-		45
9	ND	DNM103	1F5	37
10	NDD	DNM103	1F3	7
11	IT	ADM101	1F3	36
12	NT	ADM101	1F3	6
13	IDT	DPM11-	1F5	35
14	ITOC	DPM11-	1F4	5
17	PDB	DPM101	1G6	39
18	REMOVE ϕ SEL (OR100)	ULM19-	1E6	9
19	POSB	DPM10-	1F1	38
20	ϕ A SELECTOR	DSM20-	2G7	8
21	ϕ B SELECTOR	DSM20-	2G7	10
22	ϕ C SELECTOR	DSM201	2G8	40
23	IB	ADM101	1G6	11
24	3I0	AEM10-	2F6	41
25	TRIP PERM (OR16)	ULM19-	1B3	24
26	CHANNEL TRIP (AND16)	ULM19-	1C3	54
27	DIRECT TRIP (OR214)	ULM19-	1C5	25
28	WEAK INFEEED (TL16)	ULM19-	1C4	55
29	LINE PICKUP (OR42)	ULM181	1B10	26
30	ZONE II TIMER (TL2)	ULM19-	1C2	56
31	ZONE III TIMER (TL3)	ULM19-	1C2	27
32	RPI (OR12)	ULM15-	2E4	57
33	EXTERNAL TRIP (OR19)	ULM181	1F7	49
34	BLOCK ZONE (OR37)	ULM19-	2D6	19
35	MOB (TL6)	ULM19-	2D1	48
36	ANY POLE OPEN (OR32)	ULM181	1D10	18
37	KEY1	ULM15-	2B4	47
38	KEY2	ULM15-	2B5	17
39	ϕ A TRIP (AND21)	ULM15-	2F9	46
40	ϕ B TRIP (AND22)	ULM15-	2F9	16
41	ϕ C TRIP (AND23)	ULM15-	2F10	51
42	PTFF (OR49)	ULM171	2B11	21
43	KEY DTT	ULM15-	2B4	50
44	LR (OR62)	ULM171	2B10	20
45	3P TRIP (OR20A)	ULM181	1D8	22
46	IR (OR59)	ULM171	2B11	52
47	FDP (OR38)	ULM161	2E2	23
48	ANY TRIP (OR27)	ULM171	2E10	53

NOTE: Points 1-14 and 17-44 are scanned in the Monitor and TRIP mode.

Points 45-48 are scanned in the TRIP mode only.




Figure SE-1 (0179C7657 Sh.1[2]) PLS Analog Block Diagram
Current and Voltage Processing



SE-7A





Figure SE-3 (0179C7657 Sh.3[4]) PLS Analog Block Diagram
Positive Sequence Units and IDT, ITOC



SE-9A



SPECIFICATIONS

RATINGS

Rated Frequency	50 or 60 hertz
Rated Voltage	100 to 120 volts AC
Rated Current	$I_N = 1$ or 5 amperes
DC Control Voltage	48 VDC - Operating Range: 34- 60 VDC 110/125 - Operating Range: 88-150 VDC 220/250 - Operating Range: 176-300 VDC
Maximum Permissible Currents	
Continuous	$2 \times I_N$
Three Seconds	$50 \times I_N$
One Second	$100 \times I_N$
Maximum Permissible AC Voltage	
Continuous	2.0 x rated
One Minute (one per hour)	3.5 x rated
Ambient Temperature Range	
For Storage	-40° to +65° C
For Operation	The PLS has been designed for continuous operation between -20° C and +55° C per ANSI Standard C37.90. In addition, the PLS will not malfunction nor be damaged by operation at temperatures up to +65° C.
Insulation Test Voltage	2 kV 50/60 hertz, one minute
Impulse Voltage Withstand	5 kV peak, 1.2/50 milliseconds, 0.5 joule
Interference Test Withstand	ANSI/IEEE C37.90 and IEC 255-5

BURDENS

Current Circuits	0.03 ohm / 5°, I _N = 5 amps 0.14 ohm / 30°, I _N = 1 amp	
Voltage Circuits	0.2 VA / 49°, 60 hertz 0.24 VA / 48°, 50 hertz	
DC Battery (for contact converters)	1.4 milliamperes each	
DC Battery (for Power Supply and Telephone Relays)	<u>Normal</u>	<u>Tripped</u>
ALL VOLTAGE RATINGS	15 watts	40 watts

CONTACT DATA**Trip Outputs**

Continuous rating = 3 amperes
 Make and carry for tripping duty: (per ANSI C37.90) 30 amps
 Break 180 VA resistive at 125/250 VDC
 Break 60 VA inductive at 125/250 VDC

**Auxiliary Outputs
(including Alarms)**

Continuous rating = 3 amperes
 Make and carry for 30 seconds: 5 amperes
 Break 25 watts inductive at 125/250 VDC
 Make and Carry continuously: 50 watts
 Maximum of 250 volts or 0.5 amp

**DLA and Channel
Control Contacts**

10 watts
 250 VDC maximum
 0.5 amp maximum

TABLE SP-1: REACH SETTINGS OF DISTANCE UNITS

FUNCTION	MEASURING UNIT	MODULE	REACH SETTINGS IN OHMS			
			$I_N=5$	RANGE $I_N=1$	RESOLUTION $I_N=5$	$I_N=1$
ZONE 1	PD1/ND	DPM11-	1 to 25	5 to 125	0.1	0.5
PERMISSIVE ZONE	PDT	DPM10-	2 to 50	10 to 250	0.2	1.0

The reach of the following measuring units is set as multiples of the Zone 1 (PD1) reach or permissive zone (PDT) reach:

Table SP-2: REACH MULTIPLES OF PD1 AND PDT

FUNCTION	MEASURING UNIT	MODULE	REACH IN MULTIPLES OF PD1 or PDT	
			RANGE	RESOLUTION
*ZONE 2 - NEGATIVE SEQ.	N2	DNM10-	1 TO 2.5 X PD1	0.1
*ZONE 3 - NEGATIVE SEQ.	N3	DNM10-	1 TO 4.75 X PD1	0.25
*ZONE 2 - POSITIVE SEQ.	PDX	AEM10-	1 TO 2.5 X PD1	0.1
BLOCKING	PDB	DPM10-	0.5 TO 2.25 X PDT	0.25
OUT OF STEP BLOCKING	POSB	DPM10-	1 TO 2.5 X PDT	0.1

* = Switched Distance Functions

REPLICA IMPEDANCE ANGLE SETTINGS

The replica impedance angle of the distance measuring units is adjustable from 70° to 85° in 5° steps with a board-mounted switch on the AEM11- module.

TABLE SP-3: ADJUSTABLE LOGIC TIMERS

TIMER	MODULE	PU/DO	RANGE	RESOLUTION	DESCRIPTION
TL1	ULM19-	PU	0 - 15.5 ms	0.5 ms	TRIP INTEGRATOR
TL2**	ULM19-	PU	0 - 3.1 sec*	0.1 sec	ZONE TWO
TL3**	ULM19-	PU	0 - 3.1 sec*	0.1 sec	ZONE THREE
TL9	ULM19-	PU	0 - 15 ms	1 ms	REPEAT BLOCK
TL13	ULM15-	PU	0 - 15 ms	1 ms	DTT
TL16**	ULM19-	PU	0 - 75 ms*	5 ms	WEAK INFEED
TL22	ULM15-	PU	0 - 3.1 sec	0.1 sec	DTT RECLOSE BLOCK
TL24	ULM19-	DO	10-120 ms	10 ms	NB DROPOUT
TL25	ULM19-	DO	10-120 ms	10 ms	MB DROPOUT
TL26	ULM171	PU	0 - 77.5 ms	2.5 ms	ANY TRIP BUS

* Can be defeated by setting to OUT

** Located on the front panel

ACCURACY

Distance Measuring Units

Reach: $\pm 5\%$ of setting at angle of maximum reach and rated current

Angle of Maximum Reach: $\pm 3^\circ$ of setting

Zone Timers

$\pm 3\%$ of setting

DIMENSIONS

Standard rack-mounted unit:

13-15/16 inches (354 millimeters) high
 19-1/16 inches (484 millimeters) wide
 (standard 19-inch rack)
 14 inches (356 millimeters) deep
 (including terminal blocks)

WEIGHT

Standard rack-mounted unit weighs approximately 42 pounds (19 kilograms) net.

CONTINUOUS MONITOR

BASIC OPERATION

The continuous monitor function works on the principle of recognizing a change in state of one or more of up to 40 monitored points (reference Table SE-2 in the **SERVICING** section) as an abnormal relay system condition if this change in state occurs when the power system is in a quiescent state. This means that the process must know the state of the power system at all times (i.e., quiescent or fault). A fault detector (FD) is used to determine the state of the power system. This same fault detector may also be used to supervise a trip output from the relay system's scheme logic, even if the optional Continuous Monitor module is not included. The fault detector responds to negative-sequence current as well as the change in the positive-sequence current.

A microprocessor, software stored in an EPROM, and other required support chips are the hardware/software that comprise the Continuous Monitor module. The module operation can be described functionally with the aid of Figure CM-1. If one or more of the monitored points changes state (either logic level 0 to 1 or logic level 1 to 0), the fault detector has not operated, and this condition persists for a minimum of 5 seconds, then the Continuous Monitor module issues an alarm output to indicate that an abnormal condition - a relay system failure - has occurred. Based on the actual software and hardware implementation, the "A" time delay in Figure CM-1 is not a fixed value, but rather a statistically variable 5 seconds minimum and 10 seconds maximum. An alarm output is also produced if a fault detector output persists for 60 seconds. This would be an indication that the fault detector itself had failed.

No monitor data will be taken after a bad fault detector is sensed. To alert the user, the program displays "Fd" on the front panel LED numeric display after it senses a bad fault detector. It is still possible to use the STEP DISP. pushbutton to step through the trip and monitor data already stored. If this is done, the "Fd" does not reappear on the display. For this reason, the LED labeled MON. DATA on the front panel is made to blink continuously after a fault-detector failure. This alerts the operator to the fact the unit is not operating normally.

Once OR1 in Figure CM-1 produces an output, indicating a relay system failure, the microprocessor program stores bit patterns in non-volatile memory that identify which monitored point(s) changed state. These "faulty" monitored points are not stored in chronological order, nor time-tagged, but are simply accumulated in memory. Repeated operation and reset of a particular monitored point does not result in this point being stored more than once. This accumulation of "faulty" monitored points continues until the memory is cleared. Since non-volatile memory is used, the data is not lost if the DC power supply is turned off or the DC is removed externally. To clear the memory, a CLEAR command must be given by either (1) the operator pushing a button on the front panel of the module or (2) a remote terminal communicating with the module via a serial data link. When the first relay-system failure is detected, the Continuous Monitor module closes an alarm contact that remains closed until the memory is cleared.

ADDITIONAL FUNCTION

The primary function of the Continuous Monitor module is to detect and to alarm for a relay-system failure. The other function is to store in non-volatile memory those monitored points that have changed state during a relay-system trip output. Following a trip output, the Continuous Monitor module scans the monitored points for 10 milliseconds. Any points that change state within this 10 millisecond interval are accumulated in memory as trip data. This can be useful in analyzing relay-system response to particular faults. This function and its memory are separate and distinct from

the primary function of detecting relay-system failures. The Continuous Monitor module can have both "trip data" and "monitor data" in memory at the same time.

Data for five (5) trip events will be stored sequentially. If a sixth trip event occurs prior to the memory being cleared, then the data for the first trip event will be overwritten by the data for the sixth trip event. Thus the data for the five most recent trip events will be retained.

The front panel LED numeric display shows "Fb" when the trip input to the Continuous Monitor is HIGH. This was done to make the unit easier to test. Without this feature, it is difficult to avoid the appearance of Continuous Monitor failure when the trip input is accidentally held HIGH. This makes it difficult to diagnose the real condition.

ACCESS OF STORED DATA

The bottom of Figure CM-5 shows the front panel of the Continuous Monitor module with its LEDs, two-digit LED numeric display, toggle switch and pushbuttons. The stored data, either monitor or trip, can be accessed locally at the front panel of the module, or it can be accessed from a remote terminal via an optional serial data link.

Local Access

For local access, the two LEDs on the front panel of the module indicate that monitor data and/or trip data are stored in memory. A DATA SELECT toggle switch is used to select which data are to be accessed. The step display (STEP DISP.) pushbutton is then pushed repeatedly to cause the stored points to be displayed via the two-digit point number (POINT NO.) LED numeric display.

After the DATA SELECT switch is set to the monitor data (MON DATA) position, the LED numeric display should show 0/0 (i.e., the upper and lower display digits are both zero) to indicate the beginning of the monitor data. If 0/0 is not displayed, the STEP DISP. pushbutton should be pushed to bring the display to 0/0. The next push of the STEP DISP. pushbutton will cause the first stored monitor point to be displayed and this process is continued until 0/0 reappears on the LED numeric display to signal the end of the monitor data.

After the DATA SELECT switch is set to the TRIP DATA position, a 0/0 on the LED numeric display indicates the beginning of the trip data. Once again, successive operations of the STEP DISP. pushbutton cause all the trip data to be displayed between the initial 0/0 and the subsequent 0/0. However, additional codes, E/1, E/2 through E/5 are displayed to differentiate between the trip events. E/1 refers to the last trip event, E/2 to the next-to-last trip event, and E/5 to the earliest stored trip event, assuming five trip events are stored in memory. When starting from 0/0, the first push of the STEP DISP. pushbutton will cause E/1 to appear on the LED numeric display. Successive operations of the STEP DISP. pushbutton will cause all trip data points associated with the last trip event to be displayed, followed by E/2 to indicate the beginning of the trip data points associated with the next-to-last trip event. This continues until 0/0 is displayed to indicate the end of the trip data.

Remote Access

For remote access, a serial data link must be supplied. The Continuous Monitor module includes the necessary software to operate with a serial data link and the chassis backplane wiring connects the input/output ports to a 25-pin connector on the rear of the chassis. To provide serial data transmission, an optional, small, fiber-optic transmitter/receiver module (FOM101) can be supplied, or the more economical MIM101 module for direct RS-232 communication is available.

The FOM101 consists of standard Hewlett-Packard devices using SMA connectors and packaged by GE into a connector housing. This device is simply plugged into the 25-pin connector on the rear of the chassis. One means of completing the serial data link is to connect one end of a fiber-optic cable to the small fiber-optic transmitter/receiver module on the rear of the relay chassis and the other end to a commercially available fiber-optic-to-RS-232 converter. The RS-232 side of the converter can then be connected to a modem to provide remote access via telephone lines, as shown in Figure CM-2. Either a "dumb" or a "smart" terminal may be used at the remote site, since no terminal software is required.

The MIM101 module was designed as a relay-powered stand-alone RS-232 interface for Mod-10 relays containing the continuous monitor module, TAM101. It contains an optically isolated transmitter and receiver pair for electrical and galvanic isolation. The communications port contained on the MOD-10 units is a direct-coupled non-standard RS-232 port. Since no isolation is contained within the MOD-10 unit, and the output is of a non-standard type, the MIM101 is necessary for communication via personal computer or dumb terminal. Connection is made to the DB25 connector at the rear of the relay and to any standard DB25 RS-232 cable. The MIM101 was designed to replace the externally powered fiber-optic-to-RS-232 converter previously used for data communication. The MIM 101 can be used on the DLS, PLS1, TLS1, and TYS3 relays.

The serial data link option provides the user with the capability of remotely interrogating the Continuous Monitor module to read the data in memory and to clear the memory. Clearing the memory also clears the alarm contact. In the examples below, the full-duplex system as shown in Figure CM-2 is assumed, and the entries by the operator at the terminal are shown in parentheses. Carriage returns are not indicated, but every entry **must** be followed by a carriage return. Entries must be exactly as shown; extra spaces or added punctuation may cause the message to be ignored.

The first step in obtaining data remotely is to address the particular Continuous Monitor module by its identifying number (up to 16 unit-identification numbers can be assigned via an on-board switch setting on the module). This module or unit-number designation allows several modules at one substation to be addressed via one serial data link. Assume that unit 2 is to be addressed. Enter the following at the keyboard:

(**2)

The Continuous Monitor module will respond with one of the following messages:

***2 N	No data in memory
***2 M	Monitor data only in memory
***2 T	Trip data only in memory
***2 M T	Monitor and trip data in memory

Assume that "***2 M T" is received, indicating the presence of both monitor and trip data.

To access the monitor data, enter the following at the keyboard:

(MON)

Assume the response is:

***2 MON
03 09 31

In this case, points 3, 9 and 31 are stored in memory.

To access the trip data, enter the following at the keyboard:

(TRIP)

Assume the response is:

```
***2 TRIP
06 20 21 22 25 37

06 20 21 22 25 37
```

The first line of data is for the most recent trip, while the last line is for the earliest trip in memory. In this example data are shown for two trip events, but up to 5 events could be present.

If a different Continuous Monitor module served by the same link is to be accessed at this time, it will be necessary to deselect the present module by issuing a QUIT command, and then to address the next module. To quit a module, enter the following at the keyboard:

(QUIT)

The QUIT command does not erase the memory of the currently addressed module. It does deselect and return to normal mode any unit receiving the command, whether selected or not.

Clearing the Stored Data

The data can be cleared from memory either locally, via the module's front panel, or remotely, via the serial data link. Local clearing is accomplished by pushing the CLEAR DATA button located on the front of the module. The LED numeric display will show C/C until clearing is complete. Remote clearing of the selected unit is accomplished via the serial data link by entering the following command at the keyboard:

(CLEAR)

The CLEAR command, whether issued locally or remotely, clears both monitor and trip data from memory, and it resets the two contacts associated with the monitor alarm. When issued remotely, the CLEAR command also deselects the present module. If there is only one Continuous Monitor on a communications link, then either QUIT or CLEAR can be used as the final command after interrogation.

If there are multiple Continuous Monitor modules, then QUIT should be used, since it will return all the units on the communication line to the normal state. QUIT will not clear the memory, whereas CLEAR will. If the memory is to be cleared in such cases, CLEAR should be sent to each module, then one QUIT command to return all to the normal state. The monitor alarm contacts close when monitor data is stored in memory, and stay closed until a CLEAR command is issued.

MODES OF OPERATION

The Continuous Monitor module can be thought of as having three modes of operation: (1) monitor mode, (2) local-display mode, and (3) serial-data-link-access mode. Note that regardless of which mode the monitor is in, a relay-system trip will interrupt the program and trip data will be stored. The module is then returned to the monitor mode. Normally the module is in the monitor mode with no local-display-mode bits set. In this condition the module's front panel LED numeric display will show 0/0.

Local-Display Mode

To enter the local-display mode the operator places the DATA SELECT switch at either the MON DATA or the TRIP DATA position and pushes the STEP DISP. pushbutton. If there has been no trip since the last pass through the program, the program looks at the status (local- display mode) word to see if a display bit is set. There are two local-display-mode bits. One indicates that monitor data is to be displayed on the front panel LED numeric display. The other bit signifies that trip data is to be displayed. Only one of the two bits can be on at one time, and the presence of either bit will prevent use of the serial data link. To exit the local-display mode and return to the monitor mode, the operator changes the position of the DATA SELECT switch and pushes the STEP DISP. pushbutton once so that the LED numeric display shows 0/0. Pushing the CLEAR button will also return the module to the monitor mode but will erase the data. After a 5 minute delay, initiated when the local display mode is first entered, the module will automatically revert to the monitor mode. If an operator happens to leave the module in the local display mode, this automates reversion will prevent the loss of all but the first five minutes

of data. While in the local-display mode, the module continues its monitoring, as in the monitor mode, except on those program passes when it sees the STEP DISP. pushbutton operated or when a trip has just occurred.

Serial-Data-Link-Access Mode

When in the serial-data-link-access mode the module does not continue the monitoring it performs in the monitor mode; however, it will record the trip data, then leave the serial-data-access mode. While the Continuous Monitor module is sending or receiving data, local access via the module's front panel is also denied.

Assuming that there is only one Continuous Monitor module that can be addressed by the remote terminal, the normal way to terminate this mode and return to the monitor mode is to issue a CLEAR or QUIT command. If neither command is received, after a 5 minute delay, initiated when the serial-data-link-access mode is first entered, the module will automatically revert to the monitor mode, preventing the loss of all but the first five minutes data.

When addressing several Continuous Monitor modules via one serial data link, all the modules will go to the serial-data-link-access mode when a signal is received over the link. In this case, QUIT will not only deselect the presently addressed module, but also act as a "site global" command, since all of the Continuous Monitor modules will return to the monitor mode. CLEAR will deselect the presently addressed module and clear its memory, but it will not cause all the modules to revert to the monitor mode. If the terminal operator forgets to issue a QUIT command, each module will automatically revert to the monitor mode following expiration of its individual 5 minute delay.

CONTINUOUS MONITOR ADJUSTMENTS

The only adjustment on this board is the address-setting switch. The location of this switch and the bit values of the individual switches are shown in Figure CM-5. The setting is the sum of the switch values. The setting can range from 0 to 15. Values from 10 to 15 correspond to addresses from Capital A to Capital F. This address is used to select a particular Continuous Monitor using the serial data link.

CM

The front panel controls are as follows:

<u>Panel Marking Description</u>	
Point Number	Two-digit LED to display abnormal point input number. Top digit is the most significant.
Step Disp.	Pushbutton to step Point Number to next point (in numerical order).
Trip Data	LED that indicates, when lit, that trip data has been stored.
Mon. Data	LED that indicates, when lit, that monitor data has been stored.
Data Select	Two-position switch to select either trip or monitor data on Point Number display.
Clear Data	Recessed pushbutton that clears all memory data when operated.

CONTINUOUS MONITOR SERIAL LINK USE

The continuous monitor serial data link has the following characteristics:

Baud rate	300
Data bits	7
Parity	odd
Stop bits	1

When shipped, the PLS relay system chassis containing the Continuous Monitor is always wired to operate with the serial data link. To provide serial data transmission, a small fiber-optic transmitter/ receiver module can be installed on the 25-pin connector on the rear of the chassis. This connector resembles an RS-232 connector, but it is **not** RS-232 compatible. This fiber-optic transmitter/receiver module (FOM101) is made by GE and contains only the optical transmitter and receiver to couple to and from the fiber-optic cables. The optical transmitter and receiver are standard Hewlett-Packard devices, HFBR1402 and HFBR2402, which use SMA connectors. The other end of the fiber-optic cables (HFBR-3000 or equivalent) can be coupled to any suitable optical devices. Under normal conditions (no transmission) the fiber-optic transmitter at the chassis is OFF. The receiver at the chassis expects a similar "OFF" signal.

The simplest means of using the fiber-optic link is to purchase commercially available fiber-optic-to-RS-232 converters and related communications equipment. Figures CM-3 and CM-4 show two communication schemes that have been implemented.

CHECKSUM

There is a checksum routine that continually checks for EPROM memory errors. If it detects a failure, the front-panel display will reach "C5". The monitor alarm will operate and monitor bit 16 will be set. If this occurs, the Continuous Monitor module should be replaced.




Figure CM-1 (0285A9897) Simplified Functional Diagram Depicting Continuous Monitor Operation




Figure CM-2 (0285A9899 [3]) Serial Data Link Connection




Figure CM-3 (0285A9836 [1]) Continuous Monitor Phone Connection




Figure CM-4 (0285A9837 [1]) Connection for Multiple Continuous Monitors




Figure CM-5 (0286A5379) MIM Module connection




Figure CM-6 (0285A9831 [3]) Front Panel & Internal Switches, TAM101

SOFTWARE

The following programs are provided on a 3.5 inch disk. A 5.25 inch disk will be supplied upon request.

SET PLS: A guide to calculating the settings for the PLS
CONTMON: Communications Software for the Continuous Monitor.

Running the programs

SET PLS

An MS-DOS-compatible computer is required to run the program. The computer must be booted up before the program can be run. To run the program, insert the disk in the drive to be used and then type the following:

```
a:
cd\setpls
Then type MEFIRST <ENTER> to run the settings program. Follow the directions on the
screen to input your data. Refer to the Readme text file on the disk, and the
CALCULATION OF SETTINGS section of this instruction book for complete information on
setting the relay.
```

CONTMON

To run the Continuous Monitor communications program, insert the disk and enter the following commands at the c:prompt:

```
a:
cd\contmon
Then type CONTMON <ENTER> to run the Continuous Monitor program. Refer to the
CONTINUOUS MONITOR section of this instruction book and the Readme file stored on
the disk for complete information on operating the Continuous Monitor.
```

Where:

a: = drive where program disk is inserted

These programs may also be copied to your hard drive by using the DOS xcopy or copy command. It is recommended that they be stored in separate directories on the hard drive.

Note: A: and c: drive names are for reference only.



GE Power Management

215 Anderson Avenue
Markham, Ontario
Canada L6E 1B3
Tel: (905) 294-6222
Fax: (905) 201-2098
www.ge.com/indsys/pm