



469 Oscillography Power Cycle Measurements

GE Power Management No. GET-8417

Copyright © 2002 GE Power Management

In early versions of the 469PC software, the oscillography feature measures a 50 Hz powercycle time as 16.67 ms.

This problem has been corrected for versions 2.8 and higher of 469PC. However, the 469 system frequency setting dictates the power cycle time and must be set to the actual system frequency.