



GE VERNOVA

869 Advanced Motor Control – A Comprehensive Control Solution for Motor Applications


8 Series Mini Paper

Copyright 2014, General Electric Company. All rights reserved.



Breaker/Contactor control


The 869 protection relay can control and monitor two types of motor switching devices: breakers and contactors. The selection is straightforward, and the wiring similar to the SR469. The settings are shown below:



Front panel/remote control

The 869 provides operator control of the motor from the front panel via several pushbuttons or by executing SCADA commands from the remote location. This is a significant improvement compared to the 469 relay where these control features were not available.


There are three pushbuttons with associated status LEDs on the relay faceplate. All three pushbuttons and all three LEDs are programmable. The labels in shown in Figure below match the default assignment.



Start Supervision Inhibit


Start Supervision consists of four elements that guard against excessive starts. They are: Thermal Start Inhibit, Maximum Starting Rate, Time between Starts, and Restart Delay. All Start Supervision elements operate Output relay 3 (Start Inhibit).

- **Thermal Start Inhibit.** Inhibits starting if there is insufficient thermal capacity remaining
- **Maximum Starting Rate.** The number of start attempts allowed in a time interval.
- **Time Between Starts.** Enforces a minimum time duration between two start attempts.
- **Restart Delay.** Ensures a specific time passes from the motor stopping and being restarted.



Emergency restart

This function overrides all four Start Supervision Inhibit elements and when activated, provides an emergency start of the motor. It must only be used in an emergency when the process is more important than protecting the motor. The feature is assignable to any contact input or any operand as shown in Figure below.



Output Relays Operation Type and Flexibility

Either Failsafe or Non-Failsafe Operation Type can be assigned to any 869 output relay except the Critical Failure Relay. Failsafe operation causes the output relay to be energized when the operand assigned to operate that relay is low and de-energized when the same operand is high.

A failsafe relay also changes state (if not already activated by an operand driving this output relay) when control power is removed from the 869. Conversely a non-failsafe relay is de-energized in its normal non-activated state and will not change state when control power is removed from the 869 (if not already activated by a protection element).

The list includes Output Relay 1 (Trip) and Output Relay 2 (Aux/Close). The Operation Type selection is simple and it is shown in Figure below. The default selection for the Breaker application is “Non-Failsafe” and the default selection for the Contactor application is “Failsafe”. This is a significant improvement compared to older motor relays where all output relays except the Critical Failure Relay have a fixed Non-Failsafe functionality.

SETTING	PARAMETER
Trip	
Name	Trip
Block	Off
Type	Latched
Operation	Non-Failsafe
Events	Non-Failsafe
	Failsafe
Aux Relay 2	
Name	Aux Relay 2
Operate	Off
Seal-In Time	0.100 s
Type	Pulsed
Operation	Non-Failsafe
Events	Enabled

Additionally output relays can be selected either Pulsed or Latched and be sealed-in for a user-definable time.



GE VERNOVA

GE Vernova

650 Markland Street

Markham, Ontario

Canada L6C 0M1

Worldwide telephone: +1 905 927 7070

Europe/Middle East/Africa telephone: +34 94 485 88 54

North America toll-free: 1 800 547 8629

Fax: +1 905 927 5098

Worldwide e-mail: GA.support@gevernova.com

Website: <https://www.gevernova.com/grid-solutions/multilin/>