

## UR Family

# UR Relays Percent Differential Element Testing

## Application Note

GE Publication Number: GET-20105A

Copyright © 2022 GE Multilin

This document outlines testing of the UR relays Percent Differential element and results. Although content below is shown for the B90 relay for illustration purposes, it's fully applicable to all UR platform percent differential relays, B30, B90, G30, G60, M60, T35 and T60 having the same algorithm.

---

## Introduction

The B90 Low Impedance Bus Differential System is part of the GE Universal Relay (UR) product family.


The B90 provides protection and metering for busbars with up to 24 feeders. It provides multi-zone differential protection with both restrained (percent, biased) and unrestrained (unbiased, instantaneous) functions incorporated, together with the phase comparison operating principle. Low and high breakpoints are connected together with a cubic spline function to provide a smooth transition between slope 1 and slope 2. If testing of points along this region is required, use the 87T Characteristics.xlsx spreadsheet.



87T

Characteristics.xlsx

Figure 1: Biased operating characteristics



The differential signal is composed of the sum of individual feeder currents.


$$I_{DIF} = |I_1 + I_2 + \dots + I_n|$$

The restraint quantity is chosen to be the maximum of the individual feeder currents.

$$I_{RES} = \max(|I_1|, |I_2|, \dots, |I_n|)$$

The biased operation has two FlexLogic operands, BUS 1 BIASED PKP and BUS 1 BIASED OP. The pickup (PKP) operand responds to the characteristic shape. The operate (OP) operand responds to the characteristic shape AND the directional principle or the characteristic shape and NO saturation detected.

Figure 2: Biased pickup and operate



The differential and restraint quantities can be plotted on the biased operating characteristic curve. Since the relay also uses the directional principle, the biased trip may not occur when the two points intercept the curve. To test the curve, assign the FlexLogic BUS 1 BIASED PKP operand to an output that is used for sense on the test set.

The directional principle responds to the relative direction of the fault currents; therefore, no reference signal is required. The directional principle declares that

- If at least one fault current flows in the same direction, compared with the sum of the remaining

currents, the fault is internal, or

- If at least one fault current flows in an opposite direction compared with the sum of the remaining currents, the fault is external


The current is determined to be a fault current if the magnitude is greater than an adaptable threshold based on the restraint current and the number of feeders in the bus. The current is considered if its magnitude is greater than  $K * I_{rest}$  or 2 times the CT rating. For bus zones with two feeders  $K = 0.2$ , for bus zones with three to six feeders  $K = 0.8 / (N - 1)$ . For bus zones with more than six feeders  $K = 0.16$ . This is important when testing the directional principle supervision.

---

## Setup


The example in this document tests a B90 with six zones each with a 2000:5 CT on each CT input. The following settings are used.

Figure 3: Bus differential settings




The **View** button (shown in red outline) at the top of the settings opens a live view of the element.

Figure 4: Bus differential characteristic view




Zoom into regions of the graph by clicking and holding the left mouse button on the graph and expanding the window.

Figure 5: Zoomed-in bus differential characteristic view



Set the trip output or spare output wired to test set sense to BUS 1 BIASED PKP to test the shape of the dual slope characteristic.

Figure 6: Output contact setting pickup



**NOTICE**

The current inputs have a continuous rating of  $4 \times I_{nom}$ . Do not exceed  $4 \times I_{nom}$  current continuously during testing, else damage to the relay occurs.

The characteristic accuracy is  $\pm 3\%$  of the maximum circuit current or  $\pm 2\%$  of rated, whichever is greater.


**Pickup test**

The pickup is set at 0.2 pu, which makes the operate current  $0.2 \times 5 = 1$  A. The per unit value is based on the largest CT primary rating. In this case, because all the CTs are 2000:5, the pickup is  $0.2 \times 2000$  on the primary or  $0.2 \times 5$  on the secondary.

To test the pickup value, use a pulsed linear ramp test starting with two equal currents 180° apart. Then increase or decrease one of the currents until the test set receives a sense.

1. Set the initial values to 2 A on each source, one set to 0° and the other set to 180°. This results in zero differential current.
2. Set the pulse duration to 50 ms with a wait time of 50 ms.
3. Set the delta current to -0.01 A with a current limit of 0 A.
4. Select current source 2 as your action source.
5. Start the test.

Figure 7: Pickup test pulsed ramp setup



View the test points live on the Operating Characteristic Graph View. The restraint current is the maximum, 1 A in this case, which is 0.4 pu. The red X starts at (0.4,0) and rises to the differential characteristic.

Figure 8: Pickup test view




Figure 9: Pickup test result

Test Points									
Expected		Measured Results				Tolerance			Aux Timers
Op	Current	Op	Current	Δ		Minus	Plus	Severity	
Value ▾	1.000 A	Op	0.950 A	-0.050 A	✓	0.100 A	0.100 A	Error ▾	
						Tolerance Type		Absolute ▾	

Accuracy is  $\pm 2\%$  of 5 A, or 0.100 A.

## Slope 1 test

Slope 1 can be checked in a similar way because the restraint quantity is less than the continuous amp limit of the relay.

The settings have a 25% slope with a low breakpoint of 2 pu. Choosing a restraint of 1.5 pu results in a (required differential current of  $1.5 * 0.25 = 0.375$  pu. The current on source 2 must then be  $(1.5 - 0.375) * 5 = 5.63$  A.

To test slope 1, use a pulsed linear ramp test starting with equal currents  $180^\circ$  apart. Increase or decrease one of the currents until the test set receives a sense.

1. Set the initial values to 7.5 A on each source, one set to  $0^\circ$  and the other set to  $180^\circ$ .

2. Set the pulse duration to 50 ms with a wait time of 50 ms.
3. Set the delta current to -0.01 A with a current limit of 0 A.
4. Select current source 2 as your action source.
5. Start the test.

Figure 10: Slope 1 test pulsed ramp setup

Pulsed Linear Ramp, Current (IB) ... ProTeST Equivalent: PRAMPI

Test Points	
Expected	Actual
5.630 A	M

Test Parameters	
Name	Value
A	Offset Current: 7.500 A
B	Offset Duration: 1.000 s
C	Initial Current: 7.500 A
D	Pulse Duration: 0.050 s
E	Wait: 0.050 s
F	± Delta Current: -0.010 A
G	Current Limit: 0.000 A

Fault details	
Fault type	None
Voltage	0.00 V

---

Action State Summary			Control Panel		
Sources		Connections	Amplitude	Phase	Frequency
Name	DC	Hi Lo			
VA	<input type="checkbox"/>	1	0.0 V	0.0 °	60.000 Hz
VB	<input type="checkbox"/>	1	0.0 V	0.0 °	60.000 Hz
VC	<input type="checkbox"/>	1	0.0 V	0.0 °	60.000 Hz
IA	<input type="checkbox"/>	1	7.50 A	0.0 °	60.000 Hz
IB	<input type="checkbox"/>	1	Action	180.0 °	60.000 Hz
IC	<input type="checkbox"/>	1	0.00 A	0.0 °	60.000 Hz

Sense Settings			
Channel ID	Label	Connections	Sense Condition
S1	LN1		0 > 1
		Sense Delay	0.000 s
		Sense Duration	0.000 s
		Play sound when relay operates	<input type="checkbox"/>

Figure 11: Slope 1 test view






Figure 12: Slope 1 test results

Test Points									
Expected		Measured Results			Tolerance			Aux	
Op	Current	Op	Current	Δ	Minus	Plus	Severity	Timers	
Value	5.630 A	Op	5.610 A	-0.020 A	0.225 A	0.225 A	Error		
Tolerance Type							Absolute		

Accuracy is ±3% of 7.5 A, or 0.225 A.

## Slope 2 test

Slope 2 begins at breakpoint 2, which is set at 8.0 pu and the slope is 50%. Since 8.0 pu is above the 4.0 pu continuous rating of the input, a test cannot hold the restraint current at 40 A. Test set source limitations also can come into play, requiring the user to parallel sources to get the higher magnitude currents.

For slope 2, the restraint quantity needs to be 8 pu or 40 A. The test requires using two paralleled sources each set at half of the test value. The differential current needs to be 50%, so  
 $Source\ 2 = 8(1 - 0.5) * 5 = 20\ A$ .

To test slope 2, use a pulsed linear ramp with three sources. Fix one source at 180° and the other two at 0°, then increase their magnitudes until the test set receives a sense.

1. Parallel sources 1 and 3 going into the relay.
2. Set the initial values to 10 A on sources 1 and 3, set to 0°, and source 2 set to 20 A and 180°.
3. Set the pulse duration to 50 ms with a wait time of 50 ms.
4. Set the delta current to 0.1 A with a current limit of 25 A.
5. Select current sources 1 and 3 as your action sources.
6. Start the test.

Figure 13: Slope 2 pulsed ramp setup

Pulsed Linear Ramp, Current (IA, IC) ... ProTest Equivalent: PRAMPI

Test Points	
Expected	Actual
20.000 A	#

Test Parameters	
Name	Value
A	Offset Current: 10.000 A
B	Offset Duration: 1.000 s
C	Initial Current: 10.000 A
D	Pulse Duration: 0.050 s
E	Wait: 0.050 s
F	+ Delta Current: 0.500 A
G	Current Limit: 25.000 A

Fault details	
Fault type	Value
Fault type	None
Voltage	0.00 V

---

Action State Summary			
Sources	Connections	Action	
Name	DC	CT/VT Ratio	Frequency
VA	<input type="checkbox"/>	1	0.0 V
VB	<input type="checkbox"/>	1	0.0 V
VC	<input type="checkbox"/>	1	0.0 V
IA	<input type="checkbox"/>	1	0.0 V
IB	<input type="checkbox"/>	1	20.00 A
IC	<input type="checkbox"/>	1	0.0 V

Control Panel		
Amplitude	Phase	Frequency
0.0 V	0.0 °	60.000 Hz
0.0 V	0.0 °	60.000 Hz
0.0 V	0.0 °	60.000 Hz
20.00 A	180.0 °	60.000 Hz
0.0 V	0.0 °	60.000 Hz

Sense Settings			
Channel ID	Label	Connections	Sense Condition
S1	LN1	LN1	0->1

Sense Delay	0.000 s
Sense Duration	0.000 s
Play sound when relay operates	<input type="checkbox"/>

Figure 14: Slope 2 test view




Figure 15: Slope 2 test results

Test Points										
Expected		Measured Results				Tolerance			Aux Timers	
Op	Current	Op	Current	$\Delta$	Minus	Plus	Severity			
Value <input type="text" value="20.000 A"/>	20.000 A	Op	20.100 A	0.100 A	0.600 A	0.600 A	Error			
Tolerance Type							Absolute			


Accuracy is  $\pm 3\%$  of -0 A, or -1.20 A, but because we have current from two sources it is half, or 0.600 A.

## Directional principle check

Now that the characteristic has been verified, the trip operation can be verified quickly by injecting currents that meet the operate conditions.

First, change the output operate being used for test set sense to BUS 1 BIASED OP.

Figure 16: Output contact setting OP



If a restraint value of 15 A or 3 pu is chosen, because there are six feeders in this relay's bus zone,  $K = 0.16$  so source 2 current is  $15 * 0.16 = 2.4$  A. Use the pulsed ramp test for this.



In firmware released after April 2021, the B90 uses an extra protection security enhancement that requires the relay to detect an actual fault disturbance to operate. The fault detection algorithm uses a rate of change of current algorithm to distinguish a fault from non-fault conditions.

1. Set the initial values to 15 A on source 1, set to  $0^\circ$ , and the other set to  $180^\circ$ .
2. Set the pulse duration to 50 ms with a wait time of 50 ms.
3. Set the delta current to  $-0.05$  A with a current limit of 0 A.
4. Select current source 2 as your action source with an initial value of 5A.
5. Start the test.

Figure 17: Directional principle check settings

Pulsed Linear Ramp, Current (IB) ... ProTesT Equivalent: PRAMPI

Test Points	
Expected	Actual
2.400 A	*

Note: Pulse ends on Sense

Test Parameters	
Name	Value
A	Offset Current 5.000 A
B	Offset Duration 1.000 s
C	Initial Current 5.000 A
D	Pulse Duration 0.050 s
E	Wait 0.050 s
F	± Delta Current -0.050 A
G	Current Limit 0.000 A

Fault details	
Fault type	None
Voltage	0.00 V

Sources			Connections		Action		
Name	DC	CT/VT Ratio	Hi	Lo	Amplitude	Phase	Frequency
VA	<input type="checkbox"/>	1			0.0 V	$0.0^\circ$	60.000 Hz
VB	<input type="checkbox"/>	1			0.0 V	$0.0^\circ$	60.000 Hz
VC	<input type="checkbox"/>	1			0.0 V	$0.0^\circ$	60.000 Hz
IA	<input type="checkbox"/>	1			15.00 A	$0.0^\circ$	60.000 Hz
IB	<input type="checkbox"/>	1			Action	$180.0^\circ$	60.000 Hz
IC	<input type="checkbox"/>	1			0.00 A	$0.0^\circ$	60.000 Hz

Channel ID	Label	Connections	Sense Condition
S1	LN1	LN1	$0 > 1$

Sense Settings	
Sense Delay	0.000 s
Sense Duration	0.000 s
Play sound when relay operates	<input type="checkbox"/>

The relay operates when the source 2 current gets to 2.4 A.

Figure 18: Directional principle test view




Figure 19: Directional principle test results

Test Points									
Expected		Measured Results				Tolerance			Aux Timers
Op	Current	Op	Current	$\Delta$		Minus	Plus	Severity	
Value <input type="button" value="v"/>	2,400 A	Op	2,400 A	0,000 A	<input checked="" type="checkbox"/>	0,450 A	0,450 A	Error <input type="button" value="v"/>	
						Tolerance Type		Absolute <input type="button" value="v"/>	

Accuracy is  $\pm 3\%$  of 15 A, or 0.450 A.

---

## For further assistance

For product support, contact the information and call center as follows:

GE Grid Solutions

650 Markland Street

Markham, Ontario

Canada L6C 0M1

Worldwide telephone: +1 905 927 7070

Europe/Middle East/Africa telephone: +34 94 485 88 54

North America toll-free: 1 800 547 8629

Fax: +1 905 927 5098

Worldwide e-mail: [multilin.tech@ge.com](mailto:multilin.tech@ge.com)

Europe e-mail: [multilin.tech.euro@ge.com](mailto:multilin.tech.euro@ge.com)

Website: <http://www.gegridsolutions.com/multilin/>