



INSTRUCTIONS

GEK-45402
INSERT GEK-34059

A. C. PILOT WIRE CHECKING RELAY FOR TWO WAY TRANSFER TRIP

TYPE BBA99AB001E

INTRODUCTION


This supplement in addition to GEK-34059 constitutes the instruction for type BBA99AB001E relay.

DESCRIPTION

Special relay BBA99AB001E is similar to relay BBA11B except as follow

1. The internal connections are as shown in Fig. 1 of this supplement.
2. The trip unit pickup is 5 milliamperes D.G.

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company.



HIGH VOLTAGE STUDS (28 & 29) PROJECT THRU REAR OF CASE. LEADS & BUSHINGS MUST BE REMOVED FROM STUDS 28 & 29 BEFORE CRADLE CAN BE WITHDRAWN.

Fig. 1 (0257A8352-0) Fig. 1 Internal connections diagram for the BBA99AB(-) Relay