



INSTRUCTIONS

DFP1*C***01**

DFP100 WITH REDUCED MINIMUM SETTING ON TOC AND NEGATIVE SEQUENCE PICKUP

INTRODUCTION

These instructions, together with GEK-105545, constitute the complete instructions for the DFP1*C*****01.

DESCRIPTION

This relay has the following differences from the standard relay described in GEK-105545:

The range for Negative Sequence TOC has been changed to 0.6 - 5.00 amps rms.

These instructions do not purport to cover all details or variations in equipment nor provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company. To the extent required the products described herein meet applicable ANSI, IEEE and NEMA standards; but no such assurance is given with respect to local codes and ordinances because they vary greatly.

Calculations of Settings

1. In the **Calculation of Settings** section of the GEK-105545 Instruction Book, replace the following items with the corresponding items in Table 3-1:

Table 3-1. DFP100 Relay Settings

CATEGORY	SETTING NAME	RANGE	INCREMENT	DEFAULT
NEGATIVE SEQUENCE { SET }	DISABLE NEG. SEQ. DT	1(YES)/0(NO)		YES
	PICKUP NEG. SEQ. DT	1.00 - 12.00	0.01 amps	1.00
	DELAY NEG. SEQ. DT	0 - 100.00	0.01 seconds	0
	DISABLE NEG. SEQ. TOC	1(YES)/0(NO)		YES
	CURVE NEG. SEQ. TOC	1 (EXT INV 2 (VERY INV.) 3 (INVERSE)		3 (INVERSE)
	PICKUP NEQ. SEQ. TOC	0.60 - 5.00	0.01 amps	1.00
	NEG. SEQ. TOC TIME DIAL	0.5 - 10.0	0.1	10.0

2. Replace the following paragraphs in the **Time Overcurrent Settings** section.

Pickup Neg. Seq. TOC - This setting establishes the pickup level of the Neg. Seq. TOC function. the range is 0.60 - 5.00 amps RMS.



GE Power Management

215 Anderson Avenue
 Markham, Ontario
 L3R 1B3 Canada
 Telephone (905) 294-6222
www.GEindustrial.com/pm