

SUPPLEMENTARY INSTRUCTIONS

RELAYS WITH EXTERNAL AUXILIARIES

When external resistors and capacitors are furnished with relays they are indentified by means of serial numbers. These numbers are of the form KX-1023 or OA-2155. The purpose of these numbers is to insure that each relay, when installed, will be provided with the same auxiliaries with which it was calibrated at the factory.

The reason for this precaution is to eliminate the variation in calibrations of the relays which would otherwise result from the variation in electrical properties of the auxiliaries.

GENERAL  ELECTRIC