



INSTRUCTIONS

GEK-65662
Insert Booklet GEI-10190

DC AUXILIARY RELAY TYPE HGA99AG(-)

INTRODUCTION

These instructions plus those in insert booklet GEI-10190 form the instructions for the HGA99AG(-) relay.

DESCRIPTION

The HGA99AG(-) DC auxiliary relay is similar to the HGA17C relay except the drop-out time delay is nine to ten cycles at rated voltage and on a 60 cycle basis. No factory calibration is made for the pickup time delay.

MODEL NO	VOLTS	FREQUENCY
12HGA99AG001	125	DC

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company.

To the extent required the products described herein meet applicable ANSI, IEEE and NEMA standards; but no such assurance is given with respect to local codes and ordinances because they vary greatly.