



TOL	+/-
A	.06
B	.12
C	.18
D	.25
E	.04


SIZE A	DWG NO 16L0404WH3	SHT 2	REV 3
REV 3	DESCRIPTION UPDATE DWG	DATE 05/15/2012	APPROVED JBC



TERM	uF	kVAR
1	300.9	37.5
2	300.9	37.5



SCHEMATIC DIAGRAM - 212



2x301 UF/TAP
 575 V 1 PH kVBIL
 75 KVAR 60 Hz
 CAT 16L0404WH3 SN
 1.53 GAL.
 MFG DATE
 101N171 READ GEH- 2743

* UP TO +.50[13] CASE BULGE

MAX. TERMINAL TIGHTENING TORQUE 15 FT-LBS
 NP267192A

GE ENERGY FORT EDWARD, N.Y., U.S.A.		SIZE A	<h1>OUTLINE</h1> <h2>16L0404WH3</h2>	
DRAWN E. McGinn	DATE 10/22/1996	SCALE		
ISSUED	DATE 10/23/1996		SHEET 2	CONT ON 3

DISTR. TO