



NOMENCLATURE

1. ALUMINUM BASE FRAME
2. CAPACITOR UNIT
3. COPPER BUS BARS
4. LINE TERMINAL - #4/0 TO 600 MCM
5. GROUND TERMINAL - #6AWG TO 250 MCM
6. BUS ENCLOSURE
7. ACCESS COVER
8. RATING NAMEPLATE
9. OPTIONAL FIELD ASSEMBLED WALL MTG. FRAME



CONNECTION DIAGRAM

CAT 65L919TK2 SERNO
KVAR 150 60Hz 3ph
VOLT 600 DIAG 186C3233FA
CONN Y-CONN
Read instructions: GEH-2728

SIGNATURES		DATE		<div></div> <div>INDUSTRIAL SYSTEMS FORT EDWARD, N.Y., U.S.A.</div>	
DRAWN E.McGINN		9/28/92			
CHECKED					
ENGR					
ISSUED		9/30/93		<div>OUTLINE</div> <div>65L919TK2</div>	
				FIRST MADE FOR:	
CAD SYS. NO.		SIZE C	FSCM NO.	DWG NO. 65L919TK2	REV 1
AUTOCAD		SCALE		SHEET	CONT ON SHT

413

DISTR
TO