



SPECIFICATION OF LOW VOLTAGE CAPACITOR BANK

DW-SERIE: DETUNED FILTER CAPACITOR BANK

BANK :

Type designation	DW16/3+6+6-400-50/189-0812
Rated power	16 kvar
Steps	3+6+6 kvar
Rated frequency	50 Hz
Tuning frequency	189 Hz (7 %)
Rated voltage	400 V
Rated current (rms)	27 A
Insulation level of bank	3 / - kV
Cabinet (W x H x D)	750x1150x320 mm
Total mass of bank	80 kg
Degree of protection	IP 20C
Mounting	indoor on the floor or wall
Temperature category	0 / + 40 °C
Colour	RAL 7035
Cooling fan	Ebm-papst W2S 130-BM
Cable entry from top or bottom	

STEPS 1: 3 kvar/400V

Harmonic currents (dimensioning)	50 / 150 / 250 / 350 f/Hz 5.0 / 0.2 / 1.7 / 0.6 I/A
Rated current (rms)	5.3 A
Rated inductance (iron core reactor)	12.264 mH
Contacteur type	CL45A300MN
Step fuses	3 x gG 10 A
<u>Capacitor unit :</u>	
Type of capacitor unit	ML1D 5/525-50 IP00
Rated voltage	525 V
Rated capacitance (Y)	57.9 µF
Discharging time 75 V	180 s
Reconnection time	60 s

STEPS 2-3: 6 kvar/400V

Harmonic currents (dimensioning)	50 / 150 / 250 / 350 f/Hz 9.9 / 0.3 / 3.4 / 1.2 I/A
Rated current (rms)	10.6 A
Rated inductance (iron core reactor)	6.132 mH
Contacteur type	CL45A300MN
Step fuses	3 x gG 16 A
<u>Capacitor unit :</u>	
Type of capacitor unit	ML1D 10/525-50 IP00
Rated voltage	525 V
Rated capacitance (Y)	115.6 µF
Discharging time 75 V	180 s
Reconnection time	60 s



Power factor controller:

Type

NC-12

STANDARDS :

SGS FI 26351 certificate
IEC/EN 61439-1&2 (bank)
IEC/EN 60831 1&2 (capacitors)
IEC/EN 60529 (IP-code)

Voltage dimensioning :

Suitable for continuous overvoltage
Harmonic voltages
Capacitor unit nominal voltage

1.1 x Un
U₃= 0,5 %, U₅= 6 %, U₇= 5%
525 V