



# INSTRUCTIONS

GEK-34145  
Insert Booklet- GEK-34123

## RECLOSING RELAY

NLR21C

### INTRODUCTION

This supplement in addition to GEK-34123 constitutes the instructions for the NLR21C type relay.

### DESCRIPTION

Relay NLR21C is similar to relay NLR21A except for a fixed cam lobe attached to the indicating dial (of the stepping switch) located in the zero position to provide instantaneous reclosing. There are also three adjustable cam lobes for delayed reclosure. The internal and external connections diagrams are shown in Figures 4 and 6 respectively in the attached booklet. For APPLICATION AND SETTINGS refer to the sections in the attached booklet.

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company.

**POWER SYSTEMS MANAGEMENT DEPARTMENT**

**GENERAL  ELECTRIC**

PHILADELPHIA, PA.



---

***GE Power Management***

**215 Anderson Avenue  
Markham, Ontario  
Canada L6E 1B3  
Tel: (905) 294-6222  
Fax: (905) 201-2098  
[www.ge.com/indsys/pm](http://www.ge.com/indsys/pm)**